



Commonwealth Edison

Dresden Nuclear Power Station

R.R. #1

Morris, Illinois 60450

Telephone 815/942-2920

DSB

June 12, 1979

BBS LTR #79-471

James G. Keppler, Regional Director
Directorate of Regulatory Operations - Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Reportable Occurrence Report #79-011/03L-0, Docket #050-249 is hereby submitted to your office in accordance with Dresden Nuclear Power Station Technical Specification 6.6.B.2.(a), reactor protection system or engineered safety feature instrument settings which are found to be less conservative than those established by the technical specifications but which do not prevent the fulfillment of the functional requirements of affected systems.

for *Arthur M. Roberts*
B.B. Stephenson
Station Superintendent
Dresden Nuclear Power Station

BBS:lbg

Enclosure

cc: Director of Inspection & Enforcement
Director of Management Information & Program Control
File/NRC

7906190437

JUN 18 1979

A002
5/1



Commonwealth Edison

DEVIATION REPORT

DVR NO. STA UNIT YEAR NO.
D-12 - 3 - 79 - 17

PART 1 TITLE OF DEVIATION

IRM #17 Rod Block 1% above Tech. Specs.

OCCURRED
5-17-79 0900
DATE TIME

SYSTEM AFFECTED 700
Neutron Monitoring System

PLANT CONDITIONS

MODE Run PWR(MWT) 2427.75 , LOAD(MWE) 812

TESTING
☒ YES ☐ NO

DESCRIPTION OF EVENT

IRM #17 was found to generate a Hi alarm at 109% which is 1% above the \leq 108/125 Tech. Spec.
Rod Block limit.

DESCRIPTION OF CAUSE

Both Hi end points shifted about 1% higher than last surveillance instrument drift.

OTHER APPLICABLE INFORMATION

Adjusted set-point to 106%↑ as per DIS 700-4 and tested several times for repeatability.

EQUIPMENT ☐ YES
FAILURE ☒ NO

DR NO.
N/A

WR NO.
N/A

Alan R. Zapatocky
RESPONSIBLE SUPERVISOR

5-17-79
DATE

PART 2 OPERATING ENGINEERS COMMENTS

Minimal safety significance since redundant channels were operable.

TYPE OF DEVIATION
REPORTABLE OCCURRENCE

☐ 14 DAY ☐ 10CFR21
☒ 30 DAY NOTIFICATION
6.6.B.2a

EVENT OF POTENTIAL
PUBLIC INTERESTTECH SPEC
VIOLATIONNON-REPORTABLE
OCCURRENCEANNUAL
REPORTING

YES ☒
NO ☐

SAFETY-
RELATED
WR ISSUED

YES ☐
NO ☒

REPORTABLE OCCURRENCE
NUMBER

X- 79-11 - 03L-0

ACTION ITEM NO.

N/A

PROMPT ON-SITE NOTIFICATION

A. Roberts Asst. Supt

5/18/79

0930

TITLE

DATE

TIME

N/A

DATE

TIME

24-HOUR NRC NOTIFICATION

☐ TPH N/A
REGION III DATE TIME
☐ TGM N/A
REGION III & DOL DATE TIME

PROMPT OFF-SITE NOTIFICATION

F. A. Palmer

5/18/79

10:48

TITLE

DATE

TIME

J. R. Gilliom

5/18/79

10:48

TITLE

DATE

TIME

RESPONSIBLE COMPANY OFFICER INFORMED OF 10CFR21
CONDITIONS AND THEIR REPORT TO NRC

TITLE

DATE

TIME

REVIEW AND COMPLETED

C. E. Sargent *C E Sargent*
OPERATING ENGINEER

5/18/79
DATE

ACCEPTANCE BY STATION REVIEW
AS REQUIRED

DATE

RESOLUTION APPROVED AND
AUTHORIZED FOR DISTRIBUTION

6-13-79

6/13/79

Arthur M Roberts
for STATION SUPERINTENDENT

6/13/79
DATE