NRC FORM 366
(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

	Field	Value
01	LICENSEE CODE (2)	I L D R S 3
	LICENSE NUMBER (3)	0 0 - 0 0 0 0 0 - 0 0
	LICENSE TYPE (4)	4 1 1 1 1
	CAT (5)	
01 CON'T	REPORT SOURCE (6)	L
	DOCKET NUMBER (7)	0 5 0 0 0 2 4 9
	EVENT DATE (8)	0 5 1 7 7 9
	REPORT DATE (9)	0 6 1 2 7 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

While performing monthly surveillance DIS 700-4, IRM 17 was found to trip at 109/125 instead of Tech. Spec. required trip Table 3.2.3 of </= 108/125 of full scale. Safety implications minimal since remaining channels in the "B" system and all channels in "A" safety system were operable. Last occurrence of this nature was reported in R.O. 78-01-03L-0.

SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
I A	E	G	I N S T R U	Q	Z

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
7 9	—	0 1 1	/	0 3	L	—	0

ACTION TAKEN (18)	FUTURE ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	NPRD-4 FORM SUB. (24)	PRIME COMP. SUPPLIER (25)	COMPONENT MANUFACTURER (26)
E	Z	Z	Z	0 0 0 0	N	Y	N	G 0 8 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

Cause attributed to instrument drift. IRM #17 was readjusted to 106% increasing and DIS 700-4 was successfully completed. IRM's will continue to be tested monthly per DIS 700-4.

FACILITY STATUS (28)	% POWER (29)	OTHER STATUS (30)	METHOD OF DISCOVERY (31)	DISCOVERY DESCRIPTION (32)
E	0 9 6	N/A	B	Routine Surveillance

ACTIVITY RELEASED (33)	CONTENT OF RELEASE (34)	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
Z	Z	N/A	N/A

PERSONNEL EXPOSURES

NUMBER (37)	TYPE (38)	DESCRIPTION (39)
0 0 0	Z	N/A

PERSONNEL INJURIES

NUMBER (40)	DESCRIPTION (41)
0 0 0	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

TYPE (42)	DESCRIPTION
Z	N/A

7906190447

PUBLICITY

ISSUED (44)	DESCRIPTION (45)
N	N/A

NRC USE ONLY

NAME OF PREPARER J. Dunbar PHONE: X-489