NRC FORM 366
(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: [| | | | |] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	LICENSEE CODE (2)	I L D R S 3
	LICENSE NUMBER (3)	0 0 - 0 0 0 0 0 - 0 0
	LICENSE TYPE (4)	4 1 1 1 1
	CAT (5)	

CON'T 0 1	REPORT SOURCE (6)	L
	DOCKET NUMBER (7)	0 5 0 0 0 2 4 9
	EVENT DATE (8)	0 5 1 7 7 9
	REPORT DATE (9)	0 6 1 2 7 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While performing monthly surveillance DIS 700-4, IRM 17 was found to trip at 109/125

0 3 instead of Tech. Spec. required trip Table 3.2.3 of </= 108/125 of full scale. Safety

0 4 implications minimal since remaining channels in the "B" system and all channels in

0 5 "A" safety system were operable. Last occurrence of this nature was reported in

0 6 R.O. 78-01-03L-0.

0 7

0 8

0 9	SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
	I A	E	G	I N S T R U	Q	Z

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	7 9	—	0 1 1	/	0 3	L	—	0

ACTION TAKEN (18)	FUTURE ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	NPRD-4 FORM SUB. (24)	PRIME COMP. SUPPLIER (25)	COMPONENT MANUFACTURER (26)
E	Z	Z	Z	0 0 0 0	N	Y	N	G 0 8 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Cause attributed to instrument drift. IRM #17 was readjusted to 106% increasing and

1 1 DIS 700-4 was successfully completed. IRM's will continue to be tested monthly per

1 2 DIS 700-4.

1 3

1 4

1 5	FACILITY STATUS (28)	% POWER (29)	OTHER STATUS (30)	METHOD OF DISCOVERY (31)	DISCOVERY DESCRIPTION (32)
	E	0 9 6	N/A	B	Routine Surveillance

1 6	ACTIVITY RELEASED (33)	CONTENT OF RELEASE (34)	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
	Z	Z	N/A	N/A

PERSONNEL EXPOSURES

1 7	NUMBER (37)	TYPE (38)	DESCRIPTION (39)
	0 0 0	Z	N/A

PERSONNEL INJURIES

1 8	NUMBER (40)	DESCRIPTION (41)
	0 0 0	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

1 9	TYPE (42)	DESCRIPTION
	Z	N/A

7906190447

PUBLICITY

2 0	ISSUED (44)	DESCRIPTION (45)	NRC USE ONLY
	N	N/A	

NAME OF PREPARER J. Dunbar PHONE: X-489