



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

June 11, 1979

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

REGULATORY DOCKET FILE COPY

Subject: Dresden Station Unit 3
Cable Tunnel Fire Protection System
NRC Docket No. 50-249

Reference (a): R. F. Janecek letter to H. R. Denton
dated March 7, 1979

Dear Mr. Denton:

Reference (a) transmitted revised drawings of the Dresden Unit 3 cable tunnel sprinkler system for your review.

Subsequent to the above information transmittal, discussions with the NRC Staff have resulted in an additional modification to the sprinkler system.

It was agreed in discussions with the Staff that the cable trays at the west end of the tunnel would be modified such that one header with a separate isolation valve and its associated sprinkler heads would protect the upper three tiers of cable trays which includes the top tray containing Division II safety-related cables. A second header with a separate isolation valve and its associated sprinkler heads would protect the lower two tiers of cable trays, including the bottom tray which contains Division I safety-related cables.

The system remains a wet pipe system.

Please address any questions you may have concerning this matter to this office.

Thirty (30) copies of this letter are provided for your use.

Very truly yours,

Robert F. Janecek
Robert F. Janecek
Nuclear Licensing Administrator
Boiling Water Reactors

7907050290

A006
S 1/0