(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
0 1	LICENSEE CODE (2)	I L D R S 2
	LICENSE NUMBER (3)	0 0 - 0 0 0 0 - 0 0 0
	LICENSE TYPE (4)	4 1 0 0 0
	CAT (5)	
CON'T 0 1	REPORT SOURCE (6)	L
	DOCKET NUMBER (7)	0 5 0 0 0 2 3 7
	EVENT DATE (8)	0 6 0 5 7 9
	REPORT DATE (9)	0 7 0 3 7 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 Radwaste foreman discovered water spraying in the radwaste reboiler room
0 3 and the radioactively contaminated floor flooded. Water was discovered
0 4 leaking onto the ground around building from under doors and along foundation.
0 5 Analysis of water yielded activity ≤ 1.25E4 pCi/l (CS134 8%, CS137 43%
0 6 CO60 48%) with a total estimated release from building of ≤ 10uCi. Water
0 7 remained close to building and cement pads outside doors and within restricted
0 8 area boundry.

0 9	SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
	M A	E	X	X X X X X X	Z	Z

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	7 9	—	0 4 0	/	0 3	L	—	0

ACTION TAKEN (18)	FUTURE ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	NPRD-4 FORM SUB. (24)	PRIME COMP. SUPPLIER (25)	COMPONENT MANUFACTURER (26)
X	X	Z	Z	0 0 0 0	N	N	X	X 9 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Clean demin water hose ruptured. Hose water supply was isolated, area was secured,
1 1 and water sample taken. Contaminated soil near building removed and barreled for
1 2 shipment. Station Nuclear Engineering has been requested to evaluate installation of
1 3 a floor drain in the reboiler room to the radwaste sump.
1 4

1 5	FACILITY STATUS (28)	% POWER (29)	OTHER STATUS (30)	METHOD OF DISCOVERY (31)	DISCOVERY DESCRIPTION (32)
	E	0 9 1	N/A	B	Observation by radwaste personnel

1 6	ACTIVITY RELEASED (33)	CONTENT OF RELEASE (34)	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
	L	P	10 microcuries	Radwaste bldg. to ground along foundation

PERSONNEL EXPOSURES

1 7	NUMBER (37)	TYPE (38)	DESCRIPTION (39)
	0 0 0	Z	N/A

PERSONNEL INJURIES

1 8	NUMBER (40)	DESCRIPTION (41)
	0 0 0	N/A

LOSS OF OR DAMAGE TO FACILITY

1 9	TYPE (42)	DESCRIPTION (43)
	Z	N/A

PUBLICITY

2 0	ISSUED (44)	DESCRIPTION (45)
	N	N/A

7907110 433

NRC USE ONLY

NAME OF PREPARER Frederick Jones PHONE: Ext. 217

GPO 917-923