(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 LICENSEE CODE: I L D R S 3 (2) LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3) LICENSE TYPE: 4 1 1 1 1 (4) CAT (5)

CON'T 01 REPORT SOURCE: L (6) DOCKET NUMBER: 0 5 0 0 0 2 4 9 (7) EVENT DATE: 0 6 0 6 7 9 (8) REPORT DATE: 0 7 0 3 7 9 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While performing DOS 1400-1, the core spray pump 3A gland supply line was found leaking

03 at connection to the pump casing. 3A core spray pump still met rated flow and dis-

04 charge pressure limits as required by Tech. Specs. Safety significance minimal, since

05 3B core spray pump, LPCI system, and Unit 3 diesel generator operable. This is first

06 occurrence of this nature.

07

08

09 SYSTEM CODE: S F (11) CAUSE CODE: E (12) CAUSE SUBCODE: B (13) COMPONENT CODE: P I P E X X (14) COMP. SUBCODE: A (15) VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR: 7 9 — SEQUENTIAL REPORT NO.: 0 1 4 / OCCURRENCE CODE: 0 3 REPORT TYPE: L — REVISION NO.: 0

ACTION TAKEN: A (18) FUTURE ACTION: Z (19) EFFECT ON PLANT: Z (20) SHUTDOWN METHOD: Z (21) HOURS (22): 0 0 0 0 ATTACHMENT SUBMITTED: N (23) NPRD-4 FORM SUB.: N (24) PRIME COMP. SUPPLIER: N (25) COMPONENT MANUFACTURER: G 0 8 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Cause attributable to leaky fitting. Fitting was replaced, and surveillance completed

11 to prove pump operable. No further corrective action deemed necessary.

12

13

14

15 FACILITY STATUS: E (28) % POWER: 0 9 5 (29) OTHER STATUS (30): N/A METHOD OF DISCOVERY: B (31) DISCOVERY DESCRIPTION (32): Operating Surveillance

16 ACTIVITY RELEASED: Z (33) CONTENT OF RELEASE: Z (34) AMOUNT OF ACTIVITY (35): N/A LOCATION OF RELEASE (36): N/A

17 PERSONNEL EXPOSURES NUMBER: 0 0 0 (37) TYPE: Z (38) DESCRIPTION (39): N/A

18 PERSONNEL INJURIES NUMBER: 0 0 0 (40) DESCRIPTION (41): N/A

19 LOSS OF OR DAMAGE TO FACILITY (43) TYPE: Z (42) DESCRIPTION: N/A

7907110554

20 PUBLICITY ISSUED: N (44) DESCRIPTION (45): N/A NRC USE ONLY

NAME OF PREPARER: Gary Smith PHONE: Ext 421