(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
01	Licensee Code (2)	I L D R S 3
01	License Number (3)	0 0 - 0 0 0 0 0 - 0 0
01	License Type (4)	4 1 1 1 1
01	CAT (5)	
CON'T 01	Report Source (6)	L
01	Docket Number (7)	0 5 0 0 0 2 4 9
01	Event Date (8)	0 6 2 1 7 9
01	Report Date (9)	0 7 1 9 7 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While performing monthly surv. DIS 250-1, MSL Hi Flow Isol. Sw. DPIS 3-261-2G tripped
03 at 116.5 PSID. (T.S. limit </= 115.0 PSID at 120% flow; table 3.2.1). The 16 MSL
04 Hi Flow Isol. Sw's provide containment isolation when required. Safety significance
05 minimal. Both trip systems were operable and would have provided containment isolation
06 at 108.5 PSID, conservative to T.S. limit. Similar events ref. under R.O. 79-001/
07 03L-0; 78-022, 027, 028, 033 & 050/03L-0 Docket 050-249.
08

09	System Code (11)	Cause Code (12)	Cause Subcode (13)	Component Code (14)	Comp. Subcode (15)	Valve Subcode (16)
	C D	E	E	I N S T R U	S	Z

(17) LER/RO Report Number	Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
	7 9	—	0 1 6	/	0 3	L	—	0

Action Taken (18)	Future Action (19)	Effect on Plant (20)	Shutdown Method (21)	Hours (22)	Attachment Submitted (23)	NPRD-4 Form Sub. (24)	Prime Comp. Supplier (25)	Component Manufacturer (26)
A	Z	Z	Z	0 0 0 0	N	Y	N	B 0 8 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Cause attributable to failed mercury sw. which has been replaced with a new Mercoid
11 Type 3-11. DPIS 3-261-2G was adjusted to trip at 110.5 PSID and its repeatability was
12 verified using DIS 250-1. All MSL Hi Flow Sw's will continue to be tested monthly.
13
14

15	Facility Status (28)	% Power (29)	Other Status (30)	Method of Discovery (31)	Discovery Description (32)
	E	0 9 7	NA	B	Surveillance Testing

16	Activity Released (33)	Content of Release (34)	Amount of Activity (35)	Location of Release (36)
	Z	Z	NA	NA

17	Personnel Exposures Number (37)	Type (38)	Description (39)
	0 0 0	Z	NA

18	Personnel Injuries Number (40)	Description (41)
	0 0 0	NA

19	Loss of or Damage to Facility Type (42)	Description (43)
	Z	NA

7907250372 8

20	Publicity Issued (44)	Description (45)	NRC USE ONLY
	N	NA	

NAME OF PREPARER Carl Lindberg PHONE: X-289

GPO 917-926