(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01	LICENSEE CODE	LICENSE NUMBER	LICENSE TYPE	CAT
	I L D R S 2 (2)	0 0 - 0 0 0 0 0 - 0 0 (3)	4 1 1 1 1 (4)	(5)

CON'T

01	REPORT SOURCE	DOCKET NUMBER	EVENT DATE	REPORT DATE
	L (6)	0 5 0 0 0 2 3 7 (7)	0 6 2 1 7 9 (8)	0 7 1 9 7 9 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 The "A" floor drain sample tank was filled from max recycle evaporator
03 distillates and placed on recirc for sampling. Sampling results yielded a
04 concentration of 9.2 E06 pCi/l with a total of 0.74Ci. This exceeded the
05 0.7 Ci tank storage limit as defined in 3.8.D of the Technical Specs.
06 Event had minimal safety significance as there was no significant
07 increase in radiation exposures and no radioactivity was released.
08

09	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
	M A (11)	A (12)	B (13)	X X X X X X (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	7 9	—	0 4 3	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
H (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	Z (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Evap. bottoms tank was pressurized to clear plugged "B" max recycle evap.
11 dump line. When line cleared a temporary surge in evap. level resulted in
12 concentrate carry-over with distillate. Floor drain sample tank processed
13 within 24 hrs. required by T.S. 3.8.D. Operations instructed on careful examination
14 of frequency and conditions for evap. dump to prevent recurrence.

15	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
	E (28)	0 9 8 (29)	N/A	B (31)	Routine sample analysis

16	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
	Z (33)	Z (34)	N/A	N/A

PERSONNEL EXPOSURES

17	NUMBER	TYPE	DESCRIPTION (39)
	0 0 0 (37)	Z (38)	N/A

PERSONNEL INJURIES

18	NUMBER	DESCRIPTION (41)
	0 0 0 (40)	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

19	TYPE	DESCRIPTION
	Z (42)	N/A

7907260720 S

PUBLICITY

20	ISSUED	DESCRIPTION (45)	NRC USE ONLY
	N (44)	N/A	

NAME OF PREPARER Frederick A. Jones PHONE: 815-942-2920 ext 217

GPO 917-925