(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01	LICENSEE CODE	LICENSE NUMBER	LICENSE TYPE	CAT
	I L D R S 2 (2)	0 0 - 0 0 0 0 0 - 0 0 (3)	4 1 1 1 1 (4)	(5)

CON'T 01	REPORT SOURCE	DOCKET NUMBER	EVENT DATE	REPORT DATE
	L (6)	0 5 0 0 0 2 3 7 (7)	0 7 0 9 7 9 (8)	0 8 0 3 7 9 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While both units were at steady power, a surveillance test was performed on U 2/3 D/G.
03 While loading the diesel, stop light came on and D/G cooling water pump trouble alarm
04 came up. Operator manually tripped output breakers. Safety significance minimal be-
05 cause other redundant D/G's were immediately proved to be operable and off-site power
06 was available at all times.
07
08

09	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
	E E (11)	E (12)	X (13)	Z Z Z Z Z Z (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	7 9	—	0 4 4	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
X (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	Z (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 After trip, diesel was run three times successfully and has been run numerous times
11 since. D/G clg water pp, engine clg water pp, LWS switch, and TD3 relay were checked
12 and functioned normally. No cause of the trip could be identified. This specific
13 diesel failure is not repetitive.
14

15	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
	E (28)	0 9 7 (29)	NA	B (31)	Surveillance test

16	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
	Z (33)	Z (34)	NA	NA

17	PERSONNEL EXPOSURES NUMBER	TYPE	DESCRIPTION (39)
	0 0 0 (37)	Z (38)	NA

18	PERSONNEL INJURIES NUMBER	DESCRIPTION (41)
	0 0 0 (40)	NA

19	LOSS OF OR DAMAGE TO FACILITY (43) TYPE	DESCRIPTION
	Z (42)	NA

20	PUBLICITY ISSUED	DESCRIPTION (45)	NRC USE ONLY
	N (44)	NA	

7908080387

NAME OF PREPARER J. Chan PHONE: X-421

GPO 917-926