

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	I	L	D	R	S	2	0	0	-	0	0	0	0	0	0	0	0	0	4	1	1	1	1	4	5				
8	9	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE				30	57	CAT 58		80

0	1	L	0	5	0	0	0	2	3	7	0	8	1	6	7	9	0	9	1	1	7	9	9	
8	9	REPORT SOURCE		60	61	DOCKET NUMBER					68	69	EVENT DATE				74	75	REPORT DATE					80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While synchronizing the Unit 2 Diesel Generator to bus 24-1, the output circuit

0 3 | breaker closed initially but then tripped open as load was increased. The diesel

0 4 | was declared inoperable. Safety significance of event was minimized because re-

0 5 | dundant diesel remained operable and off-site power was available.

0 6 |

0 7 |

0 8 |

0	9	E	E	E	A	C	K	T	B	R	K	A	Z				
9	10	11	12	13	14	15	16	17	18	19	20	21	22				
17	LER/RO REPORT NUMBER		EVENT YEAR		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE			COMP. SUBCODE		VALVE SUBCODE		REVISION NO.	
21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
X	Z	Z	Z	0	0	0	0	N	N	N	G	0	8	0			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause of this event could not be determined. Circuit breaker was tested and

1 1 | operated 22 times with no failure. Breaker returned to service and diesel tested

1 2 | per DOS 6600-1 and declared operable. No further corrective action is deemed

1 3 | necessary at this time.

1 4 |

1	5	E	0	9	0	N/A	B	Operator Observation		
7	8	9	10	11	12	13	14	15		
FACILITY STATUS		% POWER			OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	

1	6	Z	Z	N/A	N/A		
7	8	9	10	11	12		
ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE	

1	7	0	0	0	Z	N/A
7	8	9	10	11	12	13
PERSONNEL EXPOSURES NUMBER		TYPE		DESCRIPTION		

1	8	0	0	0	N/A
7	8	9	10	11	12
PERSONNEL INJURIES NUMBER		DESCRIPTION			

1	9	Z	N/A
7	8	9	10
LOSS OF OR DAMAGE TO FACILITY TYPE		DESCRIPTION	

2	0	N	N/A
7	8	9	10
ISSUED PUBLICITY		DESCRIPTION	

NAME OF PREPARER: J. E. Doyle 7909180410 PHONE: X-265