NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
01	Licensee Code (2)	ILDRS2
01	License Number (3)	00-00000-00
01	License Type (4)	41111
01	CAT (5)	
01	Report Source (6)	L
01	Docket Number (7)	0 5 0 0 0 2 3 7
01	Event Date (8)	0 9 0 8 7 9
01	Report Date (9)	0 9 2 6 7 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 With U-3 at steady state conditions and U-2 at 765 MWe increasing at 5MWe/hr, plant
03 chimney sampling system lost flow for approx. 10 min. Load increase was terminated
04 until standby pump 2/3B was started to re-establish flow. Safety significance of
05 the event was minimal since the steam jet air ejector monitors were operable for
06 chimney monitoring. Flow problems in system have occurred before, but this particular
07 event is the first of its kind.

System Code (11)	Cause Code (12)	Cause Subcode (13)	Component Code (14)	Comp. Subcode (15)	Valve Subcode (16)
MC	E	F	PUMPXX	H	Z

LER/RO REPORT NUMBER (17)

Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
79	—	048	/	03	L	—	0

Action Taken (18)	Future Action (19)	Effect on Plant (20)	Shutdown Method (21)	Hours (22)	Attachment Submitted (23)	NPRD-4 Form Sub. (24)	Prime Comp. Supplier (25)	Component Manufacturer (26)
C	Z	Z	Z	0000	N	N	A	A499

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 U 2/3 A stack gas sample pump seized after natural deterioration of carbon vanes
11 attached to rotor. Due to the operating requirements and the design limits of these
12 pumps, required replacement will be done on a like for like basis.

Line	Facility Status (28)	% Power (29)	Other Status (30)	Method of Discovery (31)	Discovery Description (32)
15	E	082	NA	A	Operator observation

Line	Activity Released (33)	Content of Release (34)	Amount of Activity (35)	Location of Release (36)
16	Z	Z	NA	NA

PERSONNEL EXPOSURES

Line	Number (37)	Type (38)	Description (39)
17	000	Z	NA

PERSONNEL INJURIES

Line	Number (40)	Description (41)
18	000	NA

LOSS OF OR DAMAGE TO FACILITY (43)

Line	Type (42)	Description
19	Z	NA

PUBLICITY

Line	Issued (44)	Description (45)	NRC USE ONLY
20	N	NA	

NAME OF PREPARER Shafic Badran 7910160503 PHONE: Ext. 265/421

GPO 917-926