LICENSEE EVENT REPORT

CONTROL BLOCK: [1] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[1] ILDRS3 (2) 00-0000-00 (3) 41111 (4) (5)
8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

N'T
[1] REPORT SOURCE L (6) 05000249 (7) 100579 (8) 110179 (9)
8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[2] During inspection of pipe supports per I. E. Bulletin 79-14, bent load carrying bolts
[3] were found on supports 1509-M-213 and -214, and variable springs were bottomed out on
[4] supports 1509-M-211 and 216 for the LPCI drywell spray header. The safety significance
[5] of this event was minimal because the redundant LPCI drywell spray header was operable.
[6] Other discrepant pipe supports have been found. (Ref. 79-054/03L-0).
[7]
[8]
8 9 80

[9] SYSTEM CODE SF (11) | CAUSE CODE B (12) | CAUSE SUBCODE C (13) | COMPONENT CODE SUPORT (14) | COMP. SUBCODE A (15) | VALVE SUBCODE Z (16)
8 9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER: EVENT YEAR 79 | — | SEQUENTIAL REPORT NO. 028 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN B (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER G255 (26)
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

[0] The probable cause was a water hammer which occurred prior to installation of ECCS
[1] Jockey pump, to ensure lines remain completely filled at all times. The bent bolts
[2] were replaced, and the variable springs were reset. No further corrective action is
[3] deemed necessary.
[4]
8 9 80

[5] FACILITY STATUS E (28) | % POWER 069 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY C (31) | DISCOVERY DESCRIPTION (32) Hanger Inspection
8 9 10 12 13 44 45 46 80

[6] ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A
8 9 10 11 44 45 80

[7] PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) N/A
8 9 11 12 13 80

[8] PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) N/A
8 9 11 12 80

DUPLICATE
7911090507

[9] LOSS OF OR DAMAGE TO FACILITY TYPE N (42) | DESCRIPTION (43) N/A
8 9 10 80

[0] PUBLICITY ISSUED (44) | DESCRIPTION (45) N/A | NRC USE ONLY
8 9 10 68 69 80

NAME OF PREPARER J. E. Doyle PHONE: Ext. 265

GPO 917-926