





Commonwealth Edison

# DEVIATION REPORT

DVR NO.	STA	UNIT	YEAR	NO.
D-12	-	2	-	79-91

<b>PART 1</b> TITLE OF DEVIATION	OCCURRED
Core Spray Support Failure	10-20-79 2100
	DATE TIME

SYSTEM AFFECTED 1400	PLANT CONDITIONS	TESTING
Core Spray	MODE Run PWR(MWT) 968 LOAD(MWE) 288	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO

DESCRIPTION OF EVENT  
Core Spray pipe support analysis showed pipe supports 2-1404-W-211 and 2-1404-M-209 did not meet seismic criteria. Only 2A core spray line was affected.

DESCRIPTION OF CAUSE  
Section of hanger bent and hanger bolts loose respectively.

OTHER APPLICABLE INFORMATION  
Unit scrambled before surveillances could be initiated. Rx in cold shutdown 0340, 10-21-79

EQUIPMENT FAILURE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	DR NO.	WR NO.	Donald L. Reece	10-29-79
		02519	RESPONSIBLE SUPERVISOR	DATE

**PART 2** OPERATING ENGINEERS COMMENTS  
Rx maintained in the cold shutdown mode of operation until the hanger abnormalities identified above were corrected. 2A core spray line demonstrated operable following the repair.

TYPE OF DEVIATION REPORTABLE OCCURRENCE	EVENT OF POTENTIAL PUBLIC INTEREST	TECH SPEC VIOLATION	NON-REPORTABLE OCCURRENCE	ANNUAL REPORTING	SAFETY-RELATED WR ISSUED
<input type="checkbox"/> 14 DAY <input type="checkbox"/> 10CFR21	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
<input checked="" type="checkbox"/> 30 DAY NOTIFICATION 6.6.B.2.b					

REPORTABLE OCCURRENCE NUMBER	ACTION ITEM NO.	PROMPT ON-SITE NOTIFICATION
79-59-03E-0		R. M. Ragan 10-22-79 0832
		TITLE DATE TIME
		TITLE DATE TIME

24-HOUR NRC NOTIFICATION	PROMPT OFF-SITE NOTIFICATION
<input type="checkbox"/> TPH N/A	F. A. Palmer 10-24-79 9:41
<input type="checkbox"/> TGM N/A	J. R. Gilliom 10-24-79 9:41
REGION III DATE TIME	TITLE DATE TIME
REGION III & DOL DATE TIME	TITLE DATE TIME

RESPONSIBLE COMPANY OFFICER INFORMED OF 10CFR21 CONDITIONS AND THEIR REPORT TO NRC

REVIEW AND COMPLETED John W. Wujciga 10-22-79 OPERATING ENGINEER DATE

ACCEPTANCE BY STATION REVIEW AS REQUIRED [Signature] 11-15-79

DATE

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION [Signature] 11/16/79

STATION SUPERINTENDENT DATE