





Commonwealth Edison

# DEVIATION REPORT

DVR NO.	STA	UNIT	YEAR	NO.
	D-12	- 2	- 79	- 101

**PART 1** TITLE OF DEVIATION: SRM Rod Block Calibration Check

OCURRED DATE: 11-14-79 TIME: 1430

SYSTEM AFFECTED: 700 Neutron Monitoring System

PLANT CONDITIONS: MODE Run PWR(MWT) 2499 LOAD(MWE) 826

TESTING: YES  NO

DESCRIPTION OF EVENT: While doing Surveillance DIS 700-3 found SRM CH. 23 High Alarm to trip at  $1.02 \times 10^5$  cps. Tech. Spec. Limit  $\leq 10^5$  cps.

DESCRIPTION OF CAUSE: Set Point Drift

OTHER APPLICABLE INFORMATION: Adjusted Set Point to  $.98 \times 10^5$  cps

(Dresden Limit  $.98 \times 10^5 + 2 \times 10^3$  cps)

EQUIPMENT FAILURE	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	DR NO. N/A	WR NO. N/A	R. Campbell	11/14/79
				RESPONSIBLE SUPERVISOR	DATE

**PART 2** OPERATING ENGINEERS COMMENTS: Remaining three SRM channel were operable and would have performed the intended function.

TYPE OF DEVIATION REPORTABLE OCCURRENCE	EVENT OF POTENTIAL PUBLIC INTEREST	TECH SPEC VIOLATION	NON-REPORTABLE OCCURRENCE	ANNUAL REPORTING	SAFETY-RELATED WR ISSUED
<input type="checkbox"/> 14 DAY <input checked="" type="checkbox"/> 30 DAY NOTIFICATION 6.6.B.2.a	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>

REPORTABLE OCCURRENCE NUMBER	ACTION ITEM NO.	PROMPT ON-SITE NOTIFICATION
79-63/03L-0	N/A	R. M. Ragan TITLE DATE: 11/26/79 TIME: 0900

24-HOUR NRC NOTIFICATION	PROMPT OFF-SITE NOTIFICATION
<input type="checkbox"/> TPH N/A <input type="checkbox"/> TGM N/A	F. A. Palmer TITLE DATE: 11/26/79 TIME: 3:37 J. R. Gilliom TITLE DATE: 11/26/79 TIME: 3:37

RESPONSIBLE COMPANY OFFICER INFORMED OF 10CFR21 CONDITIONS AND THEIR REPORT TO NRC: John W. Wujciga

REVIEW AND COMPLETED: John W. Wujciga OPERATING ENGINEER DATE: 11/15/79

ACCEPTANCE BY STATION REVIEW AS REQUIRED: [Signature] DATE: 12/1/79

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION: [Signature] DATE: 12-6-79

STATION SUPERINTENDENT