



Commonwealth Edison

DEVIATION REPORT

DVR NO.	STA	UNIT	YEAR	NO.
D-12	2	-	79	-104

PART 1 TITLE OF DEVIATION: "B" SBGTS Flow Control Valve Failure

SYSTEM AFFECTED: 7500 Standby Gas Treatment

PLANT CONDITIONS: U2-2501, U3-1705, LOAD (MWE) U3-550 MWe

TESTING: U2-831 MWe YES, U3-550 MWe NO

OCCURRED: 11-30-79 0130
DATE TIME

DESCRIPTION OF EVENT: While running test for secondary containment integrity, found "B" SBGTS running at 4600 CFM, and flow control valve (A0-2/3-7510-B) failed OPEN.

DESCRIPTION OF CAUSE: Found rubber tube on flow control valve controller faulty and leaking.

OTHER APPLICABLE INFORMATION: Restarted test using "A" SBGTS and continued a 10 hour test run per DOS 7500-2.

EQUIPMENT FAILURE	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	DR NO.	WR NO.	RESONSIBLE SUPERVISOR	DATE
		NA	03350	Donald L. Reece	11-30-79

PART 2 OPERATING ENGINEERS COMMENTS: SBGTS "A" demonstrated operable immediately.

TYPE OF DEVIATION REPORTABLE OCCURRENCE	EVENT OF POTENTIAL PUBLIC INTEREST	TECH SPEC VIOLATION	NON-REPORTABLE OCCURRENCE	ANNUAL REPORTING	SAFETY-RELATED WR ISSUED
<input type="checkbox"/> 14 DAY <input checked="" type="checkbox"/> 30 DAY NOTIFICATION 6.6.B.2.b	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>

REPORTABLE OCCURRENCE NUMBER	ACTION ITEM NO.	PROMPT ON-SITE NOTIFICATION
XX50- 79-065/03L-0	N/A	R. M. Ragan TITLE DATE 12/3/79 TIME 0800

24-HOUR NRC NOTIFICATION	PROMPT OFF-SITE NOTIFICATION
<input type="checkbox"/> TPH N/A REGION III DATE TIME <input type="checkbox"/> TGM N/A REGION III & DOL DATE TIME	F. A. Palmer 12/4/79 3:23 TITLE DATE TIME J. R. Gilliom 12/4/79 3:23 TITLE DATE TIME

RESONSIBLE COMPANY OFFICER INFORMED OF 10CFR21 CONDITIONS AND THEIR REPORT TO NRC: John W. Wujciga
DATE: 12/3/79

REVIEW AND COMPLETED: John W. Wujciga
OPERATING ENGINEER DATE: 12/3/79

ACCEPTANCE BY STATION REVIEW AS REQUIRED: Dennis James
DATE: 12/26/79

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION: [Signature]
STATION SUPERINTENDENT DATE: 12/26/79