

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 I L D R S 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

REPORT SOURCE L 6 0 5 0 0 0 2 3 7 7 1 2 1 3 7 9 8 0 1 1 1 1 8 0 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

2 During normal operations, sample was taken from 2/3 "A" Waste Sample Tank, which
3 contained water processed from the 2/3 Waste Collector Tank. The sample contained
4 6.3 E06 pCi/l at 90 percent level, which corresponds to 0.708 Ci and exceeds the 0.7
5 Ci limit of Tech. Spec. 3.8.D. There were no abnormal releases or safety hazards to
6 the public. This event has occurred before. (Refer to RO 79-43/03L-0 Docket 050-237)

SYSTEM CODE MA 11 CAUSE CODE D 12 CAUSE SUBCODE Z 13 COMPONENT CODE Z Z Z Z Z Z 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16

17 LER/RO REPORT NUMBER 7 9 EVENT YEAR 7 9 SEQUENTIAL REPORT NO. 0 6 6 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0

ACTION TAKEN X 18 FUTURE ACTION G 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER Z 25 COMPONENT MANUFACTURER Z 9 9 9 9 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

0 This was first tank filled with water flushed thru bed previously used in Unit 3
1 Condensate Sys. Sample tank level lowered to 68% and activity to <.7 Ci within 24 hrs.
2 New Operating Order requires tank sampling prior to potentially reaching activity limits
3 using contaminated demin. beds.

5 FACILITY STATUS E 28 % POWER 0 8 1 29 OTHER STATUS N/A 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Activity Analysis of Tank 32

6 ACTIVITY CONTENT Z 33 RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY N/A 35 LOCATION OF RELEASE N/A 36

7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION N/A 39

8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION N/A 41

9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION N/A 43

0 PUBLICITY ISSUED N 44 DESCRIPTION N/A 45

8001150462

NRC USE ONLY