

LIC SEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 I L D R S 3 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

1 REPORT SOURCE: L 6 0 5 0 0 0 2 4 9 7 1 2 1 0 7 9 8 0 1 0 8 8 0 9
8 9 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
2 During normal operations, the high and downscale lights were up for RBM 8 on the front
3 panel with no lights on the back panel. RBM 8 was placed out of service. Personnel
4 immediately verified a non-limiting control rod pattern and successfully tested RBM 7
5 in accordance with Tech. Spec. 3.3.B.5 and Table 3.2.3. There was minimal safety
6 significance and no effect on public health or safety. This was the first occurrence
7 of this type at Dresden.

9 SYSTEM CODE I B (11) CAUSE CODE E (12) CAUSE SUBCODE F (13) COMPONENT CODE I N S T R U (14) COMP. SUBCODE P (15) VALVE SUBCODE Z (16)
17 LER/RO REPORT NUMBER 7 9 (18) EVENT YEAR 7 9 (19) SEQUENTIAL REPORT NO. 0 3 3 (20) OCCURRENCE CODE 0 3 (21) REPORT TYPE L (22) REVISION NO. 0 (23)
ACTION TAKEN A (18) FUTURE ACTION Z (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS 0 0 0 0 (22) ATTACHMENT SUBMITTED N (23) NPRD-4 FORM SUB. N (24) PRIME COMP. SUPPLIER N (25) COMPONENT MANUFACTURER G 0 8 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
0 A fuse was found to be bad in the DC power supply. An Instrument Mechanic checked
1 the fuse holder and associated wiring. No corrosion or damage was found. The fuse
2 was replaced, RBM 8 was tested satisfactorily, and placed back in service. Sur-
3 veillance DIS 700-8 will continue to be done monthly.

5 FACILITY STATUS E (28) % POWER 0 4 7 (29) OTHER STATUS N/A (30) METHOD OF DISCOVERY A (31) DISCOVERY DESCRIPTION Operator Observation (32)
6 ACTIVITY RELEASED Z (33) CONTENT Z (34) AMOUNT OF ACTIVITY N/A (35) LOCATION OF RELEASE N/A (36)
7 PERSONNEL EXPOSURES NUMBER 0 0 0 (37) TYPE Z (38) DESCRIPTION N/A (39)
8 PERSONNEL INJURIES NUMBER 0 0 0 (40) DESCRIPTION N/A (41)
9 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) DESCRIPTION N/A (43)
0 PUBLICITY ISSUED N (44) DESCRIPTION N/A (45)

8001150669