



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

January 28, 1980

Mr. Thomas A. Ippolito, Chief
Operating Reactors - Branch 3
Division of Operating Reactors
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Dresden Station Units 2 and 3
Quad Cities Station Unit 1
Temporary Technical Specification
Changes Concerning ADS Operability
NRC Docket Nos. 50-237/249 and 50-254

References (a): D. L. Peoples letter to Director of
Nuclear Reactor Regulation dated
January 24, 1980

(b): D. L. Peoples letter to J. G. Keppler
dated January 18, 1980

(c): D. L. Peoples letter to J. G. Keppler
dated January 25, 1980

Dear Mr. Ippolito:

This letter is to provide additional information concerning our Technical Specification changes submitted in Reference (a) and to confirm to you statements made in References (b) and (c).

Commonwealth Edison Co. will perform the necessary inspections, tests, and modifications to ensure that the air supply line to the Target Rock ADS valve meets necessary leakage and seismic qualification requirements. This will ensure that the air line from and including the isolation check valve to the ADS valve will remain functional following a seismic event and the accumulator will retain sufficient pressure to ensure ADS valve operability. These actions will be completed during the next scheduled refueling outages at Dresden 2 and 3 and Quad Cities 1 and prior to startup from the current refueling outage on Quad Cities 2. If an outage of insufficient length occurs prior to the refueling outages, the actions will be completed at that time.

A001
S
1/D

8001300435

Mr. Thomas A. Ippolito

- 2 -

January 28, 1980

Please address any questions you may have concerning this matter to this office.

One (1) signed original and fifty-nine (59) copies of this transmittal are provided for your use.

Very truly yours,

Robert F. Peoples

for D. L. Peoples
Director of Nuclear Licensing