NRC FORM 366
(7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | I L D R S 2 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE (9–14) | LICENSE NUMBER (15–25) | LICENSE TYPE (26–30) | CAT (57–58)

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 2 3 7 (7) | 1 2 2 9 7 9 (8) | 0 1 2 3 8 0 (9)
DOCKET NUMBER (60–68) | EVENT DATE (69–74) | REPORT DATE (75–80)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During steady state operation, while conducting a routine plant inspection, the in-
03 tegrity of a fire stop in the vicinity of Bus 28-2 was found to be inadequate. As per
04 T.S. 3.12.F.2, a fire watch was established in affected area. There was no effect
05 upon public health or safety. No previous event of this nature has occurred at Dresden
06
07
08

09 SYSTEM CODE A B (11) | CAUSE CODE A (12) | CAUSE SUBCODE E (13) | COMPONENT CODE X X X X X X (14) | COMP. SUBCODE X (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 9 | — | SEQUENTIAL REPORT NO. 0 6 8 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN B (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Event caused by inadequate supervision. After cables were pulled thru penetration,
11 temporary fire stop was not installed in accordance with procedure DFPP 4175-1. Upon
12 discovery, fire watch posted and temporary fire stop installed. Appropriate personnel
13 admonished as to importance of following requirements for fire stops in fire
14 protection program.

15 FACILITY STATUS E (28) | % POWER 0 9 4 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Routine Inspection

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A

17 PERSONNEL EXPOSURES: NUMBER 0 0 0 (37) | TYPE (38) | DESCRIPTION (39) N/A

18 PERSONNEL INJURIES: NUMBER 0 0 0 (40) | DESCRIPTION (41) N/A

19 LOSS OF OR DAMAGE TO FACILITY (43): TYPE Z (42) | DESCRIPTION N/A

20 PUBLICITY: ISSUED N (44) | DESCRIPTION (45) N/A

NRC USE ONLY

NAME OF PREPARER Sam Bader 8002040481 PHONE: Ext. 489