NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	I L D R S 2 (2)	0 0 - 0 0 0 0 0 - 0 0 (3)	4 1 1 1 1 (4)	(5)
7	8	9 LICENSEE CODE 14	15 LICENSE NUMBER 25	26 LICENSE TYPE 30	57 CAT 58

CON'T

0	1	REPORT SOURCE L (6)	0 5 0 0 0 2 3 7 (7)	1 2 2 9 7 9 (8)	0 1 2 3 8 0 (9)
7	8	60	61 DOCKET NUMBER 68	69 EVENT DATE 74	75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During steady state operation, while conducting a routine plant inspection, the in-

0 3 tegrity of a fire stop in the vicinity of Bus 28-2 was found to be inadequate. As per

0 4 T.S. 3.12.F.2, a fire watch was established in affected area. There was no effect

0 5 upon public health or safety. No previous event of this nature has occurred at Dresden

0 6

0 7

0 8

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	A B (11)	A (12)	E (13)	X X X X X X (14)	X (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	7 9	—	0 6 8	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
B (18)	Z (19)	Z (20)	Z (21)	0 0 0 0 0	N (23)	N (24)	Z (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Event caused by inadequate supervision. After cables were pulled thru penetration,

1 1 temporary fire stop was not installed in accordance with procedure DFPP 4175-1. Upon

1 2 discovery, fire watch posted and temporary fire stop installed. Appropriate personnel

1 3 admonished as to importance of following requirements for fire stops in fire

1 4 protection program.

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	E (28)	0 9 4 (29)	N/A	B (31)	Routine Inspection

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	N/A	N/A

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	(38)	N/A

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	N/A

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	N (44)	N/A	

800204048l

NAME OF PREPARER Sam Bader PHONE: Ext. 489