

NUCLEAR ENERGY BUSINESS GROUP • GENERAL ELECTRIC COMPANY
SAN JOSE, CALIFORNIA 95125

GENERAL  ELECTRIC

APPLICABLE TO:
PUBLICATION NO. NEDO-24146A
T. I. E. NO. 79NED273
TITLE LOCA ANALYSIS REPORT FOR
DRESDEN UNITS 2,3 AND QUAD
CITIES 1,2 NUCLEAR POWER STATIONS
ISSUE DATE April 1979

**ERRATA And ADDENDA
SHEET**

NO. 2
DATE December 1979
*NOTE: Correct all copies of the applicable
publication as specified below.*

ITEM	REFERENCES (SECTION, PAGE PARAGRAPH, LINE)	INSTRUCTIONS (CORRECTIONS AND ADDITIONS)
01	Page 4-9	Replace with new page 4-9.

8009270 372

Table 4E
MAPLHGR VERSUS AVERAGE PLANAR EXPOSURE

PLANT: Dresden 2,3/Quad Cities 1,2

FUEL TYPE: 8D250

<u>Average Planar Exposure (MWd/t)</u>	<u>MAPLHGR (kW/ft)</u>	<u>PCT (°F)</u>	<u>Oxidation Fraction</u>
200	11.2	2106	0.024
1,000	11.3	2109	0.024
5,000	11.9	2169	0.029
10,000	12.1	2179	0.029
15,000	12.2	2198	0.031
20,000	12.0	2199	0.031
25,000	11.5	2148	0.027
30,000	10.6	2020	0.017
35,000	9.6	1888	0.011
40,000	9.0	1808	0.008

Table 4F
MAPLHGR VERSUS AVERAGE PLANAR EXPOSURE

PLANT: Dresden 2,3/Quad Cities 1,2

FUEL TYPE: 8D262

<u>Average Planar Exposure (MWd/t)</u>	<u>MAPLHGR (kW/ft)</u>	<u>PCT (°F)</u>	<u>Oxidation Fraction</u>
200	11.1	2104	0.024
1,000	11.3	2107	0.024
5,000	11.9	2166	0.029
10,000	12.1	2175	0.029
15,000	12.2	2199	0.031
20,000	12.0	2199	0.032
25,000	11.6	2137	0.028
30,000	10.7	2042	0.019
35,000	9.8	1915	0.012
40,000	9.2	1831	0.009