

8011110
029

B. Records and/or logs relative to the following items shall be recorded in a manner convenient for review and shall be retained for the life of the plant.

1. Substitution or replacement of principal items of equipment pertaining to nuclear safety.
2. Changes made to the plant as it is described in the Safety Analysis Report.
3. Records of new and spent fuel inventory and assembly histories.
4. (Deleted)
5. Updated, corrected, and as-built drawings of the plant.
6. Records of plant radiation and contamination surveys.
7. Records of off-site environmental monitoring surveys.
8. Records of radiation exposure for all plant personnel, including all contractors and visitors to the plant in accordance with 10 CFR 20.
9. Records of radioactivity in liquid and gaseous wastes released to the environment.

10. Records of transient or operational cycling for those components that have been designed to operate safely for a limited number of transient or operational cycles.
11. Records of individual staff members indicating qualifications, experience, training and retraining.
12. Inservice inspections of the reactor coolant system.
13. Minutes of meetings and results of reviews performed by the off-site and on-site review functions.
14. Records for Environmental Qualification which are covered under the provisions of paragraph 6.7.

6.7 ENVIRONMENTAL QUALIFICATION

- A. By no later than June 30, 1982 all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or, NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment", December 1979. Copies of these documents are attached to Order for Modification of License DPR-25 dated October 24, 1980.
- B. By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.