

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 I L D R S 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
0 1 REPORT SOURCE L 0 5 0 0 0 2 3 7 1 0 1 6 8 0 1 1 1 4 8 0 9
7 8 9 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 During Unit normal operation, reactor building vent and refueling floor rad monitor
0 3 surveillance (DCP 2700-12) was performed. Refueling floor ARM Ch 'A' tripped at 109
0 4 mR. This exceeded the 100 mR limit as listed by Tech. Spec. 3.2.E.3. The ARM set
0 5 point was adjusted. There was no hazard to public health since the redundant monitor
0 6 was operable. A similar event occurred on Unit 3 and was reported by R.O. 80-12/03L-0
0 7
0 8

0 9 SYSTEM CODE M C 11 CAUSE CODE B 12 CAUSE SUBCODE C 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE S 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 14 15 16

17 LER/RO REPORT NUMBER 8 0 21 22 SEQUENTIAL REPORT NO. 0 4 1 24 26 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 31 REVISION NO. 0 32

ACTION TAKEN E 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER G 0 8 0 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 The cause of this event was instrument drift. The set point was adjusted properly for
1 1 a refueling floor ARM to 95 mR/hr + 0/-5. No further corrective action is deemed
1 2 necessary.
1 3
1 4

1 5 FACILITY STATUS E 28 % POWER 0 5 1 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Routine Surveillance 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 6 RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

2 0 PUBLICITY ISSUED N 44 DESCRIPTION NA 45
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

8011180607

NRC USE ONLY