



Commonwealth Edison
 Dresden Nuclear Power Station
 R.R. #1
 Morris, Illinois 60450
 Telephone 815/942-2920

DSB

December 30, 1980

DJS LTR #80-342-

James G. Keppler, Regional Director
 Directorate of Regulatory Operations - Region III
 U. S. Nuclear Regulatory Commission
 799 Roosevelt Road
 Glen Ellyn, IL 60137

U.S. NRC
 DISTRIBUTION SERVICES
 BRANCH

1981 JAN 5 PM 12 51

DISTRIBUTION
 SERVICES UNIT

Reportable Occurrence Report #80-45/03L-0, Docket #050-237 is being submitted to your office in accordance with Dresden Nuclear Power Station Technical Specification 6.6.B.2.(a), reactor protection system or engineered safety feature instrument settings which are found to be less conservative than those established by the technical specifications but which do not prevent the fulfillment of the functional requirements of affected systems.

DJ Scott

D. J. Scott
 Station Superintendent
 Dresden Nuclear Power Station

DJS:lg

Enclosure

cc: Director of Inspection & Enforcement
 Director of Management Information & Program Control
 U.S. NRC, Document Mgt. Branch
 File/NRC

8101060 598

5 JAN 02 1981

ADD 5 11