



Commonwealth Edison  
1400 Opus Place  
Downers Grove, Illinois 60515

November 22, 1991

Dr. Thomas E. Murley, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Attn: Document Control Desk

Subject: Dresden Nuclear Power Station Units 2 and 3  
Inservice Testing Program (Revision 4) for  
Pumps and Valves  
NRC Docket Nos. 50-237 and 50-249

- References: (a) M. Richter (CECo) letter to T. Murley  
(NRC), dated July 17, 1991.
- (b) Teleconference between CECo (P. Piet, et al.)  
and NRC (B. Siegel, et al.), dated November 20, 1991.

Dear Dr. Murley,

Reference (a) transmitted Revision 4 of Commonwealth Edison's (CECo) Inservice Testing (IST) Program for pumps and valves at Dresden Station. The Reference (b) teleconference was held between representatives of CECo and your staff to clarify the testing requirements for Relief Request No. VR-9. During this teleconference, Dresden Station personnel stated that the method of monitoring the test performed for VR-9 will be to physically feel the air venting out of the valves while verifying that the scram air header pressure drops from 75 psig down to 10 psig within 15 seconds. The purpose of this letter is to document CECo's clarification of the test monitoring method for Relief Request No. VR-9.

If there are any questions or comments concerning this matter, please contact this office.

Sincerely,

Peter L. Piet  
Nuclear Licensing Administrator

cc: A.B. Davis - Regional Administrator, Region III  
B.L. Siegel - NRR Project Manager  
W.G. Rogers - Senior Resident Inspector, Dresden

A04?  
1/0

148

ZNLD/1342/1

9112030152 911122  
FDR ADOCK 05000237  
F FDR