

December 4, 1991

Docket Nos. 50-237
and 50-249

Mr. Thomas J. Kovach
Nuclear Licensing Manager
Commonwealth Edison Company - Suite 300
OPUS West III
1400 OPUS Drive
Downers Grove, Illinois 60515

Dear Mr. Kovach:

SUBJECT: OPERABILITY DETERMINATION AND COMMITMENTS ASSOCIATED
WITH DRESDEN STATION 250V DC BATTERY SYSTEM (TAC M81917)

Your letter of November 15, 1991, presented the most recent 250V DC battery load profile, an operability determination, and commitments associated with upgrading the 250V DC battery system. The staff has reviewed the information contained in this letter and has no objection to your proceeding as described. Implementation of all the commitments identified in Attachment B to the November 15, 1991, letter should result in a significant increase in the reliability and reserve capacity of the 250V DC battery systems at Dresden Station. It is requested that you provide written notification of any scheduler changes associated with these commitments and when all the modifications have been fully implemented.

Sincerely,

Original Signed By:

Byron L. Siegel, Project Manager
Project Directorate III-2
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION

Docket File
Local PDR
J. Zwolinski
C. Moore
OGC 15-B-18
F. Rosa 7-E-4
PDIII-2 r/f
B. Clayton RIII

NRC PDR
B. Boger
R. Barrett
B. Siegel
E. Jordan MNBB-3701
ACRS (10) P-315
Dresden Plant File

NRC FILE CENTER COPY

MAY

*See previous concurrence

OFC	:LA:PDIII-2	:PM:PDIII-2	:SELB*	:RYY	:D:PDIII-2
NAME	:CMoore	:BSiegel:sw	:FRosa:RL for:		for:RBarrett
DATE	: / / 91	: / / 91	:12/03/91	: / / 91	:12/4/91

OFFICIAL RECORD COPY
Document Name: KOVACH M81917

9112120273 911204
PDR ADOCK 05000237
P PDR

Spoke to Burgess 12/4/91 re has no problem with letter BUT didn't think it was necessary for Region to call.

QFOI 1/0

December 4, 1991

Docket Nos. 50-237
and 50-249

Mr. Thomas J. Kovach
Nuclear Licensing Manager
Commonwealth Edison Company - Suite 300
OPUS West III
1400 OPUS Drive
Downers Grove, Illinois 60515

Dear Mr. Kovach:

SUBJECT: OPERABILITY DETERMINATION AND COMMITMENTS ASSOCIATED
WITH DRESDEN STATION 250V DC BATTERY SYSTEM (TAC M81917)

Your letter of November 15, 1991, presented the most recent 250V DC battery load profile, an operability determination, and commitments associated with upgrading the 250V DC battery system. The staff has reviewed the information contained in this letter and has no objection to your proceeding as described. Implementation of all the commitments identified in Attachment B to the November 15, 1991, letter should result in a significant increase in the reliability and reserve capacity of the 250V DC battery systems at Dresden Station. It is requested that you provide written notification of any schedular changes associated with these commitments and when all the modifications have been fully implemented.

Sincerely,

Original Signed By:

Byron L. Siegel, Project Manager
Project Directorate III-2
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION

Docket File

Local PDR

J. Zwolinski

C. Moore

OGC 15-B-18

F. Rosa 7-E-4

PDIII-2 r/f

B. Clayton RIII

HRC PDR

B. Boger

R. Barrett

B. Siegel

E. Jordan MNBB-3701

ACRS (10) P-315

Dresden Plant File

*See previous concurrence

OFC	:LA:PDIII-2	:PM:PDIII-2	:SELB*	:RINI	:D:PDIII-2
NAME	:CMoore	:BSiegel:sw	:FRosa:RL	for:	:RBarrett
DATE	: / /91	: / /91	:12/03/91	: / /91	:12/4 /91

OFFICIAL RECORD COPY

Document Name: KOVACH M81917

Spoke to Burgess 12/4/91 re has no problem with letter BUT didn't think it was necessary for Reg to allow.

Mr. Thomas J. Kovach
Commonwealth Edison Company

Dresden Nuclear Power Station
Unit Nos. 2 and 3

cc:

Michael I. Miller, Esq.
Sidley and Austin
One First National Plaza
Chicago, Illinois 60690

Mr. J. Eenigenburg
Plant Superintendent
Dresden Nuclear Power Station
Rural Route #1
Morris, Illinois 60450

U. S. Nuclear Regulatory Commission
Resident Inspectors Office
Dresden Station
Rural Route #1
Morris, Illinois 60450

Chairman
Board of Supervisors of
Grundy County
Grundy County Courthouse
Morris, Illinois 60450

Regional Administrator
Nuclear Regulatory Commission, Region III
799 Roosevelt Road, Bldg. #4
Glen Ellyn, Illinois 60137

Illinois Department of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704

Robert Neumann
Office of Public Counsel
State of Illinois Center
100 W. Randolph
Suite 11-300
Chicago, Illinois 60601