

NOTICE OF DEVIATION

Commonwealth Edison Company
Dresden Power Station
Units 2 and 3

Docket Nos.: 50-237; 50-249
License Nos.: DPR-19; DPR-25


During an NRC inspection conducted December 2 through 6, 1991, a deviation of your Final Safety Analysis Report (FSAR) was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Action," 10 CFR Part 2, Appendix C (1991), the deviation is listed below:

FSAR Section 8.2.2.2 states, in part, that all protective circuit breakers are sized according to standard electrical industry practice where maximum current interrupting capabilities of circuit breakers exceed the available line-to-line or three (3) phase short circuit current taking into account the impedance of the generator, transformer and other electrical system components.

Contrary to the above, as of December 6, 1991, breakers in the 4kV system were sized such that a fault current condition could exceed their maximum current interrupting capability by up to 14 percent.

Please provide to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region III, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, in writing within 30 days of the date of this Notice, the reason for the deviation, the corrective steps which have been taken and the results achieved, the corrective steps which will be taken to avoid further deviations, and the date when your corrective action will be completed. Where good cause is shown, consideration will be given to extending the response time.

Dated at Glen Ellyn, Illinois
this 20th day of Dec., 1991



Mark A. Ring, Chief
Engineering Branch

7201210028 211220
FDR ADDCK 05000237
FDR