



**KHNP**

**KOREA HYDRO & NUCLEAR POWER CO., LTD**

70-1312-gil, Yuseong-daero, Yuseong-gu, Daejeon, 305-343, KOREA

Tel: +82-42-870-5400 / Fax: +82-42-870-5449

<http://www.khnp.co.kr>

June 23, 2017  
Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attention: Mr. William Ward  
Division of New Reactor Licensing

Docket No. 52-046  
MKD/NW-17-0151L

**Subject: Revised Response to RAI 317-8271 for Question 14.03.05-30**

**References: 1) NRC Request for Additional Information 317-8271, dated November 17, 2015**  
**2) KHNP Letter MKD/NW-16-0585L, Response to RAI 317-8271 for Questions 14.03.05-24, 25, and 30, dated June 29, 2016**

KHNP is hereby submitting a revised response to RAI 317-8271, dated November 17, 2015. The revised response addresses Question 14.03.05-30 to clarify that the Steam Generator wide range level indicator is the credited Type A variable for initiating operator actions. The enclosure provides the revised response to RAI 317-8271 for Question 14.03.05-30 (Non-Proprietary).

If additional information or clarification is required, please contact Daegeun Ahn, Director of KHNP Washington DC Center at [ahn.daegeun@khnp.co.kr](mailto:ahn.daegeun@khnp.co.kr) or 703-388-0592.

Sincerely,

Han-gon Kim  
Project Manager  
Advanced Reactors Development Laboratory  
Korea Hydro & Nuclear Power Co., Ltd.

Enclosure: Revised Response to RAI 317-8271 for Question 14.03.05-30 (Non-Proprietary)

**Enclosure**

Revised Response to RAI 317-8271 for Question 14.03.05-30

(Non-Proprietary)

June 23, 2017