

Vogle PEmails

From: Hoellman, Jordan
Sent: Monday, June 26, 2017 4:07 PM
To: Stacy, Kara M.; THOMPSON, RYDER CLARK
Cc: Haggerty, Neil
Subject: ICN and UIN Comment Status Sheet for 6/29 Public Meeting
Attachments: VOGTLE AND SUMMER ICN and UIN ISSUES June 29 mtg.docx

Hi Kara and Ryder –

Please see the attached ICN and UIN Comment Status Sheet for discussion at the Thursday, June 29, 2017, public meeting.

Let me know if you have any questions.

Thank you,
Jordan

Jordan Hoellman
Project Manager
NRO / DNRL / LB4
U.S. Nuclear Regulatory Commission
office: TWFN 6-F33
phone: (301) 415-5481
email: Jordan.Hoellman2@nrc.gov

Hearing Identifier: Vogtle_COL_Docs_Public
Email Number: 117

Mail Envelope Properties (83ddb87a5729487bb60b4825f5cc2944)

Subject: ICN and UIN Comment Status Sheet for 6/29 Public Meeting
Sent Date: 6/26/2017 4:07:18 PM
Received Date: 6/26/2017 4:07:19 PM
From: Hoellman, Jordan

Created By: Jordan.Hoellman2@nrc.gov

Recipients:

"Haggerty, Neil" <X2NHAGGE@SOUTHERNCO.COM>

Tracking Status: None

"Stacy, Kara M." <KMSTACY@southernco.com>

Tracking Status: None

"THOMPSON, RYDER CLARK" <RYDER.THOMPSON@scana.com>

Tracking Status: None

Post Office: HQPWMSMRS01.nrc.gov

Files	Size	Date & Time	
MESSAGE	456	6/26/2017 4:07:19 PM	
VOGTLE AND SUMMER ICN and UIN ISSUES June 29 mtg.docx			20177

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received:

**VOGTLE AND SUMMER
ICN / UIN
ISSUES TRACKING SHEET**

Date	No.	ICN OR UIN	TOPIC	ITAAC INDEX NUMBERS RECEIVED	ISSUE
6/29	1	ICN	RCP electrical Power for 3 seconds following a Turbine Trip	Vogtle 3 676	<ol style="list-style-type: none"> 1. The second paragraph of the IDB does not reflect the condition when the loads are being powered by the RAT. For completeness you may wish to point out the RATs are powered from the Grid/offsite power and not directly from the output of the main generator as the UATs are. 2. Third paragraph second sentence please clarify this statement. Are all loads from Vogtle Units 1, 2, 3, and 4 being modeled on the UAT and RAT or just the Vogtle 3 loads? Also should “and “be “or” in the phrase “modeled on the UAT or RAT”? 3. For completeness the fourth paragraph first sentence should specify the maximum voltage drop “from the pre-trip steady state voltage” ---.

Date	No.	ICN OR UIN	TOPIC	ITAAC INDEX NUMBERS RECEIVED	ISSUE
6/29	2	ICN	RV head pre-service inspection	Vogtle 3 Vogtle 4 89	<p>Please explain why there is such a significant change between what was put forth in the earlier versions of the UIN and what is now specified in the ICN. The previously submitted UINs’ IDB included visual inspections of the entire head plus ultrasonic and eddy current examinations of the ID surface of each UNS N06690 penetration nozzle, as well as eddy current and liquid penetrant examination of the surface of the head penetration nozzle partial penetration welds. These inspections/examinations appeared to be consistent with the Code Case, Tier 2 section 5.3.4.7 and 50.55(a)(g)(6)(ii)(D). The preservice examinations required in Table 1 of Code Case N-729-1 approved March 28, 2006 include B.4.30 and B.4.40. We recognize that B4.10 was an improper reference. The scope of the ITAAC also affects the applicable AC from the code case i.e. 3142.1</p>

Date	No.	ICN OR UIN	TOPIC	ITAAC INDEX NUMBERS RECEIVED	ISSUE
6/29	3	DRAFT UIN	Testing of RCP breaker trip function	Vogtle 3 64	The 2 nd paragraph 1 st sentence can be interpreted in two ways, 1) the signal was simulated at the detectors themselves by using a test rig to increase the pressure the detector senses or 2) by inserting a dummy signal at the PMS cabinet, please clarify how the containment pressure signal was simulated.

Date	No.	ICN OR UIN	TOPIC	ITAAC INDEX NUMBERS RECEIVED	ISSUE
6/29	4	DRAFT UIN	WGS FA	Vogtle 3 UIN 449	ITAAC Completion Description 2 nd paragraph change “approved drawings” to “approved detailed construction drawings” NEI 08-01 R5 corrected specifies “detailed construction drawings”