

**Westinghouse Comments and Proprietary Markings Regarding Draft NRC
Safety Evaluation for WCAP-16182-P/WCAP-16182-NP, Revision 3,
“Westinghouse BWR Control Rod CR 99 Licensing Report – Update to
Mechanical Design Limits” (Non-Proprietary)**

June 2017

Westinghouse Electric Company
1000 Westinghouse Drive
Cranberry Township, PA 16066

© 2017 Westinghouse Electric Company LLC
All Rights Reserved

OFFICIAL USE ONLY — PROPRIETARY INFORMATION**U. S. NUCLEAR REGULATORY COMMISSION****OFFICE OF NUCLEAR REACTOR REGULATION****DRAFT SAFETY EVALUATION FOR TOPICAL REPORT****WCAP-16182-P/NP, REVISION 3. "WESTINGHOUSE BWR CONTROL ROD CR 99****LICENSING REPORT - UPDATE TO MECHANICAL DESIGN LIMITS"****WESTINGHOUSE ELECTRIC COMPANY****PROJECT 700****1.0 INTRODUCTION**

By letter dated November 10, 2009, Westinghouse Electric Company (Westinghouse) submitted topical report (TR), WCAP- 16182-P-A/WCAP-16182-NP-A, Revision 1, "Westinghouse BWR Control Rod CR 99 Licensing Report - Update to Mechanical Design Limits," dated October 2009 (References 1 and 14). This revision provided updated design requirements for the Westinghouse Generation 3 (Gen 3) control rod blades (CRBs) that increase their service life to the Revision 0 of the TR that was approved by the U.S. Nuclear Regulatory Commission (NRC) (Ref. 2). As a result of the NRC staff requests for additional information (RAIs) and audits Westinghouse submitted Revision 2 of WCAP-16182-P with further enhancement of the design requirements and additions to the analysis options in the methodology by letter dated November 3, 2015, (Reference 3). As a result of the NRC staff RAIs and audit of Revision 1 and Revision 2 of the WCAP-16812-P TR in May 2016, Westinghouse submitted Revision 3 of WCAP-16182-P (Reference 4). Supplemental information was submitted by Westinghouse in References 5, 6, and 7 as responses to the NRC staff RAIs.

This TR presents a set of design requirements for the Westinghouse boiling water reactor (BWR) control rods based on which a set a set of measurable criteria is established. These requirements and criteria form a set of design bases for Westinghouse control rods for use in BWRs. The TR also evaluates the CR 99 design against the measurable criteria to ensure that the design meets the design bases for Westinghouse control rods for BWRs.

Pacific Northwest National Laboratory (PNNL) was a consultant to the NRC during this review. As a result of the reviews of the TR by NRC staff and PNNL consultants, RAI questions were sent to Westinghouse. Westinghouse responded to the RAI questions in References 5, 6, and 7. PNNL submitted a technical evaluation report to the NRC on the results of its review (Reference 8).

Enclosure

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

~~OFFICIAL USE ONLY PROPRIETARY INFORMATION~~

- 2 -

1 The main technical issue of this review was Westinghouse's need to increase the stress limits
2 above the stress limits established in the approved Revision 0 in order to accommodate the
3 higher design loads associated with a higher mechanical end of life (MEOL). Westinghouse
4 could not use the Revision 0 design bases because the Revision 1 stresses were higher than
5 the Revision 0 design basis stress limits. Westinghouse needed to justify the stresses that they
6 wanted under Revision 1 loading conditions. The NRC allows applicants to define novel stress
7 limits within their design bases, but adequate justification for those limits is required. This issue
8 was resolved by Westinghouse making significant changes to its analysis methodology and to
9 its design bases. Westinghouse moved to sophisticated nonlinear finite element analysis
10 methods that are compliant with American Society of Mechanical Engineers *Boiler and Pressure*
11 *Vessel Code* (ASME BPVC) (Reference 9) rules for plastic analysis. Article NB-3000 of ASME
12 BPVC, Section III, Division 1, Subsection NB covers the rules for designing Class 1
13 components, and this draft Safety Evaluation (SE) refers to that article as NB-3000.

14
15 Section 2.0 of the SE describes regulatory evaluation of the TR in terms of the applicable
16 regulations and review criteria. The applicable regulations are appropriate General Design
17 Criteria (GDC) of Appendix A to Title 10 of the *Code of Federal Regulations* (10 CFR).
18 Regulatory guidance for the review of above is provided in NUREG-0800, "Standard Review
19 Plan for the Review of Safety Analysis Reports for Nuclear Power Plants" (SRP), Section 4.2,
20 "Fuel System Design" (Ref. 10).

21
22 Section 3.0 of this SE describes the history of this review, which included a number of audits,
23 RAI questions, and significant revisions of the original submittal to address the technical issues
24 that were raised during the review. Key issues and developments are noted as they occurred
25 during this review, to help explain the progression from Revision 1, to Revision 2, and to
26 Revision 3.

27
28 Section 4.0 of this SE describes the technical review in detail. The two main issues in this
29 review were the design bases, discussed in Section 4.2, and the design evaluation, discussed in
30 Section 4.3. A number of specific technical issues were raised throughout the course of this
31 review, and they are listed and discussed in Section 4.4.

32
33 Section 5.0 of the SE lists surveillance plans and Section 6.0 provides the conclusions.

34

35 **2.0 REGULATORY EVALUATION**

36

37 Regulatory framework and guidance for the review of fuel system designs and reactivity control
38 systems are GDC 10, GDC 26, GDC 27, and GDC 35 within Appendix A to 10 CFR Part 50.
39 GDC 10 establishes specified acceptable fuel design limits (SAFDLs) that should not be
40 exceeded during any condition of normal operation, including the effects of anticipated
41 operational occurrences (AOO). GDC 26 requires two independent reactivity control systems of
42 different design principles including control rods capable of reliably controlling reactivity changes
43 to assure that under conditions of normal operations, including AOOs SAFDLs are not
44 exceeded. GDC 27 and GDC 35 establish requirements for combined reactivity control system
45 capability and emergency core cooling capability under postulated accident conditions.

~~OFFICIAL USE ONLY PROPRIETARY INFORMATION~~

~~OFFICIAL USE ONLY PROPRIETARY INFORMATION~~

- 3 -

1 Regulatory guidance for the review of fuel system design and adherence to the GDC listed
2 above is provided in NUREG-0800, "Standard Review Plan for the Review of Safety Analysis
3 Reports for Nuclear Power Plants" (SRP), Section 4.2, "Fuel System Design" (Ref. 10).

4 In accordance with SRP Section 4.2, the objectives of fuel system safety review are to provide
5 assurance that:

- 6
- 7 • The fuel system is not damaged as a result of normal operation and AOOs,
- 8 • Fuel system damage is never so severe as to prevent control rod insertion when it is
9 required,
- 10 • The number of fuel rod failures is not underestimated for postulated accidents, and
- 11 • Coolability is always maintained.
- 12

13 Westinghouse has established the following design requirements based on its mechanical,
14 operational, physics, and material acceptance criteria:

- 15
- 16 • Based on the applicable material and operational acceptance criteria, the control rod will
17 be compatible with control rod drive (CRD) system, coupling device, fuel, fuel channels,
18 and rod handling equipment.
- 19
- 20 • Mechanical, physics and operational criteria will satisfy the design requirement such that
21 rod worth and transient operation (e.g., SCRAM and free fall velocity) are consistent with
22 the plant safety analyses.
- 23 • Based on material, mechanical and operational criteria, the control rod is expected to
24 have mechanical stability and materials choices such that mechanical function is
25 maintained throughout the life of the control rod.
- 26 • Based on the physics criteria, the control rod is designed such that currently used tools
27 can monitor core power distribution and burn-up
- 28 • Material criteria satisfy the design requirement that total life cycle dose due to its use
29 (activation product dose, direct dose, and disposal dose) is minimized.
- 30 • The design and manufacture of the control rod fulfill applicable codes and standards,
31 including applicable parts of the ASME BPVC.
- 32

33 **3.0 BACKGROUND HISTORY AND ISSUE RESOLUTION**

34

35 The initial TR under review was WCAP-16182-P, Revision 1, dated October 2009 (References 1
36 and 14). The two key issues that came out of the initial review of the TR were a lack of
37 information about the structural analyses and the use of novel stress-based design criteria. The
38 lack of information about structural analysis is a common issue. It has become typical that TRs
39 like this one do not contain sufficient information to determine if finite element analyses have
40 been conducted in a reasonable manner. It is often easiest to schedule audits of internal
41 calculation packages and interactive reviews of finite element analyses than to request
42 applicants or licensees to provide sufficient documentation through RAI questions.

~~OFFICIAL USE ONLY PROPRIETARY INFORMATION~~

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

- 4 -

1 Westinghouse's use of novel design criteria is more unusual, and it was ultimately the one
2 technical issue that proved to be the most challenging to resolve.

3
4 The first round of RAI questions asked Westinghouse for more details of the finite element
5 analyses (Questions 8-10) and to justify its new novel von Mises based design criteria
6 (Question 15). Westinghouse provided a response to the first round of RAI questions in
7 LTR-NRC-11-15, Revision 1, dated June 6, 2011 (Reference 5). The RAI responses provided
8 some useful information about the finite element models (FEMs), but Westinghouse indicated
9 that it preferred to host an audit rather than provide input and output files for review. The key
10 issues surrounding the finite element analyses were still not clear at this point because there
11 was not enough information available to the review team. On the issue of the novel von Mises
12 design criteria, the RAI response referenced the German Nuclear Safety Standards
13 Commission code (KTA 3103 (Reference 11)), but the answer did not provide a sufficient
14 justification for mixing the ASME BPVC with the German KTA code. There was also an issue
15 that the general design requirements of the Revision 1 TR stated that the CR-99 met ASME
16 BPVC design rules. This was seen as a logical contradiction within the TR that needed to be
17 remedied – one section of the TR declared that the design criteria was ASME BPVC, but in a
18 different section the TR defined stress criteria that were more permissive than ASME BPVC.

19
20 A second round of RAI questions was asked as a follow up to some of the first round of RAI
21 questions. The audit to review finite element analyses had not been performed yet, so the
22 reviewer's understanding of the FEA was limited, but it appeared that Westinghouse did not
23 perform any structural analyses of the control blade under seismic loading conditions.
24 Westinghouse responded to the follow-up RAI questions in LTR-NRC-12-48 (Reference 6) with
25 a description of an elastic-plastic fatigue analysis that was associated with operational basis
26 earthquake (OBE) and safe shutdown earthquake (SSE) seismic loads. The analysis was not
27 done according to ASME BPVC, and it was not clear that the evaluation of seismic loads was
28 sufficient to demonstrate safety.

29
30 The first audit occurred on August 22, 2012, at the Westinghouse Twinbrook Office, Rockville,
31 Maryland. Westinghouse provided access to some finite element analyses of the CR-99 control
32 blade design. However, these analyses were not the correct finite element analyses of record
33 for the TR. Due to some logistics problems, Westinghouse was not able to make the correct
34 model files available for review during this audit. The NRC review team decided to review the
35 available models to best make use of the audit time.

36
37 The analyses that were made available at the first audit seemed to demonstrate that the CR-99
38 would meet ASME BPVC design requirements using standard ASME BPVC stress limit
39 definitions (stress intensity). It was not necessary for the NRC staff to accept the proposed
40 novel design criteria because the CR-99 could be approved based ASME BPVC stress limits.
41 This path to resolution was discussed and agreed upon with Westinghouse, and NRC staff
42 provided a list of information needed to complete the review at the first audit.

43
44 The most important item that the NRC requested was for Westinghouse to provide a formal
45 summary of the correct analyses of record on the docket. Westinghouse was to use both the
46 standard ASME BPVC methodology and Westinghouse's proposed von Mises design basis to

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

- 5 -

1 provide a side-by-side comparison of the two design bases. The expectation was that the
2 CR-99 would pass the ASME BPVC stress limits, so it would not be necessary for NRC to
3 decide if the novel von Mises stress limits were acceptable or not.

4
5 A second important open item topic that came out of the first audit was the need for
6 Westinghouse to explain its intended design basis. Specifically, Westinghouse stated during
7 the audit that failing the pressure boundary of the control blade (through-wall cracking) was
8 permissible under Westinghouse design philosophy. However, this is not consistent with ASME
9 BPVC NB-3000 design rules. NB-3000 provides rules for pressure vessel design, and the rules
10 do not permit any local failure of the pressure boundary under design basis loading. Revision 0
11 of the TR used NB-3000 design rules. The NRC staff understanding of Westinghouse's position
12 was that Westinghouse was proposing a novel set of design criteria that was based on
13 NB-3000, but it also permitted gross plastic deformation of the control blade and local failure of
14 the pressure boundary under certain loading conditions. A more detailed and formal
15 explanation of Westinghouse's position regarding local through-wall failure of the control blade
16 was requested.

17
18 Westinghouse responded to the open items of the August 2012 audit with LTR-NRC-12-67,
19 dated September 2012 (Reference 7). This document addressed 9 open items that were
20 composed at the audit. The response was problematic because the structural analyses of
21 record demonstrated that the CR-99 did not meet the basic ASME BPVC NB-3000 stress limits.
22 The worst case analysis exceeded the ASME BPVC limit by 26 percent, and had a design
23 margin on the proposed von Mises limit of just 1 percent. Westinghouse also provided an
24 additional collapse load analysis that showed that the loading state was close to the collapse
25 load. Westinghouse's response to the open items of the first audit derailed the resolution path
26 that was discussed at the first audit. The formal response made it clear that the stresses in the
27 CR-99 control blade would be much higher under the revised loading limits, much higher than
28 NRC had approved before for the CR-99, and potentially higher than other control blades.

29
30 A second audit was conducted on December 5, 2013, at the Westinghouse Twinbrook Office,
31 Rockville, Maryland. It was originally planned for two days. The goal was to resolve the key
32 technical issues, particularly the proposed higher stress limits. Due to availability of
33 Westinghouse staff, the audit was discontinued at noon on Day 1 and Day 2 was cancelled.
34 This audit did not resolve any of the outstanding issues.

35
36 A third audit occurred on September 30 through October 2, 2014 (Reference 12). One key
37 agreement was that Westinghouse would perform stress analyses fully in accordance with
38 ASME BPVC. The high stresses calculated for the CR-99 exceeded ASME PBVC basic stress
39 limits, but the code has alternate rules that use nonlinear analysis methods that remove some of
40 the conservatism of the basic stress limits. The CR-99 was expected to meet ASME BPVC
41 design rules using the nonlinear methods. This would eliminate the need to use a novel von
42 Mises stress criteria, which was a major sticking point in the review. Westinghouse also agreed
43 that cracking of the control blade was not to be permitted under design basis loading conditions.
44 The rules of ASME BPVC NB-3000 are defined to prevent material failure at the pressure
45 boundary, so demonstrating the control blade meets NB-3000 rules provides an assurance that
46 through-wall failures will not occur as a result of design basis loading.

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

- 6 -

1 As a result of NRC staff RAI questions and audits, Westinghouse issued Revision 2 of
2 WCAP-16182-P in October 2015. This revision largely met the expectations of the NRC review
3 team as Westinghouse followed the resolution path agreed to at the September-October 2014
4 (Reference 12) audit. The structural analyses were performed according to ASME BPVC
5 NB-3000 nonlinear analysis rules, and these new models needed to be reviewed at an audit
6 because the TR did not contain enough information to determine if the analyses were done
7 correctly. One issue that remained open was the seismic analysis of the CR-99, which did not
8 appear to follow the ASME BPVC NB-3000 nonlinear analysis rules.
9

10 A fourth audit occurred on May 17 through 20, 2016, at Westinghouse's Rockville, Maryland
11 offices (Reference 13). The audit plan was written to identify NRC expectations from the
12 previous audit (September 30 through October 2, 2014), and listed questions and discussion
13 topics that were necessary to close out the open items that were not clearly resolved in Revision
14 2 of the TR. The review team reviewed the nonlinear finite element models and found most of
15 them adhered to ASME BPVC NB-3000 rules and methodology with the exception of the
16 seismic analysis. Westinghouse had attempted an alternate analysis methodology, but agreed
17 to redo the analysis to conform entirely to the ASME BPVC methods.
18

19 Westinghouse issued Revision 3 of WCAP-16182-P in June 2016. This revision of the TR
20 completely addressed all remaining open items. The seismic analysis was documented
21 sufficiently and no further audits were needed.
22

23 **4.0 TECHNICAL EVALUATION**

24 4.1 Introduction

25 The objective of WCAP-16182-P, Revision 3, is to define higher loads and higher stress limits
26 for the CR-99 control blade (BWR C, S, and D lattices) in order to define a MEOL that is longer
27 than the one that was approved in Revision 0. Revision 3 incorporates the incremental changes
28 made in Revision 1 and Revision 2. Few changes were made in Revision 3 relative to
29 Revision 0 which was approved by the NRC staff in 2005 (Reference 2). The major technical
30 improvement in the increase in loads and stress limits in Revision 3 relative to Revision 0.
31
32

33 Revision 0 used ASME BPVC NB-3000 basic stress limits as the design basis. Increasing the
34 loads to the level proposed in the later revisions of the TR leads to stresses in the control blade
35 that exceeds ASME BPVC NB-3000 basic stress limits. This prompted Westinghouse to
36 change the design basis in Revision 1 to effectively increase the stress limits above NB-3000.
37 As discussed in Section 2.0, Westinghouse's von Mises stress limit approach in Revision 1
38 proved to be difficult to justify. Westinghouse did not have an experimental basis, such as
39 control rod burst test data, to justify its proposed higher limits. Ultimately, Westinghouse chose
40 to implement plastic stress analysis methods to demonstrate that the CR-99 meets the design
41 rules of NB-3000 in Revision 2 and Revision 3. This provides a credible design basis that does
42 not require further justification, per NRC's SRP Section 4.2 (Reference 10).
43
44

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

- 7 -

1 The technical review covered issues that can be divided into three broad topics: the design
2 bases, the design evaluation, and specific technical issues. These topics are discussed in more
3 detail in the Sections 4.2, 4.3, and 4.4, of this SE, respectively.

4
5 **4.2 Design Bases**
6

7 The design bases that were established in Revision 0 of the TR were ASME BPVC NB-3000
8 basic stress limits. These stress limits are defined on the basis of stress intensity and are
9 calculated using FEMs that assume elastic material behavior. The Section 4.2 of SRP
10 (Reference 10) states that stress limits that are obtained by methods similar to ASME BPVC are
11 acceptable, while other stress limits must be justified. In this case, Revision 0 used ASME
12 BPVC values so no further justification was required, but Revision 1 proposed novel stress limits
13 that used von Mises stress instead of stress intensity. Per the SRP, this change required
14 justification, but the TR did not contain any justification. The novel von Mises stress limits were
15 difficult to justify for a number of reasons. Ultimately, Westinghouse abandoned the von Mises
16 stress limits proposed in Revision 1, and changed to ASME BPVC plastic evaluation limits
17 starting in Revision 2.

18
19 The new design bases in Revision 2 and Revision 3 define load limits, which are specified to be
20 some fraction of the load that would cause the structure to collapse. Nonlinear finite element
21 analysis is used to determine the collapse load. Service Level A loads are restricted to 2/3 of
22 the collapse load. [

23]^{a,c} Service Level D loads are
24 permitted to be 90 percent of the collapse load. These load limits and the finite element
25 analysis methodology used to implement these load limits are generally in agreement with
26 NB-3000 rules. [

27
28]^{a,c} This difference only affects the amount of
29 safety margin that is required of the structure, so is not a significant safety concern. The control
30 blade is not required by NRC to be designed to meet NB-3000 rules, or maintain NB-3000
31 margins. [

32
33
34]^{a,c}
35

36 A fundamental technical issue is that Westinghouse has used the design rules of NB-3000 to
37 demonstrate safety for the CR-99 which is not Class 1 components and consequently result in a
38 very conservative MEOL assessment when compared to other design rules such as the German
39 KTA code. One reason for this is that ASME BPVC uses the Tresca (Maximum Shear Stress)
40 failure criterion rather than the von Mises failure theory, which is more appropriate for ductile
41 materials, like steel. Another source of conservatism is that the NB-3000 basic stress limits are
42 calculated on an elastic basis, and therefore do not account for the redistribution of stress in a
43 structure undergoing plastic deformation. It was reasonable for Westinghouse to look for an
44 avenue for reducing conservatism to increase the MEOL of the CR-99, but defining new Design
45 Bases (without having specific mechanical test data to support a new design basis) was a
46 significant technical challenge.

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

- 8 -

1 As an example of the difficulty in defining new Design Bases, Westinghouse stated during the
2 first audit that control blade cracking under mechanical loading was permissible under design
3 basis loading. This was a radical change from the Revision 0 TR design basis, which ensured
4 that the pressure boundary maintained its integrity under all design-basis loading scenarios.
5 Allowing the pressure boundary to fail under design basis loads, such as during seismic loading,
6 opened up the possibility of completely failing the control blade through crack propagation or
7 ductile failure. New evaluation methods needed to be devised to demonstrate safety in a
8 scenario where significant through-wall cracks were present. During this review process,
9 Westinghouse prepared new, sophisticated nonlinear models to demonstrate that cracks would
10 not propagate under seismic loading. The review staff needed to enlist the help of additional
11 material scientists to assist in the review of the crack propagation calculations. In the end, it
12 was easier for Westinghouse to back away from proposing novel design criteria and pursue
13 options within the ASME BPVC to achieve its MEOL goal.

14
15 This review finds that the new Design Bases defined in Revision 3 of the TR are appropriate for
16 maintaining safety of the CR-99 during its service life. Westinghouse's interpretation of
17 NB-3000 in regards to Service Level B collapse load limits does not strictly adhere to ASME
18 BPVC design limits, but the difference is only in the amount of margin against collapse.
19 Westinghouse design criteria has a slightly lower safety margin at Service Level B, but this is
20 reasonable because control blades are not Class 1 components and do not need to be
21 designed with margins that are equal to NB-3000 rules.

22

23 4.3 Design Evaluation

24

25 The original (Revision 0) design evaluation was performed using linear elastic finite element
26 models. Stresses were linearized and compared to NB-3000 stress intensity limits. All analysis
27 methods were in accordance with ASME BPVC. The design evaluation of Revision 0 was a
28 typical, standard approach.

29

30 The Revision 1 design evaluation used a similar methodology, but changed from stress intensity
31 stress limits to von Mises stress limits. This change is not permissible under ASME BPVC, so
32 the Revision 1 design evaluation was either incorrect or required justification. The early phases
33 of the review process focused on trying to understand Westinghouse's intent, to determine if the
34 finite element analyses of the design evaluation needed to change to be consistent with the TR,
35 or if the TR needed to be changed to be consistent with the design evaluation.

36

37 The Revision 2 design evaluation changed from linear elastic FEMs to nonlinear perfectly-
38 plastic finite element models, using an analysis methodology that is defined in ASME BPVC
39 NB-3000. There was no longer any need to linearize stresses with this analysis methodology;
40 the design criteria became loads instead of stresses. The analysis procedure is implemented
41 by defining a structural finite element model with a bilinear material model. The initial behavior
42 of the material is elastic, and that continues until the yield strength is reached. Then the
43 material behaves in a perfectly-plastic manner, meaning the tangent modulus has zero slope, or
44 zero strain-hardening. A perfectly plastic material model allows a structure to support a load
45 beyond its yield limit, as long as the load can be redistributed. As the load increases this type of
46 structural model reaches a point where it can no longer redistribute the load, and the structure

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

- 9 -

1 subsequently collapses. Using finite element analysis methods, the collapse load for a structure
2 can be determined by increasing the loads until the numerical model can no longer converge to
3 a solution. The last load step that successfully converges is considered the collapse load.
4 NB-3000 load limits are defined as a fraction of the collapse load. For example, Service Level A
5 loading conditions are limited to 2/3 (or 67%) of the collapse load. In practice, finite element
6 models are used to determine the loads that would cause collapse, in order to demonstrate that
7 the design basis loads are at least a certain margin below the collapse limit.

8
9 Westinghouse's Revision 2 models were reviewed during the fourth audit (May 2016) and all
10 models were found to be appropriate, with no errors. Only one design evaluation change was
11 required in Revision 3, which was the seismic loading analysis. The Revision 2 version of the
12 analysis was not performed according to ASME BPVC, and Westinghouse agreed to revise the
13 model to bring it into full compliance.

14
15 A preliminary version of the Revision 3 seismic analysis was reviewed during the fourth audit.
16 Westinghouse was advised about what to document in the TR to avoid having another audit to
17 review the Revision 3 seismic analyses. Westinghouse included sufficient information in the TR
18 that the reviewers could determine that the new seismic analysis was appropriate, and no
19 further review of the FEMs was necessary.

20
21 This review finds that the Revision 3 design evaluation is appropriate for demonstrating that the
22 design bases are met. Westinghouse's design evaluation was performed in accordance with
23 ASME BPVC. The FEMs were reviewed sufficiently to confirm that they are error-free and of
24 appropriate quality.

25 26 4.4 Specific Technical Issues and Resolution

27
28 This review covered many specific technical issues. All of them were adequately addressed
29 through the audit process or as changes to the models of the design evaluation or changes
30 documented in the TR. This section lists the issues and identifies how they were resolved.

31 32 *Design Requirements*

33
34 Section 4.0 (Table 4-1) of the TR defines the design requirements. In Revision 1, it was not
35 clear whether Westinghouse considered it a design requirement to design the CR-99 control
36 blade in accordance with ASME BPVC NB-3000. Revision 3 of the TR clarifies the design
37 requirements by stating "Although the control rod is not classified as a Class 1 component, the
38 structural qualification is based on stress criteria defined in ASME III Subsection NB-3200."

39 40 *Mechanical Analyses*

41
42 The finite element analyses used to demonstrate compliance with the mechanical design criteria
43 were reviewed during the fourth audit, and were found to be performed according to NB-3000
44 rules. At the end of the fourth audit, Westinghouse had a preliminary analysis of the seismic
45 load case, and that model was also reviewed. Westinghouse included enough information
46 about the seismic analysis in Revision 3 that no further review of the mechanical analyses was

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

~~OFFICIAL USE ONLY PROPRIETARY INFORMATION~~

- 10 -

1 necessary. All of the mechanical analyses were found to be adequate, and support the
2 increase in MEOL that Westinghouse is seeking.

3
4 *Maximum Channel Distortion*

5
6 The seismic loading conditions were not documented in Revision 1. The TR was updated
7 starting in Revision 2 to include the maximum channel deflection limit.

8
9 *Residual Stresses Caused by B₄C Swelling*

10
11 Loads caused by B₄C swelling were not included in all analyses in Revision 1, but by Revision 3
12 all possible B₄C swelling loads were included in the design evaluation.

13
14 *Mechanical Stress/Strain Data for Irradiated Material*

15
16 When Westinghouse moved to nonlinear stress analysis methods, they also began to use
17 irradiated material properties. The irradiated material data was reviewed and references to the
18 data were included in Revision 3 of the TR.

19
20 *Cracking and Local Depletion*

21
22 The NRC staff raised the question about Westinghouse's use of average depletion values in its
23 swelling calculations. The concern was that local depletion can cause higher local swelling, and
24 thus higher localized swelling loads, than the average depletion values would predict. [

25
26
27]^{a,c} This design feature is mentioned in the TR, but
28 Westinghouse presented additional, more detailed material at one of the audits to fully address
29 the reviewer's concerns.

30
31 *Surveillance Plan*

32
33 The NRC staff requested a surveillance plan for the CR-99 be instated due to the new, higher
34 load limits. Westinghouse included the final version of the plan in Revision 3 of the TR. The
35 surveillance plan will look for material integrity issues, which includes cracking. One point to
36 note is that the rods will be inspected for material integrity issues at 90% depletion, which could
37 take ten or more years of service. NRC staff reviewed the surveillance plan internally and found
38 it to be acceptable. The surveillance plan documented in Revision 3 fully resolves this issue.
39 The surveillance plan is summarized in Section 5.0.

40
41 **5.0 SURVEILLANCE PLAN**

42
43 Westinghouse has been performing inspection on third generation of CR 99 control rods that
44 were operating in two Swedish BWRs to almost 80% of their nuclear life and found no cracks.
45 Westinghouse is committed to continue to inspect the leading rods at high exposures close to

~~OFFICIAL USE ONLY PROPRIETARY INFORMATION~~

~~OFFICIAL USE ONLY PROPRIETARY INFORMATION~~

- 11 -

1 nuclear end-of-life (NEOL). The following inspection plan has been developed for D, C, and S
2 lattice BWRs (Reference 4):
3

- 4 1. A minimum of two third (3rd) generation of CR 99 control rods shall be followed at
5 operation in high duty locations in a D, C, and S-lattice US or international BWR.
6
- 7 2. Additional third (3rd) generation CR 99 control rods are operated in other US BWRs to a
8 lower depletion than the two lead-depletion 3rd generation CR 99 control rods at the
9 designated BWRs. Should other control rods at a domestic or international BWRs
10 become the highest depletion in the BWR fleet, they shall become the control rods
11 inspected per this surveillance program.
12
- 13 3. The two lead-depletion control rods shall be irradiated, achieving as close to NEOL as
14 practical (target minimum 90% of EOL).
15
- 16 4. For refueling outages in which the depletion of the lead 3rd generation CR 99 control
17 rods are greater than 75% of design life, two highest depletion 3rd generation CR 99
18 control rods shall be visually inspected on all eight (8) on each control rod.
19
- 20 5. For the 3rd generation CR 99 rods inserted in the opposite lattice type as the lead
21 depletion units, the two highest depletion control rods shall be visually inspected during
22 outages where the control rods exceed 90% of design NEOL. These visual inspections
23 shall be covering all eight faces of the control rod. For this surveillance program, the D
24 and S lattice applications are considered equivalent, since the geometry of the absorber
25 holes and absorber pins are identical.
26
- 27 6. If a material integrity issue is observed, Westinghouse shall arrange for additional
28 inspection, if necessary, to determine root cause and recommend a revised lifetime limit
29 to the NRC based on the inspections and other applicable information available.
30
- 31 7. Westinghouse shall report the results of the visual inspections of the 3rd generation
32 control rods to the NRC within 12 months of the time when the inspections were
33 performed.
34

Insert "faces"

35 **6.0 CONCLUSIONS**

- 37 1. Revision 3 of the TR (Reference 4) demonstrates that request for increased MEOL for
38 the 3rd generation CR 99 control rods is justified and the staff approves the request.
39
- 40 2. The NRC staff has determined that the new design bases as presented in Revision 3 of
41 WCAP-16182-P are appropriate. The design bases are plastic analyses that follow the
42 rules of NB-3000 (Reference 9). The NRC staff has concluded that the new design
43 bases demonstrate that the control blade will maintain its integrity throughout normal
44 conditions of operation and safe shutdown earthquakes.
45

~~OFFICIAL USE ONLY PROPRIETARY INFORMATION~~

~~OFFICIAL USE ONLY PROPRIETARY INFORMATION~~

- 12 -

- 1 3. Though control blades are not actually Class 1 components, Westinghouse has applied
2 the rules of NB-3000 to the control blade. NB-3000 is potentially more conservative than
3 necessary for a BWR control blade. However, the NRC staff finds this appropriate.
4
5 4. Westinghouse design rules do not permit the control blade to fail its pressure boundary
6 during design basis loading conditions. The NRC staff concludes that design rules do
7 not allow a stress or loading state that would be expected to lead to failure of the
8 pressure boundary.
9
10 5. The design bases deviate slightly from ASME BPVC NB-3000 rules for service level B
11 limit load analysis, as described in TR Section 6.5. [

12
13
14
15
16
17
18
19 NRC staff has determined that this difference is not a safety concern, as both load limits
20 ensure a safety margin against collapse, and therefore finds this acceptable.
21

- 22 6. The new design evaluation finite element models were reviewed and found to be
23 appropriate. No errors were found. The staff finds that the models had appropriate
24 mesh density and were good implementation of modern nonlinear finite element
25 analyses.
26
27 7. The NRC staff finds the surveillance plan listed in Section 5.1 acceptable.
28

7.0 REFERENCES

- 29
30
31 1. WCAP-16182-P, Revision 1, "Westinghouse BWR Control Rod CR 99 Licensing Report,"
32 October 2009 (proprietary).
33 2. WCAP-16182-P-A, Revision 0, "Westinghouse BWR Control Rod CR 99 Licensing Report,"
34 March 2005 (proprietary).
35 3. WCAP-16182-P, Revision 2, "Westinghouse BWR Control Rod CR 99 Licensing Report -
36 Update to Mechanical Design Limits," October 2015 (proprietary).
37 4. WCAP-16182-P, Revision 3, "Westinghouse BWR Control Rod CR 99 Licensing Report -
38 Update to Mechanical Design Limits," August 2016 (proprietary).
39 5. LTR-NRC-11-15 Rev. 1, "Response to the NRC's Request for Additional Information
40 RE: Westinghouse Electric Company Topical Report WCAP-16182-P-A, Revision 1,
41 "Westinghouse BWR Control Rod CR 99 Licensing Report - Update to Mechanical Design
42 Limits" (Proprietary)," June 2011.
43

~~OFFICIAL USE ONLY PROPRIETARY INFORMATION~~

OFFICIAL USE ONLY — PROPRIETARY INFORMATION

- 13 -

- 1 6. LTR-NRC-12-48, "Response to the NRC's Second Round Request for Additional Information
2 RE: Westinghouse Electric Company Topical Report WCAP-16182-P-A, Revision 1,
3 "Westinghouse BWR Control Rod CR 99 Licensing Report - Update to Mechanical Design
4 Limits" (Proprietary)," June 2011.
- 5 7. LTR-NRC-12-67, "Resolution of Open Items from NRC Audit on WCAP-16182-P-A, Revision
6 1, "Westinghouse BWR Control Rod CR 99 Licensing Report – Update to Mechanical Design
7 Limits" (Proprietary)," September 2012
- 8 8. N. A. Klymyshyn, K. J. Geelhood and C. E. Beyer, "Technical Evaluation Report of the
9 Topical Report WCAP-16182-P, Revision 3," Pacific Northwest National Laboratory,
10 January 2017.
- 11 9. ASME Boiler and Pressure Vessel Code, Section III, Division 1, Edition 2002 (ASME III).
- 12 10. NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear
13 Power Plants: LWR Edition," Chapter 4: Reactor, Section 4.2 Fuel System Design,
14 March 2007.
- 15
- 16 11. KTA 3103, "Shutdown Systems for Light Water Reactors," SAFETY STANDARDS of the
17 Nuclear Safety Standards Commission (KTA), March 1984.
- 18
- 19 12. Memorandum from J.L. Dean to A. J. Mendiola (USNRC), Regulatory Audit report –Review
20 of TRs (1) WCAP-16182 Revision 1 Westinghouse BWR Control Rod CR 99 Licensing
21 Report Update to Mechanical Design Limits Revision 1, October 2009 (ME2630) and (2)
22 WCAP-15492-P-A Supplement 1 Revision 0 Material Changes for SVEA-96 Optime2 Fuel
23 Assemblies, September 2010 (ME4700)," USNRC, December 7, 2014 (ADAMS Accession
24 No. ML14325A846).
- 25
- 26 13. Memorandum from J.L. Dean to K. P. Hsueh (US NRC), "Regulatory Audit Report Review
27 Of Topical Reports (1) Westinghouse Commercial Atomic Power -16182 Revision 2
28 Westinghouse Boiling Water Reactor Control Rod 99 Licensing Report Update To
29 Mechanical Design Limits Revision 2, November 2015 (ME2630) And (2) Westinghouse
30 Commercial Atomic Power -17769-P Revision 0 Reference Fuel Design Svea-96 Optima3
31 Fuel Assemblies, January 2014 (MF3367)," USNRC, July 26, 2016. (ADAMS Accession
32 No. ML16201A077)
- 33
- 34 14. Response to NRC Request for Additional Information Re: Westinghouse Electric Company
35 Topical Report (TR) WCAP-1 6182-P-A, Addendum 1, "Westinghouse BWR Control Rod CR
36 99 Licensing Report - Addendum 1, Updated Design Limits," dated November 6, 2008
37 (TAC No. MD7989) and Submittal of WCAP- 16182-P-A/WCAP- 16182-NP-A, Revision 1,
38 "Westinghouse BWR Control Rod CR 99 Licensing Report - Update to Mechanical Design
39 Limits," dated October 2009 (Proprietary/Non-Proprietary) (ADAMS Accession
40 No. ML093240377).

41
42 Principal Contributors: PNNL Staff
43 Mathew Panicker, NRR/DSS/SNPB
44

45 Date: May 17, 2017

OFFICIAL USE ONLY — PROPRIETARY INFORMATION