

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Nuclear Safeguards
Open Session

Docket Number: N/A

Location: Rockville, Maryland

Date: June 7, 2017

Work Order No.: NRC-3113

Pages 1-182

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

644TH MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

OPEN SESSION

+ + + + +

WEDNESDAY

JUNE 7, 2017

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B3, 11545 Rockville Pike, at 8:30 a.m., Dennis C.
Bley, Chairman, presiding.

COMMITTEE MEMBERS:

- DENNIS C. BLEY, Chairman
- MICHAEL L. CORRADINI, Vice Chairman
- PETER RICCARDELLA, Member-at-Large
- RONALD G. BALLINGER, Member
- MARGARET CHU, Member
- WALTER KIRCHNER, Member
- JOSE MARCH-LEUBA, Member

1 DANA A. POWERS, Member
2 HAROLD B. RAY, Member
3 JOY REMPE, Member
4 GORDON R. SKILLMAN, Member
5 JOHN W. STETKAR, Member
6 MATTHEW W. SUNSERI, Member

7
8 DESIGNATED FEDERAL OFFICIAL:

9 CHRISTOPHER BROWN

10

11 ALSO PRESENT:

12 TONY AHN, KHNP
13 JIM ANDRACHEK, WEC/PWROG
14 DENNIS ANDRURROT, NRO
15 SURINDER ARORA, NRO
16 CLINTON ASHLEY, NRO
17 AYO AYEGBUSI, NRO
18 WILLIAM BAKER, TVA
19 DANIEL BARSS, NSIR
20 BEN BEASLEY, NRR
21 BRIAN BENNEY, NRR
22 STEVE BONO, TVA
23 MICHAEL BREACH, NRR
24 KATHRYN BROCK, NRR
25 MARK BLUMBERG, NRR

1 JOHN BUDZYNSKI, NRO
2 DENNY CAMPBELL, TVA
3 PAUL CLIFFORD, NRR
4 MATTHEW DEGONISH, WEC
5 JOE DEMARSHALL, NRO
6 ANTONIO DIAS, NRO
7 MICHAEL DICK, TVA
8 THINH DINH, NRO
9 STEPHEN DINSMORE, NRR
10 PETE DONAHUE, TVA
11 GERALD (GERRY) DOYLE, TVA
12 RAY DREMEL, Enercon
13 ASHLEY FERGUSON, NRO
14 CJ FONG, NRR
15 VIJAY GOEL, NRR
16 ANNE-MARIE GRADY, NRO
17 DAN GREEN, TVA
18 SYED I. HAIDER, NRO
19 STEPHEN HAMBRIC, Penn State University*
20 CHARLES HARBUCK, NRR
21 MICHELLE HART, NRO
22 RUSS HASKELL, NRR
23 ALFRED HATHAWAY, NRR
24 TREY HATHAWAY, RES
25 MICHELLE HAYES, NRO

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 RAUL HERNANDEZ, NRO
2 VICTORIA HUCKABAY, NRR
3 DANIEL (LANG) HUGHES, TVA
4 SCOTT HUNNEWELL, TVA
5 SEOKHWAN HUR, KEPCO E&C
6 ATA ISTAR, NRO
7 DIANE JACKSON, NRO
8 HYEOK JEONG, KEPCO E&C
9 JOSHUA S. KAISER, NRR
10 SANGHO KANG, KEPCO E&C
11 JUNGHO KIM, KHNP
12 TAE HAN KIM, KEPCO E&C
13 YUNHO KIM, KHNP
14 MYUNGRO KIM, KEPCO
15 LARRY KING, GE-Hitachi*
16 MICHAEL LAPRESTI, WEC
17 HIEN LE, NRO
18 SANYUM LEE, KHNP
19 JEFFERY LEWIS, TVA
20 CHANG-YANG LI, NRO
21 DAEHEON LIM, KEPCO E&C
22 KWANGIL LIM, KEPCO E&C
23 ROY LINTHICUM, PWROG
24 MARK LINTZ, NRO
25 CHRISTIANA LUI, ACRS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 SARA LYONS, NRR
2 GREG MAKAR, NRO
3 DAVID MCBURNEY, AREVA/TVA
4 MIKE MCCOPPIN, NRO
5 ALAN MEGINNIS, AREVA/TVA
6 DAMIAN MIRIZIO, PWROG
7 SHANDETH MONTGOMERY, ACRS
8 CHING NG, NRR
9 JIYONG (ANDY) OH, KHNP
10 ERIC OESTERLE, NRR
11 NGOLA OTTO, NRR
12 MATHEW PANICKER, NRR
13 DAN PAPPONE, GE-Hitachi
14 CHAN EOK PARK, KEPSCO E&C
15 SUNWOO PARK, NRO
16 HANH PHAN, NRO
17 SHEILA RAY, NRR
18 MUHAMMAD RAZZAQUE, NRR
19 JAMES ROSS, AECOM/KHNP
20 GREGORY ROZGA, Enercon
21 FARIDEH SABA, NRR
22 AHSAN SALLMAN, NRR
23 JASON SCHAPEROW, NRO
24 ED SCHRULL, TVA
25 VIKRAM SHAH, Argonne National Lab*

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 SIMON SHENG, NRR
2 ROB SISK, WEC
3 JAMES STECKEL, NRO
4 GREG STOREY, TVA
5 COURTNEY ST. PETERS, NRO
6 ANGELO STUBBS, NRO
7 ED STUTZCAGE, NRO
8 FRANCIS TALBOT, NRO
9 GETACHEW TESFAYE, NRO
10 MATT THOMAS, NRO
11 BOYCE TRAVIS, NRO
12 IAN TSENG, NRR
13 JESSICA UMANA, NRO
14 ANDREA D. VEIL, Executive Director
15 ROBERT VETTORI, NRO
16 HANRY WAGAGE, NRO
17 DAVE WAGNER, AECOM
18 GEORGE WANG, NRO
19 BILL WARD, NRO
20 SUNIL WEERAKKODY, NRR
21 WANG WEIDONG
22 BILL WILLIAMSON, TVA
23 ROBERT WOLFGANG, NRR
24 TAO WU, GE-Hitachi*
25 AARON WYSOCKI, ORNL

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ZUHAN XI, NRO

JINKYOO YOON, KEPCO E&C

SAMIR ZIADA, McMaster University*

*Present via telephone

1	T-A-B-L-E O-F C-O-N-T-E-N-T-S	
2		
3	Opening Remarks by ACRS Chairman	
4	Dennis Bley.....	10
5	Advanced Power Reactor 1400 (APR1400)	
6	Remarks by the Subcommittee Chairman	
7	Ronald Ballinger.....	12
8	Briefing and Discussion by Korea Hydro & Nuclear	
9	Power	
10	Yunho Kim.....	12
11	Briefing and Discussion by NRC staff	
12	Bill Ward.....	70
13	Jessica Umana.....	75
14	Getachew Tesfaye.....	92
15	James Steckel.....	94
16	Browns Ferry Extended Power Uprate Application	
17	Remarks by the Subcommittee Chairman	
18	Briefings by and discussion with representatives	
19	of the NRC staff and Tennessee Valley Authority	
20	regarding the safety evaluation associated with	
21	the Browns Ferry EPU 98 application	
22	Public Comment.....	126
23	Westinghouse Generation III Shutdown Seal.....	167
24	Staff Evaluation Overview.....	168
25	Assessment of Topical Report.....	167

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1	PWR Owners Group Overview.....	173
2	Public Comment.....	182
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIRMAN BLEY: The meeting will now come to order. This is the first day of the 644th meeting of the Advisory Committee on Reactor Safeguards.

Before we get to today's business, it's my pleasure to welcome Ms. Shandeth Montgomery to the ACRS staff as a program assistant. She joined the NRC back in 2008 and brings her extensive background in agency administration to the Committee. Her most recent assignment was in the Human Resources Office.

Welcome, Shandeth.

(Applause.)

CHAIRMAN BLEY: During today's meeting the Committee will consider the following: (1) Advanced Power Reactor 1400, the APR1400, the Browns Ferry extended power uprates, the Westinghouse proprietary topical report on PRA model for the Generation III Westinghouse shutdown seal, and preparation of ACRS reports.

The ACRS was established by statute and is governed by the Federal Advisory Committee Act. That means the Committee can only speak through its published letter reports.

We hold meetings to gather information to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 support our deliberations. Interested parties who
2 wish to provide comments can contact our offices
3 requesting time after the *Federal Register* notice
4 describing the meeting is published. That said, we
5 will also set aside 10 minutes for spur-of-the-moment
6 comments from members of the public attending or
7 listening to our meetings. Written comment are also
8 welcome.

9 Mr. Christopher Brown is the designated
10 federal official for the initial portion of this
11 meeting.

12 Portions of the sessions on the APR1400,
13 Browns Ferry extended power uprates and the
14 Westinghouse proprietary topical report may be closed
15 in order to discuss and protect information designated
16 as proprietary.

17 The ACRS section of the U.S. NRC public
18 web site provides our charter, bylaws, letter reports
19 and full transcripts of all Full and Subcommittee
20 meetings including all slide presentations at the
21 meetings.

22 We have received no written comments or
23 requests to make oral statements from members of the
24 public regarding today's sessions.

25 There is a telephone bridge line. To

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 preclude interruption of the meeting the phone will be
2 placed in a listen-in mode during presentations and
3 committee discussions.

4 A transcript of portions of the meeting is
5 being kept and it is requested that speakers use one
6 of the microphones, identify themselves and speak with
7 sufficient clarity and volume to be readily heard.

8 At this time we'll take up the issue of
9 the APR1400 and I'll turn the meeting over to
10 Professor Ballinger.

11 Ron?

12 MEMBER BALLINGER: Thank you, Mr.
13 Chairman.

14 Today we will hear presentations by KHNP
15 and the staff on Chapters, 6, 12, 13, 14, 16, 17 and
16 19. The schedule has evolved a little bit. Right now
17 there will be no closed session. Everything will be
18 open so that if it comes to a question or answer that
19 involves proprietary information, the presenters will
20 have to let us know so that we can make adjustments to
21 the audience, if need be.

22 But now I'll turn it over to Bill Ward.

23 CHAIRMAN BLEY: Okay. And we'll hold
24 those to the end of the session. If we need to go
25 into closed session --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BALLINGER: Okay.

2 CHAIRMAN BLEY: -- we'll do it at that
3 time.

4 MEMBER BALLINGER: Okay. Fine.

5 Bill?

6 MR. WARD: Yes, thank you. The staff is
7 happy to present to the Full Committee here. We're
8 very anxious to keep moving. We have a 42-month
9 schedule and everything's moving along pretty well.
10 We think we have a short, but good presentation for
11 today and we hope that we can answer all your
12 questions. And thank you again.

13 MEMBER BALLINGER: Okay. So KHNP?

14 MR. Y. KIM: Yes, thank, Mr. Chairman and
15 Mr. -- Dr. Ballinger for -- also for your review of
16 all the ACRS members.

17 Today I am going to present for Chapter 6,
18 12, 13, 14, 16, 17 and 19. So let me start on Chapter
19 6 about engineer safety feature. So engineer safety
20 feature materials are selected for compatibility with
21 core cooling components and containment spray
22 solution. The list of material is in the Table 6.1-1
23 and 2. The protective coating of APR1400 is listed in
24 the Table 6.1-3 and they then meet Reg Guide 1.54.

25 For the containment system the containment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of APR1400 is prestressed concrete with a cylindrical
2 shell and dome. It is designed such that peak
3 pressure is less than design pressure and well below
4 half of the peak pressure within 24 hours after the
5 accident. The leakage of containment is also below
6 the design leakage rate.

7 For the APR1400 containment pressure and
8 temperature analysis GOTHIC is used with assumption
9 and initial conditions to maximize the containment
10 peak pressure and the temperature. The analysis are
11 performed for a total of LOCA and steam line break
12 case feature selected for sensitivity study on
13 barriers, break size and power levels.

14 For the containment sub-compartment
15 analysis we analyzed at the place with use of COMPARE-
16 MOD1A in response to high energy line break in each
17 sub-compartment. Through the analysis we also
18 performed the map.

19 The structure test is based on ASME CC-
20 6000 and the leak-tight test is based on Reg Guide
21 1.163.

22 The containment heat removal system
23 reduces pressure and the transient following steam
24 line break and LOCA and the remove fission product
25 from containment atmosphere following LOCA.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The function of combustible gas control in
2 containment is to control the hydrogen concentration
3 in containment and IRWST below 10 percent by volume
4 during severe accident with PARs and igniters.

5 Let's move next, please. For the safety
6 injection system this system consist of four
7 independent trains and two diagonal trains. Trains 1
8 and 3 or trains 2 and 4 are required to mitigate the
9 loss of coolant accident. APR1400 safety injection
10 tank without fluidic device to eliminate the low
11 pressure safe injection pump by extending the
12 discharge time. KHNP got approval for the fluidic
13 device topical report recently. The operability of
14 safety injection system is checked through Tech Spec
15 3.5.1 through 5.

16 For the hability system the APR1400 are
17 designed to allow control room operators to remain in
18 the control room envelope and take action to operate
19 the plant safely under normal and maintain it in a
20 safe condition under design-basis accident conditions.
21 And the APR1400 hability system protect control room
22 operator from outside airborne radioactivity.

23 MEMBER POWERS: I am still unsure how you
24 look at the dispersion under DBA conditions of
25 radioactivity.

1 MR. Y. KIM: Could you -- I cannot hear
2 you. Could you --

3 MEMBER POWERS: I am still unclear exactly
4 how you calculate the dispersion of radioactivity
5 under DBA conditions to the main control room.

6 MR. KANG: My name is Sangho Kang, KEPCO
7 E&C In the DCD Section 2.3.4 we calculated the on-site
8 dispersion of the LOCA condition of radioactive
9 material, so based on the ARCO 96 model, which is
10 developed by U.S. NRC, the concentration at the intake
11 location of the main control room is calculated.

12 MR. Y. KIM: Yes. Now let me continue.
13 So the exposure to MCR personnel meet the occupation
14 dose limit of 50 millisievert. That is page 17 and
15 Reg Guide 1.183.

16 Go to next, please. The APR1400
17 engineered safety features filter system are designed
18 to mitigate the consequence of postulated accident by
19 filtering radioactive particulate and iodine from air
20 and meet the requirement of Reg Guide 1.52, and ASME
21 N509, and ASME AG-1.

22 The filter system include control room
23 emergency makeup air cleaning system, auxiliary
24 building controlled air emergency exhaust system and
25 the fuel handling area emergency exhaust system.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 For the containment spray system TSPs
2 stores at the holdup volume tank that enabled the
3 IRWST remains above pH 7 during 30 days in LOCA
4 condition.

5 MEMBER POWERS: I am not sure why I should
6 be confident that the pH will remain above 7 for 30
7 days. Why are we confident of that?

8 MR. KANG: I think the -- our program's
9 calculation to see the capability to maintain the pH
10 of greater than seven was performed -- the purpose of
11 this calculation to estimate the time to reach the pH
12 greater than seven. But during the staff's review we
13 got the comments that the -- can we make sure that the
14 pH value can last for the whole duration of the
15 accident? That's why we performed the analysis and
16 the -- we performed that the pH value of greater than
17 seven is maintained during the 30 days after the loss
18 of coolant accident. It was responded by our RAI
19 response to the staff's issue.

20 VICE CHAIR CORRADINI: Can we get the RAI
21 number that we can just at least look at that?

22 MR. KANG: I don't remember now, but --

23 VICE CHAIR CORRADINI: That's fine.

24 MR. KANG: -- we can get it.

25 VICE CHAIR CORRADINI: If we can get it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: I would be interested in
2 things like what you used for G values for nitric acid
3 formation, G values for cable insulation
4 decomposition, and especially how you treat phosphate
5 precipitation by interaction with containments coming
6 into the IRWST.

7 MR. KANG: So in order to calculate the pH
8 value we have considered the adverse effect from the
9 Hypalon which is the material of the cable. Also the
10 HECR and nitric acid which comes from the composition
11 material of the containment, inside the containment.
12 We take into account all of this adverse impact
13 materials.

14 MEMBER POWERS: Do you treat the
15 conversion of organic contaminants to carboxylic acids
16 like were seen in the RTF tests in Canada?

17 MR. KANG: I'm not familiar with that one.
18 So we can back to you.

19 MEMBER POWERS: I would appreciate it.

20 MR. Y. KIM: Yes, I think RA number is
21 found. So --

22 MR. OH: Yes, this is Andy Oh, KHNP
23 Washington office. I think associated RAI number is
24 362-8445, question No. 31st.

25 MR. Y. KIM: Okay. Yes. In our LOCA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analysis the credit for aerosol and iodine --
2 elemental iodine removal by spray and for aerosol
3 removal by natural deposition in containment business
4 was credit.

5 Would you move next, please? For the in-
6 containment water storage system that is consist of a
7 storage tank and holdup volume tank and the cavity
8 flooding system. The IRWST is protect, reliable and
9 safety-related source of borated water for containment
10 spray system and the shutdown cooling system and the
11 safety injection system. The IRWST is also used to
12 prepare the refueling pool in support of refueling
13 operation.

14 Holdup volume tank collect and store
15 coolant during the accident condition.

16 The function of a cavity flooding system
17 is to flood the reactor cavity in the event of a
18 severe accident.

19 And IRWST have minimum level of IRWST to
20 support safety injection and containment spray pump
21 operation during the accident condition.

22 MEMBER REMPE: Excuse me. When we discuss
23 Chapter 19 we learn that even though you have this
24 cavity flooding system, you did not take credit for
25 it. You assumed the vessel failed to be conservative.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And it's still unclear to me how much you didn't take
2 credit for it. In the PRA do you assume that the
3 water still goes to the cavity instead of whether --
4 you know, when it's injected, even though you didn't
5 take credit for the vessel to fail, did you assume
6 good heat transfer from the vessel to the water? It
7 wasn't clear how this evaluation was done.

8 And I believe when we discussed Chapter
9 19, you indicated, well, when we do severe accident
10 management guidance, that will be something the COL
11 applicant will take care of. So it -- that -- how the
12 COL applicant will look at the certified design and
13 take care of what actions should be considered is
14 unclear to me. Could you give me any clarification on
15 that interface?

16 MR. Y. KIM: Yes, let me check -- let me
17 put it to our --

18 (Simultaneous speaking.)

19 MR. OH: This is Andy Oh, KHNP Washington
20 office. I think we have a two feature of the
21 mitigation feature. I think, Member Rempe, you
22 mention that the thing is not that CF is -- cavity
23 flooding system. That is IVREVC, in-vessel retention
24 ex-vessel cooling system.

25 MEMBER REMPE: Yes, right.

1 MR. OH: That we didn't credit it, so it's
2 a COL action item. COLAs, they will develop their
3 strategy to implement that system, however, cavity
4 flooding system is certified severe mitigation
5 strategy. So it is included in our design.

6 MEMBER REMPE: So the PRA takes credit for
7 that the water would be injected. And so what I'm
8 kind of -- there's sometimes unintended concerns about
9 external reactor vessel flooding. For example, if you
10 don't take credit for it, do the staff still review to
11 make sure that the structures are robust to withstand
12 what would be needed for external reactor vessel
13 cooling?

14 And so this interface puzzles me because
15 if you say, well, we don't take credit for it, then
16 you don't have to worry about is the insulation strong
17 enough to withstand that chugging that would occur?
18 When the APR1000 or the AP600 was looking at this,
19 they had to consider how it operated.

20 And maybe this is also something the staff
21 would clarify, but I'm just not sure how carefully the
22 flooding system was reviewed and the strategy was
23 reviewed, because you actually could have less heat
24 transfer from the vessel.

25 MR. OH: Yes, all that is relevant to

1 support IVREVC, not the CFS system. But I --

2 MEMBER REMPE: What is the cavity flooding
3 system for?

4 MR. OH: Cavity flooding system is just to
5 open a valve from the holdup volume tank and provide
6 water to the cavity. Probably it's a depth about five
7 feet or six feet. But the difference from the IVREVC
8 is IVREVC, we have to inject the water through the --
9 using a shutdown cooling to the cavity. And the flood
10 level, probably it's more than 14 and 16, 17 feet. I
11 should be covered. The bottom of the reactor vessel.
12 So those two strategies totally different.

13 MEMBER REMPE: Okay. So I should have
14 held my question until Chapter 19 then.

15 MR. OH: Okay.

16 MEMBER REMPE: But I will have that
17 question when you get to Chapter 19 even though it's
18 not in your slides how did you look at that? I
19 understand now that it's a depth thing, but please
20 clarify that when you get to Chapter 19.

21 MR. OH: Thank you.

22 MR. Y. KIM: This is end of the Chapter 6.
23 In-containment water system we have a swing panel.
24 Four vent stacks are located on the top of IRWST and
25 three swing panels per vent stack are provided to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 protect overpressure and the vacuum of IRWST. Two
2 swing panels per overpressure protection and one swing
3 panel for vacuum protection. The right side -- the
4 left -- to the right side figure shows the
5 overpressure protection and the vacuum protection
6 panel.

7 Those same panels are self-actuated by
8 IRWST pressure and provided for hydrogen venting
9 during the severe accident also. Those same panel
10 also prevent vacuum in the IRWST during ECCS and the
11 containment space inflation.

12 For the functionality of IRWST swing
13 panels we got some request for additional information,
14 so KHNP is trying to provide a response for this
15 issue. So we are working on it.

16 VICE CHAIR CORRADINI: If I might ask --
17 I just want to make sure I understand the operation.
18 So there's -- the one set of panels pull out inflow.
19 Sorry. Thought it was on.

20 Let me just ask, I thought it was -- there
21 is panels to the left of your mechanical drawing to
22 allow inflow and then a different set to allow
23 outflow. So does that mean one or both panels are
24 always open?

25 MR. Y. KIM: Usually just they're slightly

1 -- slight close, but the mechanic can --

2 (Simultaneous speaking.)

3 VICE CHAIR CORRADINI: So what's the need
4 of the panels at all if you're allowing both for in
5 and outflow? I might be missing something about the
6 function. Can you help me?

7 MR. Y. KIM: Yes, if you --

8 (Simultaneous speaking.)

9 VICE CHAIR CORRADINI: -- in and outflow
10 by two different sets of panels.

11 MR. Y. KIM: Yes, you can --

12 MR. SISK: Rob Sisk, Westinghouse. Just
13 to refresh on the panels, the primary reason for those
14 panels of course is debris mitigation to the tanks
15 itself and also concern for the condensation from the
16 tank. So you want to keep the panels basically
17 closed, but you don't want to have pressure
18 differentials between containment and into the tank.

19 VICE CHAIR CORRADINI: So this is for
20 water management then?

21 MR. SISK: Tank management, call it that
22 if you will. You don't want debris and stuff going
23 into your tank. You don't want condensation.

24 VICE CHAIR CORRADINI: Okay. I couldn't
25 remember that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SISK: Yes.

2 VICE CHAIR CORRADINI: Okay. Thank you
3 very much.

4 MR. Y. KIM: And then the next chapter is
5 Chapter 12. I report it to Mr. Kang.

6 MR. KANG: Morning. My name is Sangho
7 Kang, KEPCO E&C. I'm going to briefly talk about the
8 overview of Chapter 12.

9 In order to ensure that the occupation
10 radiation exposure ALARA APR1400 provides a structure
11 to effectively implement radiation protection policy
12 for any review that are consistent with the
13 operational and maintenance requirement to Reg
14 Guide 1.8, 1.33, 8.8 and 8.10.

15 The design policy of the APR1400 is to
16 implement the ALARA velocity during the early stage of
17 the design. The APR1400-specific ALARA design guide
18 specify the approach, method and implementation guides
19 for the designers to take into account. In the design
20 of equipment the ALARA design guidelines applies to
21 easy removal of contamination, enhancement of
22 reliability to reduce maintenance and minimization of
23 corrosion. And the layout design of the ALARA design
24 guide requires to separate the radioactive equipment
25 from the non-radioactive equipment and to provide

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sufficient areas for inspection and maintenance.

2 As for the radioactive source term, the
3 reactor core fission products are estimated using
4 ORIGEN-S computer code based on the thermal power of
5 102 percent. The source term of spent fuel is
6 calculated based on 100-hour decay time before the
7 movement from the core.

8 The reactor coolant system fission product
9 source terms provided in Chapter 12 are determined
10 based on the fuel defect rate of 0.25 percent using
11 DAMSAM code and used for the design of shielding and
12 ventilation. The CVCS source terms are calculated
13 using SHIELD-APR computer program assuming that the
14 gas stripper is not operated to maximize the gaseous
15 sources.

16 The source terms of the shutdown cooling
17 systems are calculating assuming that the systems stop
18 operation at four hours after shutdown. The design
19 base source system in the spent fuel pool water is
20 determined assuming that the primary cooling water is
21 mixed with spent fuel pool water after 48 hours of
22 shutdown cooling operation.

23 The source term in the leakage waste
24 management system are determined using DIJESTER
25 computer code. The build-up activity in the gaseous

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 radioactive system is calculated using the inflow from
2 the CVCS tanks and the gas stripper. The solid waste
3 such as spent-resins, filters, sludge are generated in
4 the CVCS liquid waste management system, spent fuel
5 pool cooling and clean-out system and steam generator
6 blowdown systems.

7 The airborne activity in the
8 radiologically-controlled area is calculated assuming
9 maximum leakage of the radioactive components. The
10 accident source terms which are used for post-accident
11 shielding design and equipment qualification are
12 determined by Regulatory Guide 1.183 which assumes a
13 significant core melt.

14 The APR1400 design incorporates ALARA
15 principles in accordance with Reg Guide 8.8 and 8.10.
16 These principles apply to various areas of plant
17 design. Design criteria for shielding as specified in
18 Reg Guide 8.8, 40 CFR 190, GDC 19 and 10 CFR 50.34.

19 The shielding analysis are performed using
20 several computer codes such as ANISN, MCNP and
21 MICROSSHIELD. The RUNT-G code is used to determine the
22 post-accident shielding rulemakings. The shielding
23 analysis produce design-basis drawings including
24 radiation zone maps and the minimum required shield
25 thicknesses.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The ventilation flows are provided to
2 ensure the airborne contamination is maintained less
3 than some of the DAC fractions. These air flows are
4 designed to flow from the lower to higher contaminated
5 areas so that the spread of contamination is
6 minimized. In addition, the continuous air monitoring
7 by effluent and area radiation monitors ensure the
8 detection of the airborne contamination level change
9 within 10 DAC-hours as is specified in the SRP 12.3.

10 Area radiation monitoring systems are
11 provided to ensure to protect plant personnel from the
12 unusual radiological events and monitor post-accident
13 radiation levels. Some of the area radiation
14 monitoring system provides balance of ESF, actuation
15 signal.

16 In accordance with Reg Guide 8.19 the
17 occupational radiation exposure for APR1400 was
18 estimated based on the measurement data for operating
19 1,000 megawatt PWR in Korea. And this exposure data
20 was increased taking into account the power ratio of
21 APR1400. The resultant occupation exposure was
22 estimated to be 585 person-millisievert per year or
23 58.5 man-ram per year.

24 The vital areas mission doses is estimated
25 for both continuously occupied area and infrequent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 access areas. The exposure dose to the plant personnel
2 who takes emergency action satisfied the regulatory
3 limit of 15 millisieverts.

4 10 CFR 20.1406 requires to minimize
5 contamination of facility and the environment and to
6 minimize generation of radioactive waste. The
7 detailed guidance in implement 10 CFR 20.1406 are
8 provided in Reg Guide 4.21. To fulfill this
9 requirement APR1400 design established several design
10 objectives. Under these objectives the APR1400 design
11 was reviewed and evaluated in accordance with the
12 guidance in Reg Guide 4.21. As a result, an extensive
13 list of design features are identified and provided in
14 the DCD.

15 That's all for Chapter 12. If you don't
16 have any more questions, I'll turn it over to Mr. Kim
17 again.

18 MEMBER KIRCHNER: I have a question. So
19 you went through all this. Based on your operating
20 plants did you make any significant changes in
21 material selection for corrosion or layout for
22 maintenance or any other changes that might further
23 your ALARA objectives?

24 MR. KANG: For this design of DC
25 application the APR1400 design was based on the Shin

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Kori Units 3 and 4. It's the first unit of APR1400.
2 But the first Shin Kori design for the -- with respect
3 to ALARA, the design for DC application is not so
4 different from the Shin Kori example. But the Shin
5 Kori 3 and 4 is quite different from the previous
6 OPR1000 design with respect to the reduction of the
7 corrosion and the layout of the plant. So all of
8 these design features are provided in the Chapter 12.

9 MEMBER KIRCHNER: Okay. Thank you.

10 MEMBER BALLINGER: So to sort of clarify
11 that in my mind, the exposure was based on the 1000
12 megawatt reactor, an OPR reactor?

13 MR. KANG: That's correct.

14 MEMBER BALLINGER: And those plants had
15 different materials; in particular steam generator
16 tubing material, those kinds of things, from the Shin
17 Kori plants?

18 MR. KANG: Right.

19 MEMBER BALLINGER: And so why was there a
20 correct -- why not use the Shin Kori plants as the
21 basis for the ALARA as opposed to the OPR1000?

22 MR. KANG: Because the Shin Kori 3 and 4
23 didn't start operation yet.

24 MEMBER BALLINGER: Okay. All right. So
25 that's that point.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KANG: Okay.

2 MEMBER BALLINGER: Okay.

3 MR. KANG: All right.

4 MEMBER BALLINGER: So it didn't -- now, is
5 there a plan to --

6 MR. KANG: Yes.

7 MEMBER BALLINGER: -- check it out?

8 MR. KANG: Sure. Sure. Once it's --
9 (Simultaneous speaking.)

10 MEMBER BALLINGER: To see if you're right.

11 MR. KANG: Yes, that's what we are waiting
12 for.

13 MEMBER BALLINGER: Okay. Thank you.

14 MR. KANG: Okay. Thank you.

15 MEMBER SUNSERI: I have one other
16 question. During our -- I get the chapters mixed up
17 a little bit, but during our Subcommittee discussion
18 we had a question regarding manual drawing of post-
19 accident samples and whether or not those highly
20 radioactive samples would be sufficiently shielded to
21 keep the dose rates to the personnel acceptable. And
22 it seems like that question was left hanging. So did
23 you look into that and can you confirm that personnel
24 are able to take the post-accident samples without
25 undue radiation exposure?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KANG: I think that question was not
2 raised during the Chapter 12 Subcommittee meeting. I
3 think some other chapter. But I think I can answer
4 that question.

5 For the post-accident sampling we had
6 special shielding design sampling. So we got the
7 sample behind the shielding wall. So it's not the
8 scope of the architect engineering design. That is
9 provided by the vendor. And the sampling of the
10 primary side or coolant is protected with respect to
11 the radiation. So we take into account when we do --
12 when we calculate the vital area dose because the
13 sampling area is one of the vital areas we need to
14 take some -- the operator to take action. So when we
15 calculate the dose to the operator for the sampling --
16 so we take that into account.

17 MEMBER BALLINGER: To expand on that
18 again, have you considered related to Fukushima and
19 their radiation doses in the post-accident sampling
20 process and shielding here?

21 MR. KANG: Because we -- in our original
22 design we already take into account the post-accident
23 sampling during entry and exit for the sampling
24 action, so we do calculate the dose to the operator
25 during his passes and entry and coming back to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MCR. So all of the information was provided in
2 Chapter -- Section 12.4.

3 MEMBER BALLINGER: Yes.

4 MR. KANG: So, because it is required by
5 the TMI action items.

6 MEMBER BALLINGER: Yes, but there's
7 additional information from Fukushima.

8 MR. KANG: I think --

9 MEMBER BALLINGER: I think. Joy?

10 MEMBER REMPE: Ron, there were hydrogen
11 explosions at Fukushima. They were BWRs. They were
12 different power levels. I'm not sure that that would
13 be relevant to this design.

14 MEMBER BALLINGER: But you have failed
15 fuel?

16 MEMBER REMPE: Yes, they definitely had
17 failed fuel, but again it's a lot different to going
18 into those plants than what would be considered here.

19 MR. Y. KIM: I think because when we
20 calculated the sampling dose, the post-accident
21 sampling dose, we assume a significant core melt. And
22 the IRWS is contaminated significantly. We take that
23 into -- conservatively we calculate the dose.

24 MEMBER BALLINGER: Thank you.

25 MR. Y. KIM: Yes, let me take over Chapter

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 13. So conduct of operation. Chapter 13 consists of
2 seven sections relating to conduct of operation. Most
3 of Chapter 3 -- 13 are COL items. And the 13.6 is
4 about physical security, which is SGI information, so
5 we don't discuss today.

6 This chapter provide information related
7 to preparation and the plan for the design,
8 construction and operation of APR1400. Its purpose is
9 to provide adequate assurance that COL applicant
10 establish, maintain staffs of adequate size and
11 technical competence. And this chapter shows that
12 operating plant followed by license -- licensee
13 adequate to protect public health and safety.

14 So let me just go the table. Proposed
15 Section 13.1 is about organizational structure and
16 applicant -- this is a COL item. And .2 is plant
17 staff training. Also COL item. .3 about emergency
18 plan. .4 is about operational program implementation.
19 13.5 is about administrative and operating procedure.
20 14.3 describe the physical security design piece of
21 APR1400. The related information is in our security
22 vault. So that is SGI information, so we cannot
23 discuss that. Section 13.7 is about fitness-for-duty
24 programs. Most of these are COL items.

25 Let me move to Chapter 14. Chapter 14 is

1 about Verification Program. Chapter -- APR1400
2 Initial Test Program is developed to meet the Reg
3 Guide 1.68. The test period is from the completion of
4 construction to the power ascension test.

5 Chapter 14.3. ITAAC is not discussed
6 today's meeting. That will be presented in the Phase
7 5.

8 The test phase divide into four different
9 phase. Phase I is for pre-operation test. Phase II
10 is about fuel loading and the pre-core hot function
11 test. Phase III is criticality and the low-power
12 physics test. Phase IV is a power ascension test.
13 Total number of test we have 178.

14 Could you move next, please? For Chapter
15 16, that is about Tech Spec. Tech Spec of APR1400 are
16 developed based on NUREG-1432. APR1400 is not applied
17 risk informed tech spec. Unique design feature of
18 APR1400 were reviewed for applicability of NUREG-1432
19 to APR1400. And related technical report was
20 submitted to NRC.

21 The major deviation is APR1400 design
22 adopt POSRV and the four safety injection trains
23 rather than two trains and IRWST. And we have
24 auxiliary feed water system with the turbine. And we
25 have -- for the -- regarding electrical system, we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have a four EDG rather than three EDG. So that is a
2 major deviation, so that is incorporated in our tech
3 spec.

4 The tech spec number is specified in my presentation.

5 For Chapter 17, Quality Assurance Program.
6 Chapter 17 is composed of six section, Section 1, 2,
7 3 and 5 are about Quality Assurance Program. Section
8 4 is related to the Reliability Assurance Program,
9 RAP. Section 6 is handling about the maintenance
10 rule. KHNP is prepared to submit and submitted a QA
11 Program to NRC as the form of a topical report. This
12 comprise with all the regulatory requirements such as
13 Part 50, Appendix X, Part 21 and ASME NQA-1. This QA
14 Program is implemented and improved according to
15 corrective action in KHNP.

16 Move next slide. As an applicant KHNP has
17 the final responsibility to design control. KHNP
18 delegated the design activity to three design
19 suppliers: KEPCO E&C for balance of plant and NSSS
20 design; KEPCO NF for fuel and core design; DOOSAN for
21 NSSS component design.

22 To oversee the delegate design activity
23 KHNP are doing five kind of major activity. First,
24 KHNP evaluate, select and qualify supplier and seal
25 the contract with them only. Second, KHNP receive,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 review, approve the design product from design
2 supplier and the NRC. Third, KHNP control RAI and all
3 the related change in the design process. Fourth,
4 KHNP preside committee related to design change,
5 interface and the project measurement meeting. Fifth,
6 KHNP does QA inspection internally and externally to
7 check the implementation status and to improve QA
8 Program as a part of corrective action.

9 Let's move to RAP requirements. This
10 slide is about RAP. The design, construction and the
11 operation are consistent with risk insight and they
12 key assumption from PRA. The programmatic control
13 ensure that RAP list is appropriately developed and
14 maintained and communicated to the related
15 organization. QA Program oversee activity of
16 affecting RAP SSC quality.

17 The RAP is implemented during operation
18 phase via Maintenance Rule Program, QA program and the
19 various test and maintenance programs. Design RAP
20 should therefore align for a seamless transition to
21 these programs.

22 So maintenance rule --

23 MEMBER SKILLMAN: So back up on, please.
24 To your last bullet, there should be seamless
25 transition, that transition will be seamless only if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the leadership that is involved causes it to be
2 seamless. Those of us who have been through this know
3 that this is an effort that takes an enormous focus by
4 many people. And so I would ask even though this plan
5 is many years in the future, what KHNP's vision is of
6 how this seamless transition will be ensured.

7 MR. Y. KIM: Yes, usually in Korea we have
8 very many operate -- conceptualization project during
9 the last more than 20 years. So in our project is
10 three organization. KEPCO E&C, DOOSAN, and KEPCO NF
11 and the KHNP work together every project for reports
12 and the Kori unit that we have ability accumulate the
13 experience to work together. So we have -- each
14 company has their own energy expert. So through the
15 many meeting with expert panel -- so we are going to
16 update the RAP SSC. So probably we can do the
17 seamless transition. So from the design -- I'm not
18 sure that help you.

19 MEMBER SKILLMAN: That's in the right
20 direction. Thank you.

21 MR. Y. KIM: So Maintenance Rule Program
22 is also described in SRP 17.6 that is required by Part
23 50.65. The detailed procedure and the implementation
24 will be the responsibility of the COL applicant. We
25 are going to seamless transition to this program.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We have to move to Chapter 19, PRA.
2 Chapter 19.1 covers the APR1400 PRA. Shown on this
3 slide are the scope of PRA by the operation mode and
4 the hazard. Note that seismic evaluation was
5 performed using PRA-based seismic margin assessment
6 and we applied a bounding approach for the level 2
7 internal flooding at low power and the shutdown mode.

8 This slide highlight the key approach for
9 PRA modeling and quantification. The PRA use a linked
10 fault tree method to ensure that initiate and support
11 system impact on the front line mitigation system are
12 considered. Common-cause failure was considered for
13 the intra-system SSC. Additionally, inter-system CCF
14 modeled between containment spray and the shutdown
15 cooling pump because the pumps are identical.

16 Human error probability initially set
17 artificially high to ensure dependent operator
18 accidents are not prematurely truncated prior to
19 application of a dependent HEP barriers.
20 Quantification is performed using truncation value 10
21 to minus 13 for the CDF; 10 to minus 14 for the LRF
22 quantifications.

23 Uncertainty analysis contains three part:
24 parametric uncertainty; identification of a modeling
25 uncertainty; quantification -- and the quantification

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of a selected uncertainty case. Parametric
2 uncertainty use the state of correction to estimate
3 the mean barrier of a CDF from point estimate produced
4 by PRA quantification. Modeling assumptions were
5 identified and evaluated for the potential impact on
6 the conclusion. For sensitivity case two for CCF, two
7 for HEP were quantified.

8 Let's move to next, please. Key design
9 improvement from risk insight include original two
10 EDG design change to four EDG. AAC, we change from
11 diesel generator to gas turbine generator. Also we
12 increased capacity for 125-volt DC battery. Also,
13 Tech Spec 3.6.7 is revised for the equipment hatch
14 closure in Mode 5. Also, the protection of cable from
15 fire damage is the same.

16 Let's move next, please. Other
17 application in DC Phase include also design RAP, SAMDA
18 and the input to human factor engineering and the
19 physical security. Operational Phase would include
20 operational RAP, ROP, CVTR determination process and
21 the maintenance rule.

22 The next slide shows that the overall risk
23 profile from PRA. The result show that no one hazard
24 or operating mode dominate the risk. Internal
25 flooding risk is very low due to the design feature of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the plant.

2 Next slide.

3 MEMBER STETKAR: Let me stop you there.
4 It's my understanding that we had several questions
5 about the PRA during the Subcommittee meeting and we
6 were informed at that time that KHNP is updating the
7 PRA to include several what I'd call substantive
8 changes. I know that you're proposing to revise the
9 models for reactor coolant pump seal failures. I
10 think we were told that you're reviewing all of the
11 operator actions in both the full power and shutdown
12 models to ensure consistency in the treatment because
13 then they'd be treated differently in different parts
14 of the models. And there were several other items of
15 varying potential importance to the overall risk and
16 the distribution that you show on this slide.

17 Is that still true? Are you planning a
18 substantive update to the PRA?

19 MR. Y. KIM: Yes, we are working -- still
20 working on it. And could you help me with that?

21 MR. ROZGA: This is Greg Rozga from
22 Enercon and the simple answer to your question is yes,
23 we are working on that. We are at this point --

24 MEMBER STETKAR: Greg, get real close to
25 that mic.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. ROZGA: We are at this point complete
2 with the Level 1, and the Level 2 changes are going in
3 now.

4 MEMBER STETKAR: Okay.

5 MR. ROZGA: And we -- for Level 1 we still
6 have to do the dependency analysis, but we want to
7 make sure that we get the dependency analysis between
8 Level 1 and level 2, so we're kind of waiting --

9 MEMBER STETKAR: When you say "dependency
10 analysis," you mean --

11 MR. ROZGA: HEP dependency.

12 MEMBER STETKAR: HEP dependency?

13 MR. ROZGA: Correct.

14 CHAIRMAN BLEY: Okay.

15 MR. ROZGA: Correct. So those actions in
16 Level 2 we want to make sure if there's any dependency
17 with the Level 1 actions that we capture that.

18 MEMBER STETKAR: You also -- when you say
19 Level 1, you mean both full power and shutdown --

20 (Simultaneous speaking.)

21 MR. ROZGA: Correct.

22 MEMBER STETKAR: Because that was one of
23 the bigger areas that you were concerned about.

24 MR. ROZGA: Yes. And then the --

25 MEMBER BALLINGER: And now for the complex

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 answer. When?

2 MEMBER STETKAR: Well, I'm assuming that
3 will require an update to the DCD.

4 MR. Y. KIM: Yes, we are going to provide
5 that soon, so we will try very hard.

6 MEMBER STETKAR: Try very hard.

7 MR. Y. KIM: Okay.

8 MEMBER STETKAR: Well, we'll try very hard
9 to review it in a timely manner then.

10 VICE CHAIR CORRADINI: So can I ask a
11 question on that, John? Or, Ron, I should say.
12 Excuse me.

13 So once this is done for Chapter 19, are
14 we going to come back and have a Subcommittee meeting
15 or wait until the DCD is presented to staff and staff
16 has to -- what I'm trying to understand is the process
17 at this point. I understand the process.

18 MEMBER BALLINGER: The current answer is
19 no, that the next time we would see this would be in
20 Phase V.

21 VICE CHAIR CORRADINI: Which is 18?

22 MEMBER BALLINGER: Yes. At which time
23 people just take their chances that it'll work.
24 That's the current -- and Bill can correct me if I'm
25 wrong, but I think that's the current answer.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WARD: That's the current answer as I
2 understand it. I've had discussions with KHNP and at
3 this point they didn't want to go forward with a
4 second Subcommittee meeting.

5 MR. Y. KIM: Yes, I think that there is
6 most organized, and so you are going to close all the
7 organized probably.

8 MEMBER REMPE: So during our discussion we
9 learned that the PRA said that bypass failures
10 dominate core damage frequency. And when we started
11 delving into that, we learned that you based your
12 conditional probability for consequential steam
13 generator tube rupture on work that was done for a
14 Westinghouse plant. And there has been a more recent
15 report done by the staff where they evaluated a CE
16 geometry and a Westinghouse geometry and they found an
17 order of magnitude higher for that consequential steam
18 generator tube rupture. So that's an example of
19 something that I think might be a significant change.

20 And during our discussion I believe KHNP
21 responded that wasn't available when we did the PRA.
22 And this is a new document. It was -- the draft is
23 publicly available and they would look into it. Have
24 you guys looked into it and said, well, maybe we
25 should use a geometry that's more appropriate for CE

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 design?

2 MR. DREMEL: Ray Dremel from Enercon. We
3 have not been able to incorporate that at this -- as
4 of yet into the model. We talked earlier. That
5 document came out after we had started down Revision
6 0. We need to look into whether we can incorporate
7 that and how that will be incorporated into the
8 next --

9 (Simultaneous speaking.)

10 MEMBER REMPE: That might be a good
11 example of something that might make a significant
12 difference. And it would be nice to see that result.
13 That you are planning to do that, is what I'm hearing.

14 MR. DREMEL: We will look into
15 incorporating it. I'm not going to make commitments
16 for KHNP on what they will or will not do, but that is
17 something we need to consider.

18 MEMBER REMPE: Okay. Thank you.

19 MEMBER KIRCHNER: I'd like to ask a
20 different line of questioning. I've always felt that
21 the most value of the PRA is to insight it gives, not
22 the numbers. So if I just look at your graph, it
23 looks like half -- and I'll use the term loosely, half
24 of your risk almost is due to fire and over half of
25 the risk is at low power. So what are you doing --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: With all plants.

2 MEMBER KIRCHNER: I know. I know. So my
3 question is you have this information. Now what do
4 you do with it? Are you content with this or do you
5 then look at your operating procedures or your fire
6 protection programs and look at where the
7 vulnerabilities are here? How do you -- what are you
8 using this for that improves your design?

9 MR. DREMEL: This is Ray Dremel with
10 Enercon again. And roughly -- as you say, roughly
11 half the risk is due to fire, but the total risk for
12 APR1400 is fairly low.

13 MEMBER KIRCHNER: Right.

14 MR. DREMEL: So this is a big piece of a
15 small pie.

16 MEMBER KIRCHNER: I just --

17 MR. DREMEL: And we have looked at -- as
18 Mr. Kim mentioned earlier, there are certain cables
19 that if we -- if they are protected and they're put in
20 as a whole item, that greatly reduces risk.

21 We did use the results to -- what are the
22 vulnerable -- what are the big contributors to risk?
23 We eliminated -- we did make COLA commitments to
24 reduce that risk. Now we're down to the -- the risk
25 is fairly well balanced across things. There's not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 one --

2 MEMBER KIRCHNER: Dominant?

3 MR. DREMEL: There's not a silver bullet.
4 There's -- as this chart shows, the risk is fairly
5 well distributed across all modes and all events.
6 Flooding risk is low because there's just no flood
7 sources in the aux building.

8 MEMBER STETKAR: Just for clarification
9 for the members here, that's internal flooding.

10 One thing I wanted to mention on the
11 record is that this profile that we see here does not
12 include risk from seismic events which are not
13 quantified, nor does it include the risk from the so-
14 called other external events categories. For example,
15 high winds, tornadoes, external flooding and so forth.
16 If those were included in the PRA, they might somewhat
17 alter this profile. We don't -- there's no way of
18 knowing that until the site-specific PRA is done with
19 their hazard and winds and flooding and so forth. So
20 this is the part of the picture that they can show at
21 this point for the certified design.

22 MEMBER KIRCHNER: Thank you.

23 CHAIRMAN BLEY: I didn't attend the
24 Subcommittee meetings, but one thing I've seen in
25 other design certifications is for the kinds of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 locale-specific events that Mr. Stetkar just
2 described. They often used a surrogate seismic source
3 and surrogate water designs and then said at the COL
4 stage you have to ensure you're less vulnerable than
5 that surrogate or you have to do more work at that
6 stage. Is that the same thing done here or did you
7 just not consider those kinds of events at this point?

8 And if that second one is true, what
9 direction is there for the COL when you actually know
10 what the site-specific issues would be?

11 MR. DREMEL: There were screening analyses
12 done for certain external events like high winds. It
13 showed that we expect those based on conservative
14 criteria to be a negligible contributor to overall
15 risk. For seismic events we can't -- you can't really
16 do a seismic PRA because you don't have a plant to
17 look at. You don't know what specific make and model
18 of components were done.

19 So if there is a COL item, the licensee
20 would have to do a full seismic PRA before fuel load.
21 Certain external events like external flooding are
22 left to the COL applicant to show that they are within
23 the constraints we've assumed in their screening
24 analyses.

25 CHAIRMAN BLEY: That seems an appropriate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 time to look at those and I hope should there ever be
2 one, we actually do that.

3 MEMBER STETKAR: There is just -- again
4 for the other Committee members, like as you're aware,
5 I took a pretty good look at what they've done. They
6 do have a -- I would call it a more robust PRA model-
7 based seismic margin analysis than we've seen in other
8 design certifications. They do not have quantified
9 seismic risk values, either core damage frequency or
10 release frequencies. They have done a -- I'd call it
11 a limited conditional quantitative evaluation where
12 they've ranked seismic contributors by running a
13 nominal seismic event through their PRA models, which
14 is a little bit more than we've seen in other studies.

15 CHAIRMAN BLEY: That helps, but given what
16 was just said, when the staff comes up, I'd be
17 interested in their expectations for the COLA PRA.

18 MEMBER BALLINGER: This overall risk
19 profile includes FLEX, or whatever you're calling it?

20 MR. DREMEL: No, we took no credit in this
21 PRA for FLEX.

22 MEMBER STETKAR: Be careful. You took
23 credit for some FLEX-y stuff, so you took credit for
24 the --

25 (Laughter.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: -- whatever you call the
2 -- I've always forgotten the acronym, the truck that
3 sprays the containment.

4 MR. DREMEL: Yes. Yes, the --
5 (Simultaneous speaking.)

6 MEMBER STETKAR: And that's kind of a
7 FLEX-Y sort of thing.

8 MR. DREMEL: Yeah. So any credit would be
9 minimal. As Mr. Stetkar said, it would be the
10 external -- ESCBS.

11 MEMBER STETKAR: Yes.

12 MR. DREMEL: External containment spray --

13 PARTICIPANT: ECSBS.

14 MR. DREMEL: ES -- yeah. So we hook up a
15 fire truck to an extra header in the containment to
16 reduce containment pressure. But as far as the
17 Fukushima modifications we -- the PRA took no
18 credit --

19 (Simultaneous speaking.)

20 MEMBER STETKAR: Yes, the other parts that
21 -- we'll hear about some of those I think in 19.3.

22 MEMBER BALLINGER: I'm cautioned by Mr.
23 Stetkar about comparing to other plants because
24 everything's different, but I have the risk poster for
25 another CE, the System 80 plant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: It's irrelevant.

2 MEMBER BALLINGER: That's what he cautions
3 me on.

4 (Laughter.)

5 MEMBER BALLINGER: But I'll say it anyway.
6 The fire risk is the same. The total fire
7 contribution for that plant is pretty much the same as
8 this.

9 MEMBER STETKAR: The fractional
10 contributions here though at a high level are not
11 unusual for a broad spectrum of plant designs, whether
12 they're PWRs or BWRs or the country of origin or
13 anything. This is not an unusual risk profile. And
14 typically it will change somewhat once the seismic
15 risk is quantified.

16 MR. Y. KIM: Then let me move to next
17 chapter. Chapter 19.2 is severe accident evaluation.
18 17 -- 19.2 describe severe accident evaluation.
19 APR1400 is designed to meet the related criteria such
20 as Part 50.34 and Part 52.47, and the SECY-93-087, and
21 the Reg Guide 1.216.

22 Comprehensive analysis of in and ex-vessel
23 severe accident progression are made with conservative
24 approach to cope the uncertainty. First, for the
25 hydrogen there's -- hydrogen concentration inside the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 containment is lower than 10 percent by large free
2 volume of containment and PAR and igniters. So the
3 hydrogen combustion risk can be eliminated, can be
4 minimized.

5 For the molten core concrete interaction
6 this mid-line can maintains its leak-tightness by
7 using cavity flooding system.

8 Could you move to next slide? For high
9 pressure melt ejection and the direct containment
10 heating reactor coolant system pressure at the reactor
11 vessel failure can be low by rapid depressurization
12 system and the possibility of containment failure from
13 direct containment heating can be minimal.

14 For the fuel-coolant interaction reactor
15 vessel and the cavity structure integrity is
16 confirmed.

17 For the containment performance Reg Guide
18 1.216 Position 2 related with the combustible gas
19 control and the Position 3 for more likely severe
20 accident challenge are confirmed.

21 Accordingly, the analysis result indicate
22 containment and the severe accident mitigation
23 features of APR1400 meet the severe accident
24 requirements.

25 MEMBER REMPE: So, excuse me. I think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this is the time to re-ask my question about the in-
2 vessel retention system and the fact that it exists,
3 but no credit was taken for it and the fact that we
4 were told that that will be left to the COLA
5 applicant.

6 My question is really at a higher level is
7 -- this interface about how if an applicant came in,
8 how they would extract what's need for the severe
9 accident management strategies. Earlier in your
10 slides today you said we are preparing the severe
11 accident management strategies. Do they consider the
12 in-vessel retention system? And is it in the PRA even
13 though you don't take credit for it? Did the staff
14 review the robustness of that system and what the
15 effects are with water addition in their accident
16 management strategies?

17 MR. OH: Yes, this is Andy Oh, KHNP,
18 Washington office. And that matter is -- actually in-
19 vessel is not credited as a mitigating feature for the
20 APR1400 due to the uncertainty surrounding associated
21 phenomena. For example, steam explosion or something.
22 And along with the operator's action, for example for
23 the shutdown cooling, have to operate the cavity
24 flooding system.

25 So the position for the KHNP is for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 SAM, severe accident mitigate -- management system is
2 when develop the COL applicant, they have to consider
3 both the negative impact and the positive impact
4 together. If they think it's for -- positive impact
5 is more than negative impact, they can implement in
6 their SAM, those severe accident management system.
7 However, for APR1400 is -- this feature is already
8 implemented in our design. We are not obligated for
9 the COL applicant have to use this features their --
10 the SAM, severe accident management. So that is our
11 position.

12 So probably in a COL applicant they can
13 evaluate more of the steam explosion or other
14 associated phenomena for the negative impact to that
15 in-vessel, especially the strategy. If they think is
16 more -- positive impact is more than the negative,
17 they can implement that strategy to their management
18 system.

19 MEMBER REMPE: Thank you. So now what I'm
20 hearing is that it's an optional system at the -- and
21 I'm wondering now; and maybe I should ask the staff,
22 but did they review an optional system for robustness
23 and possible adverse effects? And if they -- again,
24 when this comes up with the applicant, it used to be
25 clearly documented at this optional system wasn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 considered in the review and if they want to
2 implement, then they need to have it reviewed by the
3 staff because it could have some negative impacts.
4 And I guess I didn't get that from our earlier
5 discussion or my review of the Chapter 19 --

6 (Simultaneous speaking.)

7 MR. OH: And also it's clearly described
8 in the DCD and also in the PRA as in-vessel. Ex-
9 vessel is not included in -- for PRA or de rigueur.
10 It is also -- we just did the sensitivity study when
11 it -- it is taken into account for the PRA how much
12 the risk gain can be achieved or not. We just show
13 them to -- but we didn't take into account for the
14 system for credit, give the credit to our PRA model.

15 MEMBER REMPE: Okay.

16 MEMBER STETKAR: By the way, just for the
17 record, for the other Committee members, this
18 discussion has perhaps given people the implication
19 that this is some separate system. It's a pipe with
20 two valves in it that provides a water flow path from
21 one train of the combined safety injection and
22 shutdown cooling system return line into the reactor
23 coolant system. Or you can align that line also to
24 the boric acid makeup pumps, I believe. So it's not
25 a separate stand alone system. It's a pipe with two

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 valves in it. It's a flow path.

2 MEMBER REMPE: So --

3 MR. WAGAGE: This is Hanry Wagage from the
4 staff. We have not reviewed the system because the
5 applicant did not take credit for the system. In the
6 PRA applicant did not take credit, but when we were
7 reviewing steam explosion ex-vessel, we asked the
8 question what would happen if the system failed and
9 much larger melt pours in -- much larger diameter melt
10 pours in the cavity and cavity would have much higher
11 water level than steam explosion loading will be
12 higher.

13 Then applicant proposed COLA item. That
14 is -- for the COL applicant is to evaluate the
15 effectiveness of ex-vessel cooling system. We have
16 not reviewed this system so far because applicant need
17 not take credit. However, there is an open item. We
18 have an open item under that we are discussing with
19 the applicant. It's not close yet.

20 MEMBER REMPE: So this fuzzy line of where
21 the -- of what will be done will be clearly documented
22 and what the staff finally produces to say we've not
23 considered the adverse effects. If they want -- if an
24 applicant does come in and says I'm going to try and
25 invoke this, that brings in a bunch of analysis about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 steam explosions and possible adverse effects, the
2 robustness of the insulation that would -- or the
3 system that would have to allow water to come in,
4 etcetera, near the vessel.

5 MR. WAGAGE: Right now that's the
6 position. We have not reviewed. And that's what
7 applicant is proposing, a COL information item. But
8 that's still under review.

9 MEMBER REMPE: Okay.

10 MR. PHAN: Good morning. My name is Hanh
11 Phan, the senior lead, PRA and severe accident
12 reviewers. Yesterday the reviewers and the senior
13 management, we had a meetings to discuss and come up
14 with the possible resolution to address this issue.
15 We decide that we will ask the applicant to send us
16 their analysis, any assessment they performed to
17 certify that the operation of the system would not
18 impact the containment or any consequences to the
19 plant. We will have another discussion with the
20 applicant and we would ask them to send us their
21 assessments. And the staff will reviews that.

22 MEMBER REMPE: Okay. Thank you.

23 MR. Y. KIM: So we are 25. So we are
24 moving to 19.3 for the beyond-design-basis external
25 event. APR1400 FLEX strategy was developed -- ELPA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 concurrent with loss of ultimate heat sink in
2 accordance with EA 12-049 and 12-051 and NEI 12-06.

3 In order to implement the FLEX strategy,
4 APR1400 design has various FLEX equipment such as
5 three secondary pumps for cooling, two high-head pumps
6 for reactor coolant system makeup, one pump for spent
7 fuel pool makeup and another one pump for spent fuel
8 pool spray. Also we have two FLEX pump for emergency
9 core secondary bypass system, ECSBS, and two 480-volt
10 portable GTG to restore one of the Class 1 E bus.

11 On-site resource include large amount of
12 cooling water and a fuel oil source that will be used
13 for 14 days and 30 days, respectively.

14 For the off-site resource we assume 4.16
15 kilovolt portable AC power and indefinite amount of
16 cooling water and the fuel oil resource available.

17 MEMBER STETKAR: Mr. Kim, before we leave
18 this slide, there's -- I want a couple clarifications.
19 The second sub-bullet under FLEX says two primary low-
20 head pumps. That's different from Rev 0 of the DCD,
21 isn't it? Rev 0 of the DCD only said one primary low-
22 head pump. I believe that's correct --

23 MR. Y. KIM: Yes, and let me just --
24 (Simultaneous speaking.)

25 MEMBER STETKAR: -- from my notes. I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 just trying to find out where there's a change from
2 what we saw previously in Rev. 0 of the DCD.

3 MR. OH: Yes, and this is Andy Oh, KHNP
4 Washington office. And NEI 12-06 required n plus one
5 requirement. That's for the -- in actual the strategy
6 we used one, however, we prepare n plus one so that's
7 -- two is the correct number.

8 MEMBER STETKAR: Two is the correct
9 number? And also that's -- the same is true for the
10 ECSBS pumps?

11 MR. OH: Yes, and per the previous ECSBS
12 we prepared one.

13 MEMBER STETKAR: Yes.

14 MR. OH: And during a conversation with
15 NRC after ACRS we corrected it to that.

16 MEMBER STETKAR: Yes, I just wanted --
17 okay. So I wanted clarification, because in my notes
18 from Rev 1 of -- Section 19.3.1 only listed one
19 primary low-head pump and one ECSBS pump. So that you
20 are now committing to two of each of those?

21 MR. OH: Yes.

22 MEMBER STETKAR: Thank you. And this by
23 the way is why I said ECSBS is FLEX-y-type stuff,
24 because it is the -- of these pumps, the equipment on
25 this slide, the PRA does include credit for ECSBS;

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and, Greg, you'll have to correct me if I misspeak,
2 and only ECSBS from this inventory. Is that right?

3 MR. OH: Yes, this is Andy Oh, KHNP
4 Washington office. Originally ECSBS is not prepare
5 for the FLEX equipment. That's originated based on a
6 SECY-93-0178.

7 MEMBER STETKAR: Andy, I don't want to
8 split hairs in terms of the name of the stuff. The
9 pumps that are called ECSBS on this slide that has a
10 FLEX heading on it are included in the PRA, is that
11 correct?

12 MR. OH: Yes, correct.

13 MEMBER STETKAR: Okay.

14 MR. Y. KIM: Let's move next slide. Core
15 cooling strategies at power operation is divide into
16 three phases. In Phase 1 reactor coolant system hot
17 standby condition is maintained with no operator
18 action. Phase 2, reactor coolant system is a cool
19 down to around the shutdown cooling system entry
20 condition using installed or proxy. In Phase 3
21 reactor coolant system control state is maintained
22 with the same strategies in Phase 2 and but using off-
23 site resource.

24 For low mode operation with a steam
25 generator available the same power operation strategy

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is applied after waiting until reactor coolant system
2 heat up to hot standby condition.

3 For low mode operation with steam generate
4 not available during Phase 1 decay heat is removed by
5 reactor coolant system inventory boil-off. And in
6 Phase 2 feed and bleed operation is applied using low-
7 head FLEX pump. In Phase 3 the operator can resume
8 shutdown cooling system operation or continue the same
9 strategies as in Phase 2 using off-site water and fuel
10 oil source. The detailed procedure will be developed
11 by COL applicant.

12 MEMBER STETKAR: Mr. Kim, on this slide my
13 notes say you've listed -- for at-power the Phase 1
14 coping time is eight hours. For shutdown modes my
15 notes indicate that the Phase 1 coping time is three
16 hours. Is that correct?

17 MR. OH: This is Andy Oh, KHNP Washington
18 office. For the beyond-design-basis external even
19 strategy we -- initially we developed the low-power
20 shutdown strategy, however during the RAI process the
21 staff request to the applicant for the portion of low-
22 power shutdown strategy that should be into the COL
23 action totally. So --

24 MEMBER STETKAR: What? Okay. We'll talk
25 to the staff about that. Just for the record, Andy,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are you saying that the staff asked you to remove that
2 from the DCD?

3 MR. OH: No, and for -- removed this --
4 not the -- ask removed the DCD. That's NEI 12-06 in
5 Revision 3 based on that for document and for low-
6 power shutdown strategy can be deeper to the COL
7 applicant. There's several requirement based on that
8 revision because the --

9 (Simultaneous speaking.)

10 MEMBER STETKAR: We'll try to get
11 clarification from the staff on this. I'm really
12 confused because quite honestly; this is my personal
13 opinion, I was quite pleased to show -- to see in the
14 DCD that you had addressed strategies for shutdown
15 conditions explicitly, which most people have ignored.
16 So I was quite pleased.

17 And in fact the strategies show that there
18 are different time windows and different things to do
19 during shutdown. That's why I brought up this three-
20 hour versus eight-hour. It's the three-hour only for
21 the condition when you're at reduced inventory and the
22 steam generators are not available. That's a minor --
23 it's an important but it's a detailed nuance.

24 And now I'm hearing that that may be
25 removed because of some interaction with the staff.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So I'll be real curious to see how the staff addresses
2 this. Thank you.

3 MR. Y. KIM: Yes, for the maintain
4 containment function containment analysis results show
5 that containment is maintained well below design
6 pressure and EQ temperature limit for 16 days. In
7 addition, ECSBS is available to manage the containment
8 condition after reaching design pressure.

9 For the spent fuel pool cooling decay heat
10 is removed by spent fuel pool inventory boil-off
11 during Phase 1, but in Phase 2 and 3 the operator
12 needs to make up spent fuel pool inventory using FLEX
13 pump and the water it was from raw water -- raw water
14 tank. And two channels level instrument -- with the
15 two-channel level instrument the operator can monitor
16 the spent fuel pool water level in MCR during the
17 event.

18 Let's move to next slide. Next slide
19 about loss of large area. The APR1400 design was
20 buried in accordance with SRP 19.4 and NEI 06-12.
21 Those strategies in NEI 06-12 are considered to
22 maintain the spent fuel pool and the core cooling
23 capability. Phase 1 LOLA event evaluation focused on
24 the operational response to explosion or fire.
25 Prearranging for the environment of outside

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 organizations, planning and the preparation activity
2 and the developing procedure and the training for the
3 event will be addressed by the COL applicant.

4 For the Phase 2 LOLA event we have -- it
5 have -- we have to focus on mitigating on the event
6 involving the spent fuel pool. APR1400 design adopt
7 internal and external spent fuel pool makeup and the
8 spray strategies.

9 For Phase 3 LOLA event evaluation focused
10 on maintaining command and control, physical writer,
11 and alternative mitigation strategy is develop to
12 perform key safety functions.

13 MEMBER STETKAR: Now during the
14 Subcommittee meeting we had some discussions about
15 I'll call it coordination of the information in
16 Chapter 19.3 and Chapter 19.4. We noted some
17 discrepancies in for example different capacities,
18 flow capacities that were listed for the same
19 functional pumps in those two sections. And it was
20 noted at that time that while 19.3 addresses guidance
21 in one NEI document and 19.4 addresses guidance in a
22 different NEI document, we have not yet reviewed
23 Revision 1 of the DCD.

24 Have you done anything to resolve those
25 discrepancies? I'm doing -- for example, I'm looking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at 1,000 gpm flow capacity required for a certain pump
2 versus I think it was 750 gpm. And different pump
3 names and different inventories of pumps. Have you
4 done anything to integrate that, because the -- I'll
5 ask staff about this when they come up -- the pending
6 regulations in 10 CFR; I always get it wrong, 50.155,
7 I think it is, the mitigation strategies, indicates
8 applicants and licensees should be integrating all of
9 these strategies, not having the kind of diverse
10 separate approach to life. So can you comment on that
11 at all? And no is a possible answer.

12 MR. SISK: This is Rob Sisk, Westinghouse.
13 I think the best we can say at this point is we're
14 taking a lot of notes on what we are hearing over the
15 ACRS Subcommittee meetings and the Full Committee
16 meetings.

17 MEMBER STETKAR: Okay.

18 MR. SISK: We are -- as you've noted,
19 we've issued Rev 1 of the DCD.

20 MEMBER STETKAR: Yes.

21 MR. SISK: There will be additional
22 revisions as we close out confirmatory items and
23 looking at things like consistency of language and
24 such.

25 MEMBER STETKAR: Okay.

1 MR. SISK: So we hear it and we consider
2 it as we go forward with the next revisions of the
3 DCD.

4 MEMBER STETKAR: I personally would hope;
5 and again I'll ask the staff about this because
6 they're reviewing it, that by the time the final DCD
7 is issued that there is more of a sense of and
8 integration between 19.3 and 19.4.

9 MR. SISK: And we've captured that and
10 we'll be looking into that.

11 MR. Y. KIM: Yes, the final section is
12 about the aircraft impact assessment. Aircraft impact
13 assessment of APR1400 was performed in accordance with
14 Reg Guide 1.217 and NEI 07-13. The integrity of the
15 containment and the spent fuel pool is maintained for
16 all strikes to meet the AIA requirement. The heat
17 removal assessments demonstrate that at least one
18 division of core cooling is available for all strikes.

19 Regarding the key design enhancement, we
20 have reinforcement and local strengthening measures
21 are taken to protect critical hallways and penetration
22 into containment. Physical separation of MCR and the
23 remote shutdown room and on-site power resource such
24 as EDJ and AEACEs are adopted in our design.

25 To prevent the fire and the shock damage

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 due to aircraft impact, three hour late fire failure
2 and the high PSI barrier are incorporate in our
3 APR1400 design.

4 Let's move to next slide. Regarding the
5 assessment result, first one is core cooling
6 capability. Reactor cooling boundaries are not
7 perforate and protect all internal safety system. And
8 the integrity of a polar crane is maintained. And
9 critical hallways and the containment penetration are
10 physically protected. And the safety system in at
11 least one quadrant will remain functional for all
12 strike scenarios.

13 With respect to integrity of the spent
14 fuel pool, spent fuel pool is protected from direct
15 strike and the spent fuel pool wall and the support
16 structure will survive secondary impact if external
17 walls are perforate. And so spent fuel pool will
18 survive secondary missile from above if external wall
19 are perforated. And spent fuel pool will survive the
20 roof collapse if the external walls above spent fuel
21 pool are perforate.

22 So in conclusion, APR1400 meet 10 CFR Part
23 50.150. So we -- this AIA result shows that the cool
24 -- core cooling capability and the integrity of the
25 spent fuel pool. That is my end of presentation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Can I come back to those
2 FLEX strategies, because I took a -- it's slide
No. 3 27 --

4 MR. Y. KIM: Twenty-seven.

5 MEMBER STETKAR: -- where I asked about
6 the coping time for the low power. I just pulled up
7 that section of Revision 1 of the DCD. And indeed,
8 that information is still in there. The Phase 1
9 coping time is listed as three hours. And as we
10 become familiar -- in Section 19.3.2.3.1.3, for the
11 record -- so that it still is included in the DCD as
12 part of the strategy.

13 MR. Y. KIM: Yes, but we also provide the
14 separate technical document through the NRC. So there
15 was a -- could you help me?

16 MR. OH: Yes, for the -- when I checked
17 for 19.3 for the shutdown strategy for -- I corrected
18 my statement. I told that all the strategy is
19 eliminated, and that's not correct. It's for -- yes,
20 for some modification is done based on --

21 (Simultaneous speaking.)

22 MEMBER STETKAR: Yes, I -- so I see change
23 bars in the margin and I can't read very quickly and
24 speak and listen at the same time, but I did at least
25 confirm that Phase 1, 0 to 3 hours; Phase 2, 3 to 72

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 hours; and Phase 3, after 72 hours is still listed
2 explicitly in the DCD. As I mentioned, I personally
3 an happy to see that. And I'm glad to see that it was
4 not removed. Details of the changes we can review
5 when we see Rev 1 of the DCD. I just wanted to get
6 that on the record while we have you here to see if
7 you wanted to comment further.

8 MR. OH: Yes, there's some modification
9 has been done for that strategy according to the COL
10 action item.

11 MEMBER STETKAR: Okay. Thank you.

12 MEMBER BALLINGER: Finished?

13 MR. SISK: This is Rob Sisk, Westinghouse
14 again. And that does conclude our presentation on the
15 Chapters 6, 12, 13, 14, 16, 17 and 19 for today,
16 unless there are any other questions from the
17 Committee.

18 MEMBER BALLINGER: Mr. Chairman, I would
19 propose a --

20 CHAIRMAN BLEY: Yes, we will do a --

21 MEMBER BALLINGER: -- break until 10:15.

22 CHAIRMAN BLEY: We're in recess for 15
23 minutes until 10:17 by that clock.

24 (Whereupon, the above-entitled matter went
25 off the record at 10:01 a.m. and resumed at 10:17

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a.m.)

2 CHAIRMAN BLEY: Meeting will come back to
3 order, please.

4 Dr. Ballinger, back to you.

5 MEMBER BALLINGER: Is the staff ready to
6 roll? That's a local term.

7 (Laughter.)

8 MEMBER BALLINGER: Bill, it's up to you.

9 MR. WARD: Thank you. We have the staff
10 presentation now. It's going to be done by the
11 chapter project managers and myself, and we're going
12 to defer to the tech staff and the audience for the
13 tough questions. So that's why we have them all here.

14 So we're going to cover all the chapters.
15 We're going to cover them by project manager. And I
16 have a few early slides.

17 As you know we've completed all the SERs,
18 so we're through Phase 2 with open items. All the
19 SERs have been submitted to the Committee. We are in
20 the process of completing Phase 3. We have one more
21 Subcommittee meeting with Chapters 7 and 18 in a
22 couple weeks.

23 As I said, we've issued all the SERs.
24 We've had a Full Committee meeting for five of the
25 chapters: 2, 5, 8, 10 and 11, and we're now covering

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 essentially seven chapters. And we have more Full
2 Committee meetings scheduled in the future with 3, 4,
3 9 and 15, and then later 7 and 18.

4 We have issued SERs with no issues for the
5 -- three of the topical reports, and two more are
6 still in process. And I know one of the topical
7 reports is QAPD, which will come up later. Another
8 one KHNP has already issued the accepted version of
9 that. And they're working on a second one, so we're
10 making progress on topical reports as well. And those
11 are included in the future scheduling.

12 So the first presentation is on Chapter
13 13, which is conduct of operations. I will present
14 that. It has seven sub-sections. For the most part
15 Chapter 13 is the conduit for the applicant to pass on
16 how they expect operations -- operational programs,
17 etcetera, to be conducted and provide any information.
18 So 13.1 provides for the organizational structure of
19 the applicant and it requires that they develop the
20 management and organizational structure, including
21 design, construction, operating, and maintenance
22 responsibilities. This includes qualification
23 requirements such as education, training, and
24 experience. There were COL items in this section. We
25 reviewed the COL items. We had no issues or technical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 challenges in that section.

2 13.2 is specifically on training. Again,
3 it provides a number of COL items. There were no
4 technical challenges there. There was one issue where
5 the COL item made the wrong reference and we asked and
6 RAI and corrected that, so there were no major issues
7 on 13.2.

8 13.3 is emergency planning. There were no
9 technical challenges there. There's a lot more to
10 review in 13.3 in the Technical Support Center size
11 and location. Descriptions were acceptable. The
12 interfaces between emergency planning and various
13 other parts of the DCD were reviewed in accordance
14 with the SRP and it was determined that they were
15 acceptably discussed in the other sections of the DCD.

16 13.4 is the operational program
17 implementation. This is all pretty much COL
18 requirements. We have a SECY paper, an SRM that give
19 the guidance for the staff as to how to approach this.
20 So this was reviewed in accordance with that paper.
21 The COL item was found acceptable.

22 13.5 is plant procedures. Again, it
23 contains COL items. The applicant briefly described
24 admin and operating procedures for all operational
25 modes and is scheduled for preparing the procedures.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 This is also where the applicant, DCD applicant
2 provides Emergency Operating Guidelines.

3 We reviewed the COL items. We found that
4 they were adequate and acceptable. Some of those are
5 -- were being edited. There was some question about
6 some wording. So we're waiting to confirm the
7 confirmatory actions on those.

8 The Emergency Operating Guideline were
9 found to be technically adequate and acceptable for
10 the COL to use as a basis for procedure development.
11 And we also reviewed a technical report, "Best
12 Estimate Analyses for Operational Transients and
13 Accidents for APR1400 EOGs," and found that it was
14 acceptable. And as KHNP discussed earlier, 13.6 is
15 physical security and 13.7 is fitness for duty, and
16 those were not presented to ACRS, but they've been
17 reviewed.

18 In summary, all the regulatory
19 requirements for Chapter 13 have been satisfied.

20 And if there are any questions, I'll
21 attempt to answer them for you.

22 (No audible response.)

23 MR. WARD: Okay. Next is Chapter 14 -- or
24 I'm sorry, 17. Seventeen is quality assurance and
25 reliability assurance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I'll be presenting that. Sections are
2 provided. There was a Quality Assurance program
3 description, QAPD, topical report submitted at the
4 very beginning of the project, actually in
5 preapplication. And that was reviewed and approved,
6 and it's up to I believe Revision 5 now. That report
7 provides the requirements for the QA sections, which
8 are 17.1, 2 and 3 and 17.5. That report and the
9 review of those sections shows that all the regulatory
10 requirements of Appendix B to Part 50 have been
11 satisfied. There are some COL items in Sections 17.2,
12 17.3 and 17.5, and those were found acceptable.

13 QA inspections have been performed. One
14 was performed a year ago; another one was completed
15 recently. And you'll have to look for the reports for
16 those as that's not really our realm to discuss.

17 Staff did review the D-RAP, Design
18 Reliability Assurance Program, ITAAC and compared the
19 list with PRA results. And that program was found to
20 be insufficient primarily because the applicant used
21 old guidance. And an RAI was issued and new guidance
22 was -- is being used for them to update their list.
23 And when that's completed we'll be able to complete
24 the review of that list.

25 MEMBER STETKAR: Bill, but that list will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 change after they change the PRA, or it could change
2 after they change the PRA again.

3 MR. WARD: That is correct.

4 MEMBER STETKAR: Okay.

5 MR. WARD: And there will be more
6 discussion in 19.

7 The maintenance rule section and the COL
8 item were reviewed and found to be acceptable.

9 That's all we have on Chapter 17. Any
10 questions on 17?

11 (No audible response.)

12 MR. WARD: Okay. Chapter 6.

13 MS. UMANA: Good morning. I'm Jessica
14 Umana. I'm the project manager for Chapter 6, which
15 is engineered safety features. The staff's areas of
16 review for Chapter 6 covered materials for engineered
17 safety features, containment systems, the safety
18 injection system, habitability systems, fission
19 product removal and control systems, in-service
20 inspections of Class 2 and 3 components, and in-
21 containment -- I believe that should be in-containment
22 refueling water storage system.

23 Most of the regulatory requirements for
24 Chapter 6 have been satisfied.

25 We do have a few remaining issues which

1 I've listed there and I'm going to briefly provide you
2 some information on the items that are listed there.

3 To start with, the staff is working and
4 communicating frequently with the applicant to develop
5 a path forward and bring closure to these items.

6 In the Subcommittee there was a question
7 about the swing panels. The staff has issued an RAI
8 requesting the applicant to provide information
9 describing whether or not the IRWST swing panels are
10 required to function properly and need to be included
11 in the tech specs in order to ensure continued
12 operability of the ECCS.

13 Moving on combustible gas control in
14 containment, which is Section 6.25 in the DCD. There
15 was a question that Dr. Rempe had from the
16 Subcommittee, and I believe the question is what is
17 the basis for the staff's satisfaction with MELCOR
18 containment nodalization.

19 The staff provided a response to Dr. Rempe
20 on May 8th. Containment modeling is addressed in many
21 -- contained in MELCOR reports where various
22 nodalization schemes have been shown to produce
23 results consistent with large experimental programs
24 such as NUPEC, HDR, and CVTR. These nodalization
25 schemes appropriately reflected both the openness and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 complexity of the internal geometry of the specific
2 containments.

3 APR1400 has a large dry open containment.
4 The APR1400 nodalization both in the applicant's MAA
5 4 and the staff's MELCOR model reflects openness of
6 the containment design as well as the locations and
7 elevations of the PARs and hydrogen igniters.

8 In summary, because the nodalization
9 scheme used to evaluate the mixing of containment for
10 APR1400 is sufficiently similar to the nodalization
11 for similar containment designs previously approved.
12 The staff's confirmatory calculation included more
13 nodes in the upper containment dome region than the
14 applicant's, and both the applicant and the staff's
15 results were within reasonable agreement with the
16 APR1400 results. The staff concluded that further
17 sensitivity was not necessary.

18 Moving onto boron recycling. The staff is
19 engaged with -- in discussions with the applicant.
20 The applicant will provide a discussion addressing how
21 the APR1400 design will control boron-10 concentration
22 in the IRWST, the safety injection tanks and the spent
23 fuel pool since APR1400 has the capability of
24 recycling boron. Currently the applicant has proposed
25 adding a tech spec or surveillance requirement for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 boron-10 control, however, we're still in the draft
2 stages and don't have much more information to provide
3 on that front.

4 For the remaining issues the -- I'm sorry,
5 the last issue, which is containment structure and
6 mass and energy release, which I believe is Section
7 6.211 and 6.213 and 6.214 in the DCD, nothing has
8 changed since the Subcommittee. We are also engaged
9 in back and forth exchange with the applicant to bring
10 resolution to the open items for those sections.

11 And that's it for Chapter 6.

12 MEMBER POWERS: In the applicant's
13 presentation he assures us that in the post-accident
14 environment the IRWST water will remain at pH 7 or
15 higher throughout a 30-day period. Were you able to
16 confirm that conclusion, and how did you go about
17 doing that?

18 MS. UMANA: This is for the swing panels.
19 I believe you had the question on the swing panels
20 last time or --

21 VICE CHAIR CORRADINI: I'm the swing panel
22 person. He's the pH person.

23 MS. UMANA: Okay.

24 (Laughter.)

25 VICE CHAIR CORRADINI: Sorry.

1 MEMBER POWERS: The swinger and the
2 stable --

3 (Laughter.)

4 MEMBER POWERS: -- sane individual.

5 MEMBER STETKAR: The old acidic guy.

6 MS. UMANA: The -- I don't think I have --
7 I know who this question is for and I don't think he's
8 here. Andrew Yeshnik's not in the crowd, is he? Or
9 was it Greg Makar? No. I'll have to take your
10 question back and provide you --

11 MEMBER POWERS: Yes, that's fine.

12 MS. UMANA: -- a response at a later date.

13 MEMBER POWERS: That's fine. I mean, just
14 point me in the right direction.

15 MS. UMANA: Okay.

16 MEMBER POWERS: Thank you a lot.

17 MS. UMANA: I didn't anticipate that
18 question. How's that?

19 (Laughter.)

20 MEMBER POWERS: Well, similarly in this;
21 I'm in Chapter 6, and kind of in Chapter 2 they look
22 at the dispersion of radioactivity toward the main
23 control room. How did you look at that?

24 (No audible response.)

25 MEMBER POWERS: It's a complex analysis

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 which I suspect one has to do fairly simply because I
2 don't think you can do it phenomenologically correct.

3 MR. WARD: You're asking about the
4 dispersion of radioactivity in the main control room?

5 MEMBER POWERS: Yes, around the intakes
6 and things like that.

7 MR. WARD: In any particular condition, or
8 just --

9 MEMBER POWERS: Post-accident.

10 MR. WARD: Oh, post-accident?

11 MEMBER POWERS: Yes.

12 MR. STECKEL: This is Jim Steckel. We do
13 have a discussion of that in Chapter 15 with regard to
14 the opening and closing of the vents. And we did have
15 several questions to iron out with KHNP.

16 MEMBER STETKAR: Jessica, in -- I was just
17 reviewing my notes from the Subcommittee meeting and
18 we had some discussions about whether or not the
19 applicant includes credit for what's euphemistically
20 known as containment accident pressure. I just pulled
21 up Rev 1 of Chapter 6 of the DCD and I note that they
22 do consistently with currently operating plants --
23 that they account for pressure equivalent to the
24 saturation pressure for the temperature of the IRWST
25 water. So for example, if the IRWST is at 110 degrees

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 C, they'll account for that amount of overpressure in
2 the containment to maintain net positive suction head
3 for the pumps. Has the staff reviewed any of that,
4 those analyses?

5 MS. UMANA: I do not know.

6 MEMBER STETKAR: Okay.

7 MS. UMANA: And again, I --

8 MEMBER STETKAR: There was some -- my
9 notes during the Subcommittee meeting, there was --

10 MS. UMANA: I recall the discussion,
11 but --

12 MEMBER STETKAR: -- some discussion about
13 whether or not the pumps would survive if the
14 containment were open to the environment. And there
15 seemed to be some people saying yes they would. Other
16 people -- but Rev 1 of the DCD seems to clearly
17 indicate -- it says for higher IRWST sump fluid
18 temperatures the containment pressure is assumed to
19 equal the saturation pressure corresponding to the
20 sump water temperature.

21 MS. UMANA: I think we may have an answer
22 for you, right?

23 MR. TRAVIS: So this Boyce Travis, the NRC
24 staff. The treatment we discussed in the Subcommittee
25 meeting is consistent with the description in Rev 1 of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the DCD. Those are just RAI responses to update. The
2 analyses do assume that the pressure credit for NPSH
3 assumed in the vapor pressure cancels out with the
4 saturation pressure of the fluid, as you stated.

5 In the event that -- so beyond the design-
6 basis, an event that -- a loss of containment pressure
7 would result in flashing of the steam and the -- if
8 you look at our table, the margin they have available
9 in the post-accident condition versus the condition
10 that you're describing, that Dr. Corradini has the
11 slide available that I presented at the Subcommittee
12 meeting, they -- we didn't review that case
13 specifically because that's outside the design-basis
14 of the plant.

15 I'll state that based on the information
16 they provided the expectation is the same amount of
17 margin would be available in the case with atmospheric
18 containment pressure. If you open it instantaneously
19 versus the case -- the post-accident case where
20 they're crediting the vapor pressure up to the
21 saturation temperature of the fluid in the IRWST.

22 MEMBER STETKAR: Well, it can't be the
23 same margin available. The question is is adequate
24 margin available?

25 MR. TRAVIS: So once the sump temperature

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reaches 212, based on how their analyses are credited,
2 the same margin is available from that point on
3 because they're crediting only the saturation pressure
4 associated with the temperature of the IRWST fluid.
5 They don't credit additional pressure in containment
6 beyond the saturation temperature of the fluid.

7 MEMBER STETKAR: Beyond the pressure for
8 the saturation temperature?

9 MR. TRAVIS: That's correct.

10 MEMBER STETKAR: So if the fluid was at
11 250 degrees Fahrenheit, the saturation pressure is --
12 I don't know what it is. Thermal-hydraulic people can
13 tell me what it is.

14 MR. TRAVIS: Call it 35 psi, something
15 like that.

16 MEMBER STETKAR: Yes. They account for
17 that?

18 MR. TRAVIS: That's correct.

19 MEMBER STETKAR: Okay.

20 MR. TRAVIS: But no higher than that.

21 MEMBER STETKAR: But no higher than that.
22 Right. I'm not arguing about no higher than that. On
23 the other hand, if I make 35 psi -- I don't know
24 whether you want to talk atmosphere or gauge, because
25 I don't remember -- if I make it 0 psi gauge, that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will reduce their margin if the temperature is 250
2 degrees Fahrenheit.

3 MEMBER MARCH-LEUBA: But in that case;
4 just to help you, in that case you can not maintain
5 250 --

6 MEMBER STETKAR: Correct.

7 MEMBER MARCH-LEUBA: -- because you will
8 flash and cool off the --

9 (Simultaneous speaking.)

10 MEMBER STETKAR: That's right, but you'll
11 flash first at the eye of the pump and it will
12 cavitate.

13 MEMBER MARCH-LEUBA: It's a complicated
14 calculation.

15 MEMBER STETKAR: It is a complicated
16 calculation. That's why pump manufacturers don't like
17 you to be in that -- I'm just trying to make sure that
18 I understand what is in the DCD, and I think I do now.

19 MR. TRAVIS: Okay.

20 MEMBER STETKAR: Thanks.

21 MR. TRAVIS: Do you require any further
22 clarification? Should I stay up here I guess is the
23 question I'm asking.

24 VICE CHAIR CORRADINI: Well, since you
25 brought up your presentation, remind me, since I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 remember you explained it; now I can't remember, I
2 didn't write notes myself, the duration is actually
3 fairly short with holdup. So remind me what with
4 holdup means again?

5 MR. TRAVIS: So that analysis is not
6 specific to the APR1400. That --

7 VICE CHAIR CORRADINI: I understand that.

8 MR. TRAVIS: Okay.

9 VICE CHAIR CORRADINI: It was -- but you
10 wanted to explain to us --

11 MR. TRAVIS: Sure. So the analyses in the
12 DCD do not account for holdup of water in other
13 locations. It's a single containment node, so all of
14 the hot water goes instantly to the sump. In reality
15 some of that hot water is going to be held up in for
16 instance the holdup volume tank, various dead end
17 compartments in the steam generator rooms. And so
18 that hot water is going to act to reduce the sump
19 temperature and therefore shorten the duration that
20 the sump is above 212 degrees Fahrenheit.

21 VICE CHAIR CORRADINI: Thank you.

22 MR. TRAVIS: No problem.

23 MEMBER REMPE: So are you -- do you have
24 another comment?

25 MR. TRAVIS: No problem.

1 MEMBER REMPE: Okay. No, I was talking to
2 Mike Corradini. His hand was up and I thought he
3 wanted to talk more. But it's gone now.

4 I wanted to thank you for your response
5 back on the hydrogen nodalization.

6 MS. UMANA: Okay.

7 MEMBER REMPE: And I appreciate it and I
8 don't need any further clarification, but I would like
9 to mention that there is an ongoing effort to get --
10 I may be saying it incorrectly, but the HYMERES
11 facility where they're getting CFD quality
12 experimental data to reevaluate this issue if the
13 nodalization is correct. And I believe research has
14 started in an effort with Caltech to try and evaluate
15 that. So might want to think about it in the future,
16 but I don't know the timing. And so again, I think
17 it's fine for what we're doing today. We don't have
18 additional knowledge yet, but there might be in the
19 future.

20 MS. UMANA: You said HYMERES?

21 MEMBER REMPE: It's H-Y-M-E-R-E-S. I may
22 be mispronouncing it. Do you know how to pronounce it
23 better?

24 MS. GRADY: This is Anne-Marie Grady and
25 I'm the staff that provided the response. And thank

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you for that reference to HYMERES.

2 MEMBER REMPE: Okay. Thank you.

3 MS. GRADY: And I will look into that.

4 MEMBER REMPE: Okay. Thanks.

5 MR. WARD: Any other questions on Chapter 6 6?

7 MS. UMANA: I'm sorry, do you want to go
8 back to Chapter 6 and attempt to address --

9 MR. McCOPPIN: I think you asked the
10 question -- this is Mike McCoppin -- the question
11 about the dispersion in the main control room.
12 Michelle Hart's here, and she might be able to address
13 that question.

14 (Pause.)

15 MS. HART: I just got here.

16 MR. McCOPPIN: Yes, Michelle just got
17 here. She'd like the question repeated, if she could.

18 MEMBER POWERS: Oh, okay. Michelle, what
19 I'm interested in is how we calculate the dispersion
20 of radioactivity around the main control room in the
21 Technical Support Center.

22 MS. HART: Are you talking about within
23 the control room?

24 MEMBER POWERS: No, no.

25 MS. HART: To the control room?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: To them.

2 MS. HART: We used the RCON 96 computer
3 code, and it is based on hourly data for a year, much
4 like we do for the off-site analysis, but it does
5 include building wake effect. And if there's a lot of
6 heat behind it, it does include lofting. But this
7 plan there's not that --

8 MEMBER POWERS: Didn't find any --

9 MS. HART: And there's no effect from
10 being released from a stack either.

11 MEMBER POWERS: Oh, okay. As long as I've
12 got you here, in their assertion of pH 7 what kinds of
13 things did we look at to make sure that they
14 maintained a pH of 7 in the IRWST for 30 days?

15 MS. HART: Well, I do have to admit I did
16 not look at that analysis. That was somebody from the
17 Chemical Engineering Branch.

18 MEMBER POWERS: Oh, okay. Okay. Fine.

19 MS. UMANA: Any other questions related to
20 Chapter 6?

21 (No audible response.)

22 MR. WARD: Okay. We'll move onto to
23 Chapter 16.

24 MS. UMANA: I also have Chapter 16, which
25 is the generic tech specs. Yes, it's my favorite.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 That's quasi-true.

2 (Laughter.)

3 MS. UMANA: The tech specs are based on
4 combustion engineering standard tech specs, NUREG-
5 1432, Revision 40. The difference between the
6 combustion engineering tech specs and the generic tech
7 specs are based on design variations unique to
8 APR1400.

9 A review of the generic tech specs has
10 been conducted resulting the safety evaluation chapter
11 that includes open items in the following areas:
12 Adequacy of requirements during reduced RCS inventory,
13 requirements to prevent inadvertent reactor coolant
14 boron dilution, AFW required actions and completion
15 times appropriate to the APR1400 design, CRHS required
16 actions and surveillances, accident monitoring
17 instrumentation requirements, and application of LCO
18 criteria, TSTF disposition and COL action items.

19 Regarding the application of LCO selection
20 criteria, the applicant did not use a systemic process
21 of evaluating the safety analysis and SSCs against the
22 criteria, but relied on evaluating applicability of
23 combustion engineering standard tech spec's LCOs to
24 APR1400 SSCs in applying engineering judgment.

25 The staff requested the applicant to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consider additional measures to ensure the criteria is
2 satisfied; that is, that the tech specs include LCOs
3 for all SSCs, parameters and initial conditions that
4 satisfy their criteria.

5 The open items are being discussed. We
6 have continuous back and forth exchange with the
7 applicant in coordination with other branches for
8 closure to the open items related to Chapter 16.

9 One thing I did want to mention before
10 concluding this presentation for Chapter 16 -- I
11 wanted to talk about requirements for mitigating
12 shutdown risk. They have been included and go beyond
13 requirements in the standard tech specs.

14 In the Subcommittee presentation given in
15 March of this year there was a question about the role
16 of risk insights into the development of the tech
17 specs. It's correct to say that the tech specs are
18 not risk-informed and that significant risk-informed
19 initiatives have not been incorporated. However, LCO
20 3.0.8, which is based on TSTF Traveler 372 and relates
21 to inoperable snuffers and LCO 3.0.9, which is based
22 on TSTF Traveler 427 and relates to inoperable
23 barriers, require risk insights for adoption. These
24 risks are presented in the form of generic risk
25 evaluations which are included with the travelers.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The applicant provided an equivalent evaluation for
2 LCO 3.0.8 and is considering providing an
evaluation 3 for LCO 3.0.9.

4 And finally, pending resolution of the
5 open items verification of compliance with the
6 regulations is not yet quite complete.

7 MEMBER STETKAR: I would just --

8 MS. UMANA: Any questions?

9 MEMBER STETKAR: No.

10 MS. UMANA: I know you have questions.

11 MEMBER STETKAR: No, I don't actually. I
12 was just going to make a statement. That being said,
13 there's this -- for the benefit of the other Committee
14 members, there's this notion of are the tech specs
15 risk-informed? And they're not risk-informed
16 according to the process related connotation of risk-
17 informed.

18 However, as Jessica noted, the tech specs
19 do have specific LCOs in them in particular for
20 shutdown, which she mentioned, that evolved from
21 information that came out of the risk assessment. So
22 the applicant used the risk assessment and insights
23 from the risk assessment to establish conditions in
24 their tech specs despite the fact that they are not,
25 quote/unquote, "risk-informing" their completion times

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 or their surveillance intervals. I hope that's
2 accurate.

3 MS. UMANA: If there are no other
4 questions for Chapter 16, I'm going to turn it over to
5 the next presenter.

6 MR. WARD: The next chapter will be
7 Chapter 12.

8 MR. TESFAYE: Good morning. My name is
9 Getachew Tesfaye. I'm the project manager for
10 Chapters 12 and 14. I have a couple of staff member
11 here to support me if there are any questions.

12 Chapter 12, radiation protection. The
13 Subcommittee presentation was on February 24. We
14 looked -- the staff looked at various sections. The
15 first one is ensuring that occupational radiation is
16 ALARA. Section 12.2, radiation source. Section 12.3
17 and 12.4, radiation protection design features,
18 including dose assessments. And the last section is
19 Operational Radiation Protection Program.

20 For Section 12.1 and 12.5 all the
21 regulatory requirements have been met. There are no
22 open items. For Sections 12.2, 12.3 and 12. 4 and --
23 I repeated 12.5 here again, so I apologize for that.
24 The regulatory requirements for these sections have
25 been satisfied with the exception of five open items

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in Sections 12.2 and nine open items in Section 12.3
2 and 12.4.

3 So the staff has been working on these
4 open items. There are no show stoppers. We have to
5 complete our Phase 4 review of Chapter 12 soon and be
6 able to present the completed SER with no open items
7 in Phase 5.

8 That's all I have. Any questions for
9 Chapter 12?

10 (No audible response.)

11 MR. WARD: The next chapter is Chapter 14.

12 MR. TESFAYE: Chapter 14 is kind of
13 complicated. We've done 14.1 and 14.2 in Phase 2, and
14 we deferred 14.3, the ITAAC for Phases 4 and 5. In
15 Section 14.1 of course there's no open items. In
16 Section 4.2 staff looked at the four phases: pre-
17 operational testing, fuel loading and post-core hot
18 functional tests, initial criticality and low-power
19 physics tests, and power ascension tests. The number
20 of tests in each category may increase as a result of
21 response to open items.

22 Currently for Phase 2 we have 16 open
23 items in Section 14.2. And again, 14.3 is -- the
24 whole section is an open item that will be addressed
25 in Phase 4.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 That's all I have for Chapter 14. Any
2 questions?

3 MEMBER KIRCHNER: Yes. So the open items
4 included things like steam generator blowdown,
5 hydrogen mitigation, liquid and gaseous waste
6 management, etcetera. Is this because the COLA will
7 address those items, or why are they -- I'm just
8 curious. Why did they remain open at this phase?

9 MR. TESFAYE: Well, they're open because
10 the applicant needs to provide more information,
11 whether this is going to be a COLA item or the
12 laboratory test to this chapter. So it's pending the
13 applicant's response.

14 MR. WARD: Any other questions?

15 (No audible response.)

16 MR. WARD: Was that response satisfactory?

17 MEMBER KIRCHNER: Yes, thank you.

18 MR. WARD: Okay. All right. We'll move
19 onto Chapter 19. This is going to be 19, 19.3, 19.4
20 and 19.5. And it's Jim Steckel.

21 MR. STECKEL: Thank you.

22 CHAIRMAN BLEY: Why don't I sneak in the
23 question I asked the applicant earlier?

24 From what they told us this time around
25 when we get to the COLA stage they're saying the COLA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 PRA will need to do a seismic PRA and things
2 associated with local water conditions and events. Is
3 that your understanding as well? I mean, the past
4 other applicants have done kind of a surrogate for
5 those things and then only required at the COLA stage
6 that people show they're better than the surrogate.
7 We don't have that this time, so it sounds like
8 they're doing it what I would call the right way this
9 time.

10 MR. STECKEL: I'm going to -- this is Jim
11 Steckel. I'm going to defer to one of the reviewers.

12 Hanh, can you answer that?

13 MR. PHAN: Hello, Hanh Phan, the lead
14 reviewer for PRA.

15 So far the applicant provides us the PRA
16 page SMA. And according to the staff guidance that is
17 acceptable for the DC applicant. With that we would
18 not ask them to further perform any analysis or
19 address any CDF or error now at this point. However,
20 there is a clear COL information items asking the COL
21 applicant to perform a full-scale PRA, seismic PRA
22 when they have the site-specific information.

23 Knowing that, because during the DC phase
24 there are some information not available, so the risk
25 insights gained from any further assessment would not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 contribute much to the staff positions regarding their
2 application.

3 CHAIRMAN BLEY: I can't say that I
4 understood that answer. I don't. And it -- the whole
5 process doesn't seem consistent with what we've done
6 elsewhere. So the applicant said people doing the COL
7 will have to do a -- those site-specific analyses.
8 And it sounds like you said no they don't.

9 MR. PHAN: Yes. Yes, they will do.

10 CHAIRMAN BLEY: That's what you said?

11 MR. PHAN: It's the other applicants --

12 (Simultaneous speaking.)

13 CHAIRMAN BLEY: Okay. I misunderstood
14 what you said.

15 MEMBER STETKAR: Let me, because I'm
16 confused again. Let me ask you a very specific yes/no
17 question.

18 Will the COL applicant's submittal to the
19 NRC for the COL review contain a risk assessment that
20 includes quantification of the seismic risk? That's
21 a yes or no question.

22 MR. PHAN: No.

23 MEMBER STETKAR: Okay. That is not what
24 I understood from everyone else's discussion. When
25 will that risk assessment that quantifies the risk

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from seismic events be expected from someone who will
2 eventually operate one of these plants?

3 MR. PHAN: Before the 103 filing.

4 MEMBER STETKAR: Well, since --

5 PARTICIPANT: Before fuel load.

6 MEMBER STETKAR: Thank you for putting
7 that into English. Before fuel load?

8 MR. PHAN: Yes.

9 MEMBER STETKAR: Okay. Thank you. That's
10 on the record now from the staff.

11 MR. PHAN: May I be clear by saying a
12 little bit more? In the COL phase there are RCOL
13 applicants and SCOL applicants. For the R, the
14 reference COLs, they can -- under Part 52 they can
15 submit their application early using DC information.
16 By that, they can use the information in the DCD
17 Chapter 19 to justify the risk, but however they have
18 to do more by performing the PRA, seismic PRA to
19 identify the risk.

20 MEMBER STETKAR: I'm sorry, you said the
21 words "seismic PRA," so I will ask you a specific
22 question. Will they submit a risk assessment at the
23 COL? Since you want to differentiate between RCOL and
24 SCOL, will an RCOL applicant be expected to submit a
25 risk assessment that quantifies the risk from seismic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 events? Again, yes or no?

2 MR. PHAN: Not the quantification risk.

3 MEMBER STETKAR: Thank you. That's what
4 I consider risk. Anything else is not a risk
5 assessment.

6 MR. PHAN: Thank you.

7 CHAIRMAN BLEY: I'd offer two things, and
8 I hope the staff thinks about this long and hard: The
9 previous design certs included a section in Chapter 19
10 that essentially bracketed these environmental events
11 and showed they were I'll just say okay under those
12 specific conditions, which then a COL applicant had to
13 show that they met that list of conditions to avoid
14 doing -- including those in their COL PRA. That isn't
15 true this time, so I think you ought to think about
16 this a bit.

17 And secondly, there ought to be no
18 distinction between an RCOLA and SCOLA because every
19 site's different. Enough said for now.

20 MR. STECKEL: Is there another question?

21 (No audible response.)

22 MR. STECKEL: If not --

23 CHAIRMAN BLEY: From me? No.

24 MR. STECKEL: Okay. We'll move on.

25 Chapter 19 contains the four main sections

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 shown there. The probabilistic risk assessment and
2 severe accident sections take up 19.1, 19.2. 19.3 is
3 beyond-design-basis external events; 19.4, loss of
4 large areas; and 19.5, aircraft impact assessment.

5 Next slide, please? So concerning PRA the
6 areas of review are considering the scope, techniques,
7 level of details and technical adequacy: Internal
8 events Levels 1 and 2, at-power and during low power
9 and shutdown; internal fire Levels 1 and 2, at-power
10 and during low power and shutdown; internal floods
11 Levels 1 and 2, at power and during low power and
12 shutdown; PRA-based seismic margin assessment; and
13 other external events. And we also did key
14 assumptions and risk insights; PRA maintenance and
15 update; uses and applications of APR1400 design-
16 specific PRA.

17 Next slide, please? So the main focus
18 areas here are: The PRA model conversion from SAREX
19 to CAFTA, which is ongoing; PRA peer review findings
20 and resolution; digital I&C modeling; seismic
21 assessment during low power and shutdown; PRA update;
22 consistency between the DCD and supporting information
23 such as the PRA notebooks; sensitivity studies, risk
24 insights, update of PRA input to other DCD chapters
25 and programs; and RAI reconciliation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 If there are no questions on 19.1, we'll
2 move to 19.2, severe accident evaluation.

3 MEMBER STETKAR: The fifth bullet under
4 there says PRA update. What are you going to do about
5 that? I know you've done audits for the I'll call the
6 Rev 0, Rev 1 version of the PRA. Are you planning to
7 do additional audits after they change the models and
8 have evaluation?

9 MR. STECKEL: We -- this is an area of
10 discussion we're having right now, and an area where
11 we'll need to engage again with ACRS to determine
12 their agreeability to have additional review.

13 MEMBER STETKAR: Okay. So it's still a
14 work in progress?

15 MR. STECKEL: It's still a work in
16 progress --

17 MEMBER STETKAR: Thank you.

18 MR. STECKEL: -- at this point.

19 And, Hanh, did you need to mention
20 anything more?

21 MR. PHAN: Yes, I have further
22 clarification regarding APR1400 PRA models.

23 Right now the applicants, they do have
24 three models. The original model in the original
25 submittals using the SAREX software. During the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 review they told us that they convert their models
2 into another software, CAFTA. During that conversions
3 they incorporate the -- some of the staff findings,
4 some of the peer review findings and their self-
5 assessment, the type of methods in their original
6 models.

7 With that, last year they present to us
8 the quantification of the CAFTA models and they told
9 us that complete this, but we have not seen that model
10 yet. We only saw their presentation. Right now they
11 told us that they finished with that conversion and
12 they are working on the update.

13 The update means that they're going to
14 incorporate all the findings from the peer review,
15 from the staff RAIs and any comments from that ACRS.
16 That model would not be complete until September, so
17 staff will have another reviews of that latest PRA
18 model in the future, near future.

19 MEMBER BALLINGER: Now I'm confused again.
20 And that is I heard the words "further engagement with
21 the ACRS." And that is, at least the way I interpret
22 those words, inconsistent with what Bill has said.

23 MR. WARD: I'll answer that.

24 Yes, I was checking with staff in the
25 break and there is an interest in providing in a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 meeting of some sort some information prior to the
2 actual Phase 5 Subcommittee, Full Committee meetings.
3 Exactly what form that would take or what -- how much
4 would be provided or when -- well, what's provided is
5 going to depend on when, but there is an interest in
6 some sort of meeting to provide you some advance
7 information before we get to that point in Phase 5.

8 MEMBER BALLINGER: Okay. So that's a
9 change?

10 MR. WARD: It has recently been proposed
11 from staff, yes.

12 MEMBER STETKAR: Sounds like we're --
13 basically it's a work in progress at this snapshot in
14 time.

15 MR. WARD: I think the goal is to provide
16 you as much information as we can because we don't
17 want to have surprises. Nobody does. But it's really
18 hard to manage it with the schedule and the timing of
19 the information coming in.

20 MR. PHAN: Hello, this is Hanh Phan again.
21 Base on the comments from the ACRS the staff proposed
22 that upon ACRS approvals that in Phase 5 we're going
23 to have two presentations. One in the early of Phase
24 5 and one at the end of Phase 5. The early
25 presentation would be sent to the Subcommittees on PRA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 regarding the staff observation on their latest PRA
2 information. And then at the end of Phase 5 we will
3 come back and present to you the staff accept the
4 evaluation report without open items and including any
5 comments, any feedback from the Subcommittee, ACRS
6 Subcommittee on their PRA models. But that upon the
7 ACRS approval.

8 MEMBER BALLINGER: I guess this is
9 definitely a work in progress. So we'll have to deal
10 with that, not here.

11 MR. WARD: I agree.

12 MEMBER BALLINGER: Not today, anyway.

13 MR. WARD: I agree.

14 MEMBER SUNSERI: And, Bill, that proposal
15 that's been laid out, I presume that does not include
16 at this time engagement with KHNP or any of their PRA
17 folks. Is that correct?

18 MR. WARD: Not as I understand it.

19 MR. STECKEL: It could change. I think we
20 can move onto 19.2, severe accident evaluation. These
21 were the areas of review: accident prevention;
22 accident mitigation, MELCOR confirmatory analysis; and
23 containment performance capability.

24 An area that is still ongoing and is a
25 strong focus area is the MAAP analysis of mid-loop

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 accidents. There are -- there's calculations that
2 we're doing, confirmatory calculations. And we're
3 still working with KHNP to complete those. And the
4 structural analysis of ex-vessel steam explosion --

5 (Simultaneous speaking.)

6 VICE CHAIR CORRADINI: So, Jim, can you
7 explain the last bullet? I'm not sure what that
8 means.

9 MR. STECKEL: I am going to get an expert
10 so that I don't --

11 (Laughter.)

12 MR. STECKEL: -- misstate a thing.

13 So if the reviewer is available on this?
14 Hanry? Hanry Wagage.

15 MR. WAGAGE: My name is Hanry Wagage.
16 Applicant has presented results from --

17 MR. STECKEL: I think you need to get
18 closer, Hanry. Kiss that mic, so to speak.

19 (Laughter.)

20 MR. WAGAGE: Hi, this is Henry Wagage.
21 The applicant has presented results of structure
22 analyses performed for preference plant, similar
23 plant. So we have been reviewing these result. We
24 were -- we had some questions. For example, how the
25 applicant attenuated the pressure calculated from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 steam explosion, how they attenuated the pressure and
2 applied on the tops of walls. That's one example.

3 So we had questions like that that the
4 applicant has to address those questions. There's an
5 open item because of that, how the applicant performed
6 structurally.

7 VICE CHAIR CORRADINI: Okay. So it's --
8 the analysis is underway that you get to review?

9 MR. WAGAGE: That's right.

10 VICE CHAIR CORRADINI: Okay. All right.
11 Thank you.

12 MEMBER REMPE: So I'd like to also chime
13 in about some of this. The Subcommittee meeting we
14 learned about the document the staff had prepared with
15 the MELCOR confirmatory calculations. And so after
16 that we had the opportunity to review it and we
17 discussed some of those calculations with the staff.
18 This has been an accelerated schedule for review. At
19 the time the staff did those calculations, they had
20 some differences in their assumptions regarding the
21 plant. And maybe they didn't pick the sequence of
22 most interest.

23 We've heard today earlier that there may
24 be some differences in the risk assessment results.
25 We discussed about the fact that the consequential

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 steam generator tube rupture effects might be
2 different when one looks at the natural circulation
3 for a CE plant-specific configuration based on CFD for
4 a CFD -- a CE plant versus a Westinghouse plant that
5 was assumed.

6 It seems to me that the staff may want to
7 look at the results from the revised risk assessment.
8 They may even want to say I want to try and run a
9 different case for a confirmatory calculation. Those
10 kind of issues, are they still on the table or are we
11 going to at least -- if they don't run additional
12 analyses are we going to have some confidence that we
13 believe that the confirmatory MELCOR calculations that
14 were performed give us confidence about what may be
15 very important with respect to the risk assessment?

16 MR. STECKEL: Just let me mention before
17 Jason begins that this was a rather long RAI with many
18 questions associated with it. Not all of them were
19 specific. Many of them were we've noticed this in
20 this limited number of things we've looked at. These
21 things needs to be looked for in many other areas.
22 And so that is still an ongoing process, but we'll get
23 further clarification from Jason Schaperow.

24 MR. SCHAPEROW: Yes, this is Jason
25 Schaperow of the staff. With regard to the steam

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 generator tube rupture observation, as you mention,
2 Dr. Rempe, the latest NRC report on that shows the
3 likelihood of steam generator tube rupture for a CE
4 plant of roughly 0.25 given a core melt accident for
5 a CE plant, whereas for a Westinghouse plant it's
6 about a factor of 10 lower.

7 The MELCOR confirmatory calculations that
8 we're doing won't really shed any light on that
9 because the analysis that was done for steam generator
10 tube rupture is a combination of a materials
11 evaluation of the tubes and the MELCOR calculations.
12 And we're not going to be redoing that for this
13 particular plant specifically.

14 With regard to your question about the
15 tube rupture probability that was previously thought
16 to be based on NUREG-1570, the numbers in there -- if
17 I recollect correctly, were for Westinghouse-style
18 plants were on the order of 0.25. So my understanding
19 is that basically the numbers stay kind of the same
20 from back in 1998 to now for -- except for the
21 Westinghouse numbers got smaller. The original
22 analysis ones for Westinghouse --

23 MEMBER REMPE: It would be good to see
24 that --

25 (Simultaneous speaking.)

1 MR. SCHAPEROW -- 0.25.

2 MEMBER REMPE: I guess I'd like --

3 MR. SCHAPEROW: That's my understanding of
4 it.

5 MEMBER REMPE: -- that because again, I
6 thought the CFD analyses that were done for the
7 Westinghouse plant -- let's see that documented and
8 let me explore that more, because that would be good
9 to see.

10 But the other question is for the analyses where
11 you had different decay heats and things like that,
12 there may be some differences in geometry. Do you
13 feel like you'll have confidence in what they produce
14 finally?

15 MR. SCHAPEROW: So for the at-power
16 scenarios we believe we have reasonable agreement with
17 the MAAP results. For the shutdown scenarios, the
18 mid-loop calculation particularly, we've identified
19 some issues we think with their calculations. And
20 they're redoing those calculations now and they're
21 redoing the documentation. So we're waiting to see
22 what the new documentation says about their updated
23 MAAP calculations. And theoretically that would also
24 be reflected in our updated PRA.

25 MEMBER REMPE: And you don't think you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 need to do any sort of revised MELCOR analyses?

2 MR. SCHAPEROW: We are in a position that
3 we could do some more, but again I would wait to see
4 what they come up with before we start spending effort
5 to redoing any MELCOR calculations at this time.

6 MEMBER REMPE: So if you do that, if it --
7 you make that decision to do that, which again it may
8 not be necessary; no one wants to waste money, there
9 were some calculations done in a separate SORCA
10 evaluation for Korea. And so my understanding is
11 there might be a better model to start with for the
12 MELCOR calculations. Have you -- are you aware of
13 what I'm talking about --

14 MR. SCHAPEROW: I --

15 MEMBER REMPE: -- that there might be such
16 a model --

17 MR. SCHAPEROW: I have --

18 MEMBER REMPE: -- that would start with a
19 plant that might be --

20 MR. SCHAPEROW: Yes, I've heard of --

21 MEMBER REMPE: You might want to compare
22 those plant models, at least.

23 MR. SCHAPEROW: I'll need to check with
24 Research on that. I think they may know more about
25 that than I.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER REMPE: Okay. It might be good to
2 do that.

3 Then the last thing I'd like to talk about
4 is this thing about in-vessel retention and this
5 optional system, or option, and what's -- where -- how
6 much was the staff reviewing it? Because if you don't
7 take credit for that system, there's a heat transfer
8 coefficient from the vessel. What was assumed? I
9 mean, it seems like that you've got this system in
10 there and you said, well, okay, we didn't take credit
11 for it, so we're going to let the vessel fail. But
12 then in reality are there some unintended effects by
13 making that observation we're not going to evaluate
14 it?

15 MR. WAGAGE: Actually -- this is Harry
16 Wagage from the staff. The applicant did not take
17 credit for this system for steam explosions. They did
18 not take credit. Because of that there is no reason
19 for the staff to look at how good the heat transfer
20 coefficient, how well is going to cool.

21 Staff's concern was that it was different.
22 If the vessel is -- if the cavity is flooded covering
23 part of the vessel, if by using the system, if the
24 melt freezes and -- at the bottom and vessel is
25 failing at the site on the top by metallic layer, then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 much larger melt core would occur. That's the concern
2 staff had, not that how well the system worked,
3 because the applicant did not take credit for the
4 system.

5 VICE CHAIR CORRADINI: So, Hanry, since
6 you brought it up; it's your fault, I thought APR1000
7 went through all of this in -- back in -- 20 years
8 ago. So staff was okay with it then. What changed?
9 All of this in terms of the physics and the situation
10 geometrically are quite similar.

11 MR. WAGAGE: Thanks for the question.

12 VICE CHAIR CORRADINI: No problem.

13 MR. WAGAGE: APR1000 --

14 (Laughter.)

15 MR. WAGAGE: -- during the review of
16 APR1000 staff had the same concern. Then applicant
17 for APR1000 argued that kind of much larger melt core
18 would not occur.

19 VICE CHAIR CORRADINI: Right.

20 MR. WAGAGE: However, staff raised an
21 issue that there are so much uncertainty. Then the
22 applicant went ahead and did structural analyses to
23 show that with much larger melt core there will be
24 much larger energy generation by steam explosion.
25 However, only the cavity would fail. But the content

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 would stay intact.

2 VICE CHAIR CORRADINI: Okay. So your --

3 MR. WAGAGE: So that's how it is you close
4 for APR1000.

5 VICE CHAIR CORRADINI: So your point is
6 that analysis is yet to be done, but you don't need to
7 do it simply because applicant is not offering this as
8 the base design? This is -- we'll call it an optional
9 addition in the design?

10 MR. WAGAGE: That's right.

11 VICE CHAIR CORRADINI: Okay. Fine.

12 MEMBER REMPE: But before you went with
13 the APR1000 folks, you first of all had a bunch of
14 questions about how robust is this cavity cooling
15 system. Will it withstand the event? Basically you
16 made them reinforce it so that it could always have
17 water come in and the steam could be generated
18 externally. Those kind of calculations or evaluations
19 or will not be done if you say, okay, we're not going
20 to take credit for it. It doesn't matter.

21 Furthermore, someone has in their MAAAP
22 evaluation made certain assumptions about the heat
23 transfer from the vessel. Now you've got an isolated
24 volume. If you don't take credit for it, what did you
25 assume -- I mean, you have this insulation, so you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have a gap. And so you have less heat coming out of
2 the vessel than you would if you did not have that
3 system there. There is that system there that could
4 actually fall into the vessel, that could even make
5 the situation worse.

6 And so those kind of discussions are not
7 occurring because we're not taking credit for it. And
8 so maybe that's fine. You throw it off to the COL
9 applicant, but then somebody, if they ever want to
10 take credit for it, needs to realize that it's going
11 to be a lot more evaluations that have to be
12 performed. And that's what I'm trying to argue for
13 with all these questions today.

14 VICE CHAIR CORRADINI: They didn't want
15 air-conditioning so they're not going to evaluate air-
16 conditioning.

17 MEMBER REMPE: Yes. But then -- but there
18 are some adverse effects. And so, and that ought to
19 be documented in the staff draft SE or in the -- in
20 the whatever that we -- we're assuming this didn't
21 exist and they need to verify that the applicant truly
22 did assume it didn't exist and considered the fact
23 that there's something in there that they're not
24 evaluating, and they properly considered that. And
25 then say if you ever want to come in and take that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 option, you got to do a lot of analyses.

2 MR. WAGAGE: I agree, because the
3 applicant needs to take credit for this system. Staff
4 heard that applicant has to show how good the system
5 works. Right at this stage there is very little
6 information provided in the DCD. In one place it's
7 mentioned there are insulations around the vessel at
8 the bottom, that there is no -- not much information.
9 Just one sentence.

10 So how was -- staff didn't have any
11 concern about that, because there is no reason how
12 well the system works. But opposite if the system
13 does not work. If the system is operating and
14 unintended consequence happens, like larger melt core.
15 That's what the staff was focused on.

16 MEMBER REMPE: Yes, okay. So I think
17 we're communicating, and it's just another issue. If
18 we have another interaction before -- what was it
19 called, Rev 5 or whatever --

20 PARTICIPANT: Phase 5.

21 MEMBER REMPE: -- Phase 5 is occurring, it
22 would be something I'd like to see included in the
23 discussion.

24 MR. STECKEL: We'll take that under
25 consideration.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER REMPE: Thank you.

2 MR. STECKEL: We can move onto the next
3 slide. Beyond-design-basis external event. These
4 were the areas of our review: The external hazards;
5 core cooling; containment; spent fuel pool cooling;
6 ventilation; water and fuel supplies; FLEX equipment
7 and off-site resources; power supply; shutdown ops;
8 protection of equipment; mechanical equipment
9 capability; programmatic controls and procedures; and
10 COL information items.

11 To summarize in the next slide, we found
12 the applicant's approach consistent with applicable
13 guidance and to be acceptable and subject to the
14 verification of our confirmatory items and our DCD --
15 and the DCD and technical report modifications
16 specified in the RAI responses.

17 Questions?

18 (No audible response.)

19 MR. STECKEL: Moving onto 19.4, loss of
20 large areas. These are the areas of our review: DCD
21 enhancements addressing 50.54(hh) (2) for firefighting,
22 actions to minimize fuel damage, and actions to
23 minimize radiological release; and review for
24 conformance with NEI 06-12 and the guidelines in
25 Revision 3 including firefighting, measures to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mitigate damage to fuel in the spent fuel pool,
2 measures to mitigate damage to the fuel in the reactor
3 vessel, and to minimize radiological release. We had
4 -- I believe we had one RAI involved in this. It was
5 answered. There are no open items.

6 And the next slide shows a quick
7 discussion on mitigative strategy. Applicant
8 addressed each item in the mitigative strategy table
9 and identified those considered COL items and those
10 provided as design enhancements. And our conclusion
11 is with incorporation of the confirmatory items in the
12 next DCD revision staff will be able to conclude that
13 the LOLA DCD section includes the necessary
14 information to find that design enhancements conform
15 to the guidance in NEI 06-12.

16 MEMBER STETKAR: Jim, as I mentioned when
17 the applicant was up, when I read Section 19.3 and
18 Section 19.4 of the DCD and read the corresponding
19 sections of the staff's safety evaluation, they read
20 as if they are submittals for an apple and a review of
21 an apple and submittals for a tractor and review of a
22 tractor. I'm trying to emphasize the fact that these
23 are not integrated at all.

24 Your slides confirm that. You said you've
25 reviewed this against 10 CFR 50.54(hh)(2), which will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 disappear. It won't be existing anymore if indeed the
2 Commission approves 10 CFR 50.155. It's integrated
3 into the new rulemaking. There is any number of
4 different NEI reports that you can cite that have
5 different numbers and different revisions. There's
6 Interim Staff Guidance.

7 My basic question is how is the staff
8 going to resolve the intent of the proposed rulemaking
9 and its regulatory guidance and Revision 2? If you
10 want to get into Interim Staff Guidance, JLB-ISG-2012-
11 01, the intent of that for an applicant to integrate
12 their mitigating strategies. How are you going to
13 review that before we finally have an accepted DCD?
14 Because right now it doesn't do it in an integrated
15 manner.

16 MR. DIAS: Good morning. This is Antonio
17 Dias from NRO. I believe I can answer partial -- part
18 of your question.

19 It is true there are many, many guidances,
20 and everyone is aware that there's a rule that is
21 about to be issued. We just don't know when. So when
22 we were looking at the application, we just made sure
23 that the application made reference to the current
24 guidance at the time.

25 So when we received the Fukushima report

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from KHNP, the one that was at the time was the ISG
2 Rev 1 that references NEI Rev 2. That was issued in
3 January of 2016. There's a new revision to the ISG,
4 which is dated February 17. And that's already
5 addressing NEI, endorsing NEI Rev 4. I just opened --
6 I went up. There's a 4. NEI is very prolific with
7 their guidances. Okay?

8 So, yes. So it's very confusing. And I'm
9 going to say the question that you pose also is
10 applicable to even to some of the ones already issued.
11 And JLD is taking the role -- the group, the Special
12 Office JLD is taking the role of how to actually
13 perhaps convert some of the license requirements and
14 how that's going to be brought back into a rule once
15 the rule is issued.

16 But the problem with KHNP is that we
17 cannot wait and see exactly how the rule is going to
18 be issued and when, so we are basically moving forward
19 with guidance that currently existed. In the case of
20 KHNP, because the latest revision of the ISG came in
21 after the report, we are not going to ask them to go
22 back and address that revision to the NEI, or the
23 revision to the ISG. So it's kind of a little bit of
24 a who-goes-first situation.

25 But what you say, that there seems to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 discrepancies between 19.3 and 19.4, that's a very
2 good point, and I think we should take a look at this.

3 MEMBER STETKAR: I know you have a
4 dilemma. On the other hand, the applicant ostensibly
5 is one organization and the NRC is ostensibly one
6 organization. And if I look at things in a DCD that
7 have a functional capability and in one section of the
8 DCD where that functional capability is specified as
9 having -- I can't find it in my notes, so I'll make up
10 numbers -- 750 gpm. And in the next section of the
11 DCD the same functional pump is specified as having a
12 capacity of a 1,000 gpm, it strikes me as an anomaly.

13 And that in the sense of integrating these
14 mitigating strategies somebody ought to identify the
15 fact that that pump in the certified design ought to
16 have a specified capacity. I don't care whether it's
17 750 or 1,000. The capacity ought to be based on
18 functional requirements and whether that pump is used
19 for an administrative licensing requirement in Section
20 19.4 or whether it's used for the administrative
21 requirement in Section 19.3. We ought to have clarity
22 on what the pump is so that when the COL applicant
23 goes out to buy a pump, he doesn't have to buy two and
24 he doesn't have to figure out whether it ought to be
25 somewhere halfway between 750 and 1,000 gpm.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DIAS: Right. I understand.

2 MEMBER STETKAR: So I don't know where --
3 and that I thought was the intent of the rulemaking,
4 to integrate the mitigating strategies for all of
5 this.

6 MR. DIAS: You're correct.

7 MEMBER STETKAR: It's why 50.54(hh) (2) was
8 rolled into the new rule.

9 MR. DIAS: That's correct.

10 MEMBER STETKAR: So from that perspective,
11 from that technical functional perspective why isn't
12 the staff asking these questions about -- in 19.4 why
13 does the same pump have a different functional
14 capacity than in 19.3? It seems you could do that
15 without pointing to --

16 MR. DIAS: This is --

17 MEMBER STETKAR: -- specific guidance,
18 because the guidance doesn't necessarily tell you how
19 many gpm --

20 MR. DIAS: This is a little bit -- this is
21 -- the fact is that -- first, I can tell you 19.4 was
22 reviewed by the staff, by a separate staff member --

23 MEMBER STETKAR: I -- that's why --

24 MR. DIAS: -- way before 19.3. This is
25 not the correct answer.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: That's why I said
2 ostensibly.

3 MR. DIAS: This is not even an excuse.
4 It's the truth.

5 MEMBER STETKAR: Okay. I hope then --

6 MR. DIAS: We are going to look into this.

7 MEMBER STETKAR: -- before Phase 5 and the
8 final version of the DCD and the final version of the
9 SER we come to some sort of convergence here on these
10 two sections, because I think that they can be made
11 consistent, at least from a functional perspective,
12 despite the morass of regulatory guidance that we're
13 in right at the moment.

14 MR. DIAS: Okay.

15 MEMBER STETKAR: Okay. Thanks.

16 MR. DIAS: Thank you.

17 MEMBER STETKAR: And thanks for being
18 honest about the different reviewers.

19 MR. STECKEL: We're moving in that
20 direction. We're not quite there yet.

21 MEMBER STETKAR: I just wanted to get it
22 on the record because it is frustrating given the
23 intent of what the agency and the industry in the
24 United States have been trying to do since Fukushima
25 to try to integrate a lot of these bits and pieces

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that have evolved over the last almost 20 years now.

2 MR. STECKEL: Understood.

3 MR. WARD: Yes, we -- I'm taking notes.
4 We'll review the record after this to make sure we
5 include those in our Phase 5 meeting.

6 MR. STECKEL: Move onto 19.5, aircraft
7 impact assessment. These are examples of the key
8 design features: Reactor containment; building
9 design; design and location of spent fuel pool;
10 physical separation of Class 1E emergency diesel
11 generators and the alternate AC source; physical
12 separation and design of the emergency core cooling
13 and support systems; pressure-related and non-
14 pressure-related fire barriers.

15 And we've concluded Section 19.5 meets 10
16 CFR 50.150(b) due to these reasons: Adequate
17 description of key design features and functional
18 capabilities; adequate description of how the key
19 design features meet the assessment requirements; and
20 the applicant has developed a reasonable formulated
21 assessment and it was performed by qualified
22 individuals.

23 And as a final note the next page, just to
24 let everyone know that the AIA inspection for APR1400
25 is scheduled for next month. Any additional

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 questions?

2 MR. WARD: Okay. That completes our
3 presentation. I did want to bring up a couple of
4 questions that came up earlier, one a question about
5 main control room ventilation, dose considerations.
6 And I know Jim mentioned there was some discussion in
7 Chapter 15. I was just scanning the SER and there
8 appears to be an open item related to some questions
9 in that area. So we'll look into that some more, but
10 it may not be resolved it.

11 And I think we have somebody else here to
12 help answer the question on pH of seven.

13 MS. UMANA: That was Mr. Powers' question.

14 MR. MAKAR: This is Greg Makar from the
15 staff. I didn't hear the question.

16 (Laughter.)

17 MR. MAKAR: I'm sorry. I apologize.

18 MEMBER POWERS: The staff -- the applicant
19 has insisted that his IRWST will remain at a pH
20 greater than 7 throughout the 30-day period following
21 a design-basis accident. And I'm wondering how do we
22 know that?

23 MR. MAKAR: The reviewer in this case
24 looked at the applicant's calculation of the pH over
25 that 30-day period accounting for the change from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 acidification primarily from hydrochloric acid and
2 nitric acid generated by radiolysis of air and water
3 and cable insulation and jacketing. There's also a
4 base from cesium hydroxide, but the main contributors
5 to the pH change are the acids.

6 So looking at the total volume and the
7 acid that is generated, base generated and the
8 buffering capacity of the tech spec amount of
9 trisodium phosphate -- those are the main parts of
10 that calculation.

11 MEMBER POWERS: The questions are in the
12 details here. I mean, there are a couple of other
13 questions that are not so much detail, but where do I
14 see what G values they used for the radiolysis
15 components on this, how they handled HCL production
16 from the cable insulation and things like that?

17 MR. MAKAR: It's in -- there is a
18 calculation that was submitted. I think it's part of
19 the RAI response. And I think that identifies the G
20 values, which are taken from a NUREG/CR. I'm sorry I
21 don't remember the number of that report, but
22 that's --

23 (Simultaneous speaking.)

24 MEMBER POWERS: In other words, something
25 I have not seen? I guarantee you I haven't seen it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The other question that comes up is do
2 they account for carboxylic acid formation from any
3 organic contaminants? And we've certainly seen that
4 in the RTF tests done in Canada. We know that
5 happens. We know that by experiment and we know that
6 by theory.

7 MR. MAKAR: Probably not.

8 MEMBER POWERS: And do we account for
9 precipitation of phosphates due to contaminants coming
10 in to the IRWST? Any calcium, iron, zinc, something
11 like that.

12 MR. MAKAR: So a loss of phosphate that's
13 assumed to be present for the buffering?

14 MEMBER POWERS: Yes.

15 MR. MAKAR: I don't --

16 MEMBER POWERS: And if you drop it at a
17 solution then it's not buffering anything.

18 MR. MAKAR: Probably -- that's probably
19 not counted.

20 MEMBER POWERS: Well, it would still be
21 good to see the calculations.

22 MR. WARD: We'll look up those references
23 and provide those to Chris Brown to make sure --

24 (Simultaneous speaking.)

25 MEMBER POWERS: That would be terrific if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you could. I mean, I don't know that there's anything
2 wrong with it, but I'd sure like to see it. Because
3 for instance, just in the area of G values on Hypalon
4 I know of three measurements. They only differ by a
5 decade. And one of them is -- in fact has a
6 qualitatively different progression of HCL production.
7 Similar differences on nitric acid formation rates.

8 MR. WARD: Okay. We'll get you those
9 references.

10 Any other questions?

11 (No audible response.)

12 MR. WARD: Well, this concludes our
13 presentation for today. Thank you.

14 MEMBER BALLINGER: Well, thank you. I
15 think now it's appropriate to take public comments
16 since we're finished. And so, I would ask if there
17 are -- is anybody in the room that would like to make
18 a public comment?

19 (No audible response.)

20 MEMBER BALLINGER: And we're trying to get
21 the -- is it open? So are there -- is there -- are
22 there any people out on the line that would like to
23 make a public comment?

24 (No audible response.)

25 MEMBER BALLINGER: Hearing none, then we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 need to have -- ask if there's any other Committee
2 discussion.

3 (No audible response.)

4 MEMBER BALLINGER: That not being the
5 case, I turn it back over to the Chairman.

6 CHAIRMAN BLEY: Thank you. Before we
7 recess for lunch, you need some work on the letter
8 before we go through it?

9 MEMBER BALLINGER: We have the letter. We
10 have a draft letter. Based on some discussions that
11 we've had here, it would be a good idea to get another
12 crack at doing it, but we could do that either offline
13 or --

14 CHAIRMAN BLEY: I think that's probably a
15 good idea, so I don't think we'll read it at this
16 time.

17 Okay. We will recess until 1:00 when we
18 will take up the next item on the agenda.

19 (Whereupon, the above-entitled matter went
20 off the record at 11:35 a.m. and resumed at 1:00 p.m.)

21 CHAIRMAN BLEY: The meeting will come to
22 order. At this time, we're going to take up the issue
23 of Browns Ferry extended power uprate, and I will turn
24 the meeting over to Dr. Rempe.

25 MEMBER REMPE: Thank you, Mr. Chairman.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So on May 3rd, our Power Upgrades Subcommittee reviewed
2 the extended power upgrade license amendment request
3 for Browns Ferry Units 1, 2, and 3, and the associated
4 draft -- the NRC staff's draft safety evaluation
5 report. And at the end of the meeting, our
6 subcommittee recommended that this LAR be presented to
7 the Full Committee.

8 Several aspects of this EPU request are of
9 special interest. The three BWRs are Browns Ferry
10 have relatively high power levels. Each unit is a GE
11 BWR/4 housed within a Mark I containment. Previously,
12 Browns Ferry has been approved to use AREVA ATRIUM 10
13 and 10XM fuels, and in this request, the licensee,
14 Tennessee Valley Authority, has proposed to eliminate
15 the reliance on containment accident pressure. And
16 prior to implementation of the EPU, TVA will install
17 a new replacement steam dryer in each unit.

18 Today, we are going to hear from TVA, NRC
19 staff, and possibly some of their consultants. Part
20 of the presentations will be closed in order to
21 discuss information that is proprietary, and before I
22 start by turning this over to Kathryn Brock of the NRR
23 management, we need to have a special statement by our
24 member, Jose March-Leuba.

25 MEMBER MARCH-LEUBA: Yes. I just wanted

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to say that I am conflicted on this topic because I
2 helped the staff work on it before I came into the
3 ACRS, so I will restrain myself from doing any
4 deliberations.

5 MEMBER REMPE: Thank you. So Kathryn?

6 MS. BROCK: Thank you. Well, my name is
7 Kathryn Brock. I am the Deputy Director in the --
8 oops. My name is Kathryn Brock. I am the Deputy
9 Director in the Division of Operating Reactor
10 Licensing in the Office of Nuclear Reactor Regulation.

11 The objective of today's discussion is to
12 present the ACRS a request by the Tennessee Valley
13 Authority to perform extended power uprates at each of
14 the three units at the Browns Ferry Nuclear Plant. We
15 feel we had a successful subcommittee meeting, and we
16 appreciate the opportunity to brief the Full Committee
17 on this important licensing action.

18 Attendees today do include NRC staff and
19 contractors, TVA staff, and TVA contractors and
20 vendors, and for the first portion, members of the
21 public. We welcome all of you and thank you for
22 joining us.

23 Next slide, please. As was mentioned, all
24 three units at the Browns Ferry are General Electric
25 boiling water reactors of BWR/4 design with Mark I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 containments. Browns Ferry is located on the
2 Tennessee River in northern Alabama. Each unit has
3 received a renewed license with a license expiration
4 date in the 2030s.

5 The proposed EPU power level of 3952
6 megawatts thermal represents an increase of
7 approximately 14 percent above the current license
8 thermal power level, and approximately 20 percent
9 above the original license thermal power level. The
10 review of the EPU license amendment request has
11 involved over 25 technical staff from 14 different NRR
12 branches, so it's a big effort.

13 The NRR document RS-001 provides guidance
14 for performing reviews of EPU applications. TVA
15 followed the format and guidance delineated in RS-001
16 in the safety analysis reports contained in the EPU
17 application. The NRC staff review also followed this
18 guidance, as well as applicable regulations,
19 regulatory guides, and the Standard Review Plan. I
20 thank the staff and the contractors for their thorough
21 and timely review of this important amendment request.

22 After this extensive review, there are no
23 open items, so the NRC staff recommends approval of
24 TVA's extended power uprate amendment request. And to
25 give you the details of the staff review, I turn the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 presentation over to Farideh Saba, the NRC project
2 manager responsible for this review.

3 MS. SABA: Good afternoon. My name is
4 Farideh Saba. I am the Regulatory Licensing Project
5 Manager for Browns Ferry Nuclear Plant Units 1, 2, and
6 3 in the Office of Nuclear Reactor Regulation,
7 Division of Operator Reactor Licensing.

8 TVA submitted the proposed Browns Ferry
9 EPU in September of 2015. The NRC staff accepted the
10 application for detailed technical review in a -- a
11 letter dated January 11th, 2016. The NRC staff has
12 planned for completion of the review in July of 2017,
13 which supports TVA EPU implementation plans during the
14 refueling outages in spring of 2018 for Unit 3, in
15 fall of 2018 for Unit 1, and in the spring of 2019 for
16 Unit 2.

17 Next one? With respect to the agenda,
18 during the open sessions, TVA will provide an EPU
19 background presentation of the planned modifications
20 associated with the EPU, an overview on elimination of
21 credit for containment accident pressure (CAP), and an
22 overview of the steam dryer replacement RSD.
23 Following TVA's presentation, the NRC staff will
24 present staff's review and conclusions regarding fuel
25 and reactor system analysis, review of elimination of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CAP credit, and review of replacement steam dryer
2 analysis. The staff presentation will be closed to
3 the public due to proprietary nature of the
4 information that will be discussed.

5 If there are no further questions, I would
6 like to turn it over to Mr. Ed Schrull of --

7 MEMBER KIRCHNER: I have a --

8 MS. SABA: -- TVA.

9 MEMBER KIRCHNER: -- question, if I may?

10 MS. SABA: Sure, yes.

11 MEMBER KIRCHNER: I am just noticing that
12 your presentations -- TVA's will be open, but your
13 presentations will be closed. Is there some summary
14 of your evaluation that you can make it an open
15 session that the public can participate in? I believe
16 that -- I think it was Dr. Powers pointed out, I think
17 he used the word, you know, is this EPU prudent in
18 light of Fukushima? So it would seem to me that you
19 should present something about your SER in an open
20 session.

21 MS. SABA: I understand your point, and
22 actually, when we were planning, the reason we did it
23 like that, because some of the review done by the
24 staff is proprietary. So we planned it that way, that
25 any question that public can hear can be asked during

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 TVA presentation, and either TVA provide the response
2 or staff will help. Anything also that is asked
3 during TVA presentation that we see that as
4 proprietary, they can refer it back to the time that
5 we are doing the NRC members, they are doing it. This
6 way, we are separating proprietary information from
7 public information, because also, we have very short
8 period of time. It's not like -- it wasn't like
9 subcommittee.

10 MEMBER REMPE: Before -- again, I think I
11 would like to talk about your response to your
12 question, but let's let the member of the -- is -- did
13 you have a question, too?

14 MS. SABA: He is Ed Schrull. He is coming
15 after me.

16 MEMBER REMPE: Oh, okay. So I think you
17 have heard them say there are no open items, and they
18 are recommending that it move forward, and I think
19 that as you go -- I mean, you were there in the
20 subcommittee meeting, and so they -- yes. So I think
21 that that is sufficient, in my judgment, but if there
22 is something that you would like to -- that you
23 believe is open that should be said, why don't you
24 tell us, if there is something that you really wanted
25 to have said?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BLEY: Or you could revisit just
2 before we go into closed session.

3 MS. SABA: Right.

4 MEMBER REMPE: Okay?

5 MS. SABA: That is exactly what was
6 planned. Thank you very much for your question.
7 Thank you.

8 So I -- I would like to turn it over to
9 Mr. Ed Schrull of TVA for an overview of the EPU for
10 Browns Ferry.

11 MR. SCHRULL: Thank you, Farideh. My name
12 is Ed Schrull. I am the TVA Corporate Fleet Licensing
13 Manager. For major projects such as the Browns Ferry
14 Extended Power Uprate Program, TVA forms a dedicated
15 site team that exists for the duration of the project.
16 TVA corporate then performs an oversight function for
17 the project.

18 So I would like to introduce the members
19 of the Browns Ferry EPU leadership team that are
20 seated at the front table. Starting from our right to
21 left: on the right side there is Mr. Dan Green, who is
22 a Senior Licensing Manager of the EPU project; next to
23 Dan is Mr. Gerry Doyle, the Director of the EPU
24 project; and next to Gerry is Mr. Pete Donahue, the
25 Senior Engineering Manager of the EPU project. All

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 three of these gentlemen have been with the Browns
2 Ferry EPU project since its inception. Next to Pete
3 is Mr. Lang Hughes, the Browns Ferry General Manager
4 of Site Operations; and next to Lang is Mr. Steve
5 Bono, the Browns Ferry Site Vice President.

6 At this time, I will turn it over to Mr.
7 Gerry Doyle, the Director of Extended Power Uprate
8 Project.

9 MR. DOYLE: Thank you, Ed. I appreciate
10 that.

11 Thank you, and good afternoon, Mr.
12 Chairman, ACRS Committee members, Director Brock, and
13 the NRC staff, good morning -- or, sorry, excuse me,
14 good afternoon. My name is Gerry Doyle, and I am the
15 Director of the EPU project. I wanted to introduce
16 and provide the background of our team and to share
17 the project goals we established early on to work
18 effectively with the NRC staff.

19 As part of our preparation, we performed
20 extensive benchmarking of previous EPU's, including
21 Grand Gulf, Monticello, Nine Mile Point, and Peach
22 Bottom, including attending both Peach Bottom ACRS
23 committee meetings. Our EPU project team is comprised
24 of personnel having extensive boiling water reactor
25 plant experience and specific EPU experience.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Our team includes dedicated project and
2 plant TVA staff; major vendors, including GE-Hitachi
3 and AREVA; as well as experienced specialty
4 contractors. We were fortunate in that we were able
5 to take full advantage of a wealth of industry
6 operating experience and experienced, qualified, and
7 talented experts. We feel we have assembled the
8 industry's best and expect to demonstrate that today.
9 Next slide, please.

10 One of the first things we did was align
11 our project on high-level team goals, recognizing the
12 need to work closely with the NRC -- with our NRC
13 counterparts and demonstrate we were committed to
14 implementing an industry-best EPU, specifically, to
15 present the NRC, Nuclear Regulatory Commission, with
16 a high-quality license amendment request consistent
17 with RS-001 standards. To that end, we have worked
18 closely with Farideh and the technical reviewers to
19 ensure we were providing the necessary information
20 that they needed for their review in a timely manner:
21 to resolve containment accident pressurization issues,
22 which Pete Donahue will discuss further along in the
23 presentation; to install replacement steam dryers for
24 all three units, again, a separate discussion by Dan
25 Pappone of GE as part of this presentation; and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 finally, I wanted to ensure we provided a smooth
2 transition to EPU for plant operations, such as there
3 were no surprises or issues in running or maintaining
4 the plant. Those are our high-level team goals.

5 With that introduction, I would like to
6 turn it over to our Site Vice President, Mr. Steve
7 Bono.

8 MR. BONO: Good afternoon. I want to
9 thank the Committee for the opportunity to present our
10 EPU project today.

11 Much of my slide has been presented, so in
12 fairness to Committee time, I will just give a quick
13 summary. But all three units are BWR/4 GE models with
14 a Mark I containment. You can see our original
15 operating license dates, and you can see where we
16 renewed that license. So all three units today
17 currently operate under a period of extended
18 operation. We did implement a stretch uprate of 105
19 percent original licensed thermal power, and what we
20 are requesting today is a proposed 120 percent of the
21 original licensed thermal power limit.

22 And with that, I am going to turn it over
23 to our General Manager of Site Operations, who is
24 going to go through some of the design changes and
25 modifications that we implemented to implement the EPU

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 project.

2 MR. HUGHES: Okay. Good afternoon. My
3 name is Lang Hughes. I am the General Manager of Site
4 Operations at Browns Ferry. I will go through some of
5 the modifications, many of which have already been
6 completed across all three units to support the
7 extended power uprate.

8 As you can see on the slide that is
9 currently on the screen, many of the modifications
10 that we have with these circles that are colored in
11 have already been completed. Included in this are the
12 replacement of the original design pumps for the
13 condensate booster and the reactor feed pumps. We
14 have the -- the EPU pumps installed. The Unit 1 and
15 2 pumps have all been installed in operation since
16 2007, but we completed installation of the condensate
17 booster pumps and the reactor feed pumps on Unit 3 in
18 the spring outage of 2016.

19 Many of these major modifications our
20 operators have been trained on for some time. You
21 know, it is nothing new with regard to individual
22 component operation for them. This is something that,
23 you know, we feel strongly about is the operator
24 training piece, and having these pumps in service for
25 some time has been able to let us run through EPU

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 scenarios on the simulator with this installed
2 equipment and so forth to get our team ready for full
3 implementation.

4 Next slide, please. I won't go through
5 and talk about all the modifications. A couple of
6 them that I will mention, we will talk later about the
7 replacement stream dryer. As far as the mods, you can
8 see them listed on the slide there. Really, these are
9 all -- for the most part will be transparent to the
10 operators. Main generator hydrogen pressure, we will
11 operate at a higher pressure. One thing that we are
12 doing with this modification in addition to assist the
13 operators is automatic hydrogen pressure control, and
14 remove the need to manually make up the hydrogen
15 pressure in a normal band. It will be controlled for
16 them, and they will have the ability to control
17 manually if there is an issue with the automatic
18 control system.

19 Next slide. Other modifications, the
20 hardened wetwell vent modification, we have completed
21 the installation on both Units 1 and 2. Unit 3 will
22 be installed in the spring outage of 2018. The other
23 one that I will address will be the alternate leakage
24 treatment pathway. That is -- you know, for us, it is
25 something that, you know, we are at a non-conforming

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 condition with respect to the alternate leakage
2 treatment pathway, and we do have designs completed.
3 They will be installed in the upcoming EPU outages.
4 Unit 3 will be the first in the spring. These will
5 install air-operated valves that will fail open, as
6 required.

7 We're all installing a new valve in the
8 main steamline drain system as well as replacing four
9 motor-operated valves with air-operated valves, also
10 in the steamline drain system. So this will remove
11 the non-conforming condition prior to EPU
12 implementation, and also, for this, this is currently
13 an operator workaround that we have in place for the
14 steamline drain system, which we'll move that as well
15 in the Unit 1 and Unit 2 outages to follow. Next
16 slide.

17 For the next slide, a couple things I will
18 say with respect to the instrumentation and for the
19 control room operators. We will be, you know, making
20 some changes to that associated with set points and
21 respanning the instrumentation. The control room, for
22 the operators, what they see, it will be transparent
23 to them. They are going through now and looking at
24 all of the new EPU conditions on the simulator as far
25 as, you know, what these changes will be.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The one thing that we are going to do as
2 far as modifications to really assist our operating
3 crews is we're going to install a new condenser vacuum
4 instrumentation. Right now, you know, we have
5 condenser vacuum indication, but we're going to go for
6 each individual condenser to where the operators will
7 have, you know, specific points to monitor for each
8 individual condenser. Air condensers are designed a
9 little bit different than some plants. They have a
10 common area, but they also have three separate water
11 boxes, either one of which can provide a turbine trip
12 signal, so this installed upgraded instrumentation
13 will give them exact indication on each individual
14 water box. This is something that the operators have
15 asked for, that it's important to them, so we will be
16 doing these implementation modifications in the Unit
17 3 outage and each succeeding EPU outage to follow.

18 So pending any questions, this completes
19 my overview for the modification summary.

20 MEMBER SKILLMAN: Yes. I would ask this:
21 with the condenser pressure model, with the higher
22 flow rates, are you going to be pushing those
23 condensers to where they are in fact a trigger for
24 your higher power conditions?

25 MR. HUGHES: With higher flow rates, there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will be some, you know, change with respect to
2 condenser vacuums, specifically in the summertime,
3 when we have elevated cooling water temperatures.
4 Now, the one thing about it as far as, you know, our
5 procedural requirements for, you know, turbine loading
6 and power for condenser vacuum, those will not change.
7 You know, we still have trigger values in our
8 procedures and so forth.

9 The other thing that we have done, not
10 really associated with EPU, but for margin purposes,
11 is, you know, over the last couple years, we have
12 started the condenser cleaning -- or chemical cleaning
13 of condensers, which we, you know, did some industry
14 benchmarking and started that, which has really
15 improved our margin with respect to condenser vacuum.
16 What this does is give the operators a better
17 indication for each water box, which actually assists
18 them for their trigger values in accordance with our
19 procedures. But as far as, you know, operating
20 margins, those will not change.

21 MR. HUGHES: Okay. The reason for my
22 question was are you actually pushing yourself into a
23 condition where you're more likely to get trips,
24 particularly when the -- when the Tennessee River is
25 running at its warmest?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DONAHUE: We performed analysis, both
2 pre-EPU and -- and EPU. Another modification that we
3 will be performing is that we're -- we're changing the
4 alarm set point, and also the -- the trip set point
5 through GE analysis for those -- those alarm and trip
6 set points, and when you look at both of them
7 together, we will actually be at a similar position
8 that we are today. So the EPU does affect condenser
9 vacuum. However, the alarm and trip set points offset
10 that.

11 MEMBER SKILLMAN: Okay. Thank you.

12 MR. DONAHUE: So I am Pete Donahue. I am
13 the Senior Engineering Manager for EPU. I will be
14 presenting elimination of -- of credit for containment
15 accident pressure.

16 So I am on Slide 15. Slide 15 shows a
17 general diagram of the -- the terms that go into
18 determining the available net positive suction head so
19 that we can compare them to the required net positive
20 suction head to ensure that we -- we are not taking
21 any credit for containment accident pressure. Next
22 slide.

23 MEMBER REMPE: Pete?

24 MR. DONAHUE: Yes.

25 MEMBER REMPE: I know you said it during

1 our subcommittee meeting, but just to make sure that
2 every member here has it and that I have it correct,
3 you indicated during the subcommittee meeting that the
4 current analysis relies on the maximum CAP credit of
5 3 psg for about 80 minutes during LOCAs, is that a
6 true statement?

7 MR. DONAHUE: That is, it is 80 minutes
8 for the long-term, and about 10 minutes for the short-
9 term, so a total of like 88 to --

10 MEMBER REMPE: Okay.

11 MR. DONAHUE: -- to 90 minutes.

12 MEMBER REMPE: Thanks.

13 MR. DONAHUE: So Slide 16 goes over the --
14 some background for containment accident pressure.
15 What we did is we took -- we took the opportunity to
16 eliminate crediting containment pressure during --
17 during an accident or an event, and there's really two
18 types of events, right? There's special events and
19 there's design basis accident types of events. So --
20 so we -- we performed our analysis to -- to ensure
21 that we're not crediting containment accident
22 pressure. As a matter of fact, we're going to update
23 both our design and our licensing basis to show that
24 we do not credit containment accident pressure, and
25 that statement will also show up in our technical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 specifications.

2 So -- so this -- we -- we used the -- the
3 current guidance, that is, SECY-11-0014, to perform
4 this analysis. Next slide. The -- the -- this slide
5 shows -- this Slide 17 shows some of the -- the
6 aspects of -- of the analysis that we performed in
7 order to eliminate crediting containment accident
8 pressure and some actions that we have taken. The --
9 the first shows that we did perform a number of
10 comprehensive containment analyses using a program
11 that some of you may be familiar with, SUPERHEX,
12 analysis to perform containment accident pressure.

13 SUPERHEX really just gives us the
14 temperature in which we will evaluate the vapor
15 pressure term for the net positive suction head, so we
16 have done a number of analyses, you can imagine, with
17 different initial conditions and different events, so
18 there is -- there is -- and with different flow rates.

19 We also increased the -- what is called
20 the -- the heat -- the heat exchanger K-value, and if
21 you're not familiar with this heat exchanger K-value,
22 it is -- it is really a factor that you use in doing
23 the -- the containment -- heat transfer analysis,
24 where you can apply this factor to the difference
25 between the hot side and the cold side, inputs to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 heat exchanger. So this K-value is no more than that,
2 but -- but there's a pretty complicated formula to
3 determine that --

4 CHAIRMAN BLEY: So is this analysis or
5 physical change?

6 MR. DONAHUE: This is analysis.

7 CHAIRMAN BLEY: Analysis? Okay.

8 MR. DONAHUE: The -- so -- so in order to
9 ensure that we maintain that -- that K-value, we are
10 putting that information on performance of our heat
11 exchangers into technical specifications to ensure
12 that we -- we both perform the -- the heat exchanger
13 performance testing on -- on a given frequency and
14 that we maintain the -- the K-factor that is in our
15 design basis.

16 MEMBER REMPE: So Pete, just to clarify a
17 couple of things, first of all, this response to
18 Dennis's question, it is analysis, but isn't it based
19 on fouling factors that were measured? So before you
20 justified this K-value, you actually had some data to
21 support it?

22 MR. DONAHUE: Oh yes, yes.

23 MEMBER REMPE: Okay.

24 MR. DONAHUE: We validated the -- the
25 fouling factors with performance tests on all 12 of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 our heat exchangers.

2 MEMBER REMPE: And then to respond to
3 Member Kirchner's question, I don't think it is
4 proprietary to say that this technical specification
5 was a result of interactions with the staff and that
6 they -- because they want to make sure they have
7 confidence in the analysis, that they have imposed
8 this --

9 MR. DONAHUE: Absolutely.

10 MEMBER REMPE: -- upon the licensee.

11 MR. DONAHUE: Right.

12 The next thing we did was we increased the
13 boron-10 enrichment during the anticipated transient
14 without scram special event to ensure that we had
15 adequate margin for containment accident pressure in
16 that event.

17 MEMBER SKILLMAN: Pete, you didn't include
18 at this bullet that you increased the flow rate for
19 the --

20 MR. DONAHUE: We also, in the technical
21 specifications, there is a specification for where
22 flow rate is an element of determining the
23 acceptability of -- of the ATWS and the injection
24 rate. I am not sure we had a bullet for -- for it.

25 MEMBER SKILLMAN: I am not sure it was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 communicated, but you did in fact increase the flow
2 rate to --

3 MR. DONAHUE: Right.

4 MEMBER SKILLMAN: -- achieve what 774 --

5 MR. DONAHUE: Right.

6 MEMBER SKILLMAN: -- ppm in the time
7 requirement for the 1 percent shutdown.

8 MR. DONAHUE: Right.

9 MEMBER SKILLMAN: Okay. Thank you.

10 MR. DONAHUE: And we also used the -- the
11 vendor supply net positive suction head curves where
12 our design basis didn't have that information
13 previously before we performed this analysis in
14 changing our design basis, and we utilized -- for
15 initial conditions, we utilized all technical
16 specification initial conditions with the exception of
17 the fire special event, where we used nominal values
18 in accordance with the SECY guides.

19 MEMBER REMPE: Pete, again, just to make
20 sure that we have it clear, when Member Skillman said
21 you increased the flow rate, he means in the analysis.
22 My understanding is that you used a more realistic
23 evaluation of what the flow rate would be. You didn't
24 actually increase the flow rate, you increased it in
25 the analysis --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DONAHUE: Oh yes, absolutely --

2 MEMBER REMPE: -- okay?

3 MR. DONAHUE: -- the pumps didn't change.

4 MEMBER REMPE: Is that understood? Okay.

5 Thank you.

6 MR. DONAHUE: Okay.

7 And then finally, on Slide 18, the
8 analysis did demonstrate that we did not need to
9 credit any containment pressure as a result of an
10 accident or the event. That's it, I think. Any
11 questions?

12 (No audible response.)

13 MR. DONAHUE: All right. I will turn it
14 over to Dan to talk about the replacement steam dryer.

15 MR. PAPPONE: I am Dan Pappone. I am GE-
16 Hitachi, and I have been -- for lack of a better word,
17 I have been kind of the principal investigator for the
18 steam dryer issues since the first indications of
19 failures at Quad Cities following their power
update 20 in 2002.

21 Next slide, please. So it has been a long
22 trip, but the replacement steam dryers we're putting
23 in in Browns Ferry is really the end product of all of
24 that research and development that we have done. They
25 are based on the curved hood prototype replacement

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 dryer that we put into a BWR/4 reactor for their
2 extended power uprate about ten years ago, now, so we
3 have had a lot of operating experience with the
4 design.

5 The design itself, what we found coming
6 out of the Quad Cities was that these fatigue
7 stresses, the flow-induced vibration, were really
8 tight on that with the original dryer designs, and we
9 basically had to refine our steam dryer design because
10 of that. Because of that, the -- these replacement
11 dryer designs are much -- much more robust than the
12 original dryers. The original dryers, the fatigue --
13 fatigue stresses were believed to be negligible, and
14 we did have some cracking initially, and that was
15 patched. It went on, but when we started doing the
16 extended power uprates, we found -- we found we were
17 right up against the structural limits, so that is
18 basically what has driven the industry to replacement
19 or -- or extensive modifications.

20 Key to that is -- key to being able to do
21 those design analyses is developing the acoustic load
22 pressure methodology for putting on the structure in
23 order to do those predictive structural analyses to be
24 able to do a design efficiently, and the method that
25 we have come up with, we take measurements -- for a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plant going in, we will take measurements from the
2 main steam lines, basically using the main steam lines
3 like stethoscopes to listen in and develop -- capture
4 the frequencies that are actually loading the dryer,
5 and then using that to develop the acoustic load
6 definition that we then put on a structural model.

7 And methodology that we developed, we used
8 that full methodology end-to-end on the previous
9 replacement dryer project. The results of that were
10 good, and we have also captured that process as part
11 of the ESBWR design certification documentation. So
12 we have captured that methodology. It has been
13 reviewed and accepted by the NRC on those projects.

14 And then of course, we have always
15 analyzed the dryers for the primary structural loads
16 to make sure that the dryers maintain their structural
17 integrity, don't generate any of those parts during
18 normal operation transient and then accident events.
19 Next slide.

20 MR. RICCARDELLA: Which plant was the
21 prototype BWR for?

22 MR. PAPPONE: Those were the Susquehanna
23 dryers.

24 MR. RICCARDELLA: Thank you.

25 MR. PAPPONE: So in the replacement dryer

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 world, we have replaced the stream dryers for Quad
2 Cities Units 1 and 2 and then used that same design on
3 the Dresden's Units 2 and 3. The next -- next EPU
4 application was really modifications that we did to
5 Vermont Yankee where we put the repair modifications
6 that we had developed on the original Quad Cities and
7 Dresden dryers while we were going through the
8 replacement dryer design process, we had put that set
9 of repairs on Vermont Yankee. Those repairs performed
10 successfully for the EPU life of the plant with no
11 issues.

12 We went back to the curved hood dryer --
13 basic curved hood dryer design for the Susquehanna
14 replacement dryers partly because of fabrication
15 issues. Complexity of the designs we used for Quad
16 Cities and Dresden, we had a lot of castings and the
17 like. We wanted to move away from that and get back
18 to simpler fabrication techniques.

19 And then Grand Gulf was the next step,
20 again with the curved hood dryer. So in each of these
21 steps, we are taking whatever lessons learned, folding
22 those into the next design. And Browns Ferry is -- is
23 taking advantage of all of this experience in their
24 replacement dryer designs. Next slide.

25 So we did have some -- some changes to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 -- from prototype design when we went to Browns Ferry.
2 We did have -- because of the hold down differences,
3 the dryer hold downs, in Unit 1 versus Units 2 and 3,
4 we did have to accommodate those differences and come
5 up with a slightly different mechanism for holding the
6 dryer down in the event of a steamline break accident
7 that would push the dryer up, and we wanted a single
8 design that would accommodate all three units.

9 We did fold in the operating experience
10 and lessons learned from the previous analyses, both
11 in the operating world and in the fabrication world.
12 And we went through a couple of design iterations
13 specifically for Browns Ferry. First is when we put
14 the specific load definition on, we see what parts of
15 the dryer are responding to the frequencies that we're
16 experiencing, take care of any amplified structural
17 response we may see, do some design changes to -- to
18 address those, and then with the Browns Ferry project
19 schedule, we had the time to do a full second design
20 iteration where we were able to go through the whole
21 structure, even out the load paths, even out the
22 stresses, and bring in as much margin as we could into
23 the design.

24 And next slide. This flow chart gives an
25 overview of the analysis approach. We've got two

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 finite element models: one for the acoustics where we
2 have modeled the steam dome cavity with the dryer in
3 -- in the steam dome, and that is the tool that we use
4 for developing the acoustic load definition and
5 projecting the loading onto the dryer surfaces. We've
6 got a second finite element, ANYSYS model of the dryer
7 structure itself, basically a shell model, and that is
8 the primary analysis for generating the -- generating
9 the stresses, calculating the stresses.

10 The one we do take going in, because we
11 don't have on-dryer measurements of the acoustic
12 loading for Browns Ferry, we are starting with the
13 steamline measurements as a basis for our load
14 definition. We -- the one key load component that is
15 not present at the current power is if there is an --
16 if there is an acoustic resonance in the safety relief
17 valve standpipe that may come as we raise -- increase
18 power, we don't have -- we may not have the
19 measurement of that today. We have to go through,
20 look at the characteristics, the geometry of the
21 steamline, what we're seeing in the actual acoustic
22 signature in the steamline measurements we have taken,
23 and predict whether or not we will -- we have the
24 possibility of the resonance coming up, and if so,
25 what frequency, what amplitude.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We go through that process and factor that
2 into our acoustic load definition that we're putting
3 on the structure. Take -- come up with the -- we also
4 go and project the amplitude growth for the loading
5 when we get up to EPU, take all of that information
6 for the load definition, put that on the structural
7 model, run that -- run that analysis, get the raw
8 stresses, then go through several stress adjustment
9 factors, scaling the stresses up to EPU. We have bias
10 and uncertainties that we apply to the raw results
11 coming from the benchmarking where we benchmark
12 methodology against instrumented dryer structural
13 response, so we factor that -- that in.

14 There are operating conditions that may
15 increase the stresses from non-acoustic sources: vane
16 passing frequency from the recirculation pumps can
17 drive structural vibrations that carry into the dryer
18 and increase the stresses by a small but non-
19 negligible amount. And then that -- that will give us
20 our final flow-induced vibration fatigue stresses. We
21 compare that against the ASME code fatigue allowance
22 limit. We are looking at the far end of the fatigue
23 curve because we are basically designing assuming
24 we've got those loads acting for the whole time -- for
25 the remaining life of the plant, and that then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 determines how much margin we have to the fatigue
2 limit.

3 Those fatigue analysis results also get
4 carried into the acceptance criteria for the -- for
5 the limit curves for power ascension, and the analysis
6 itself is part of the framework that we use for
7 monitoring -- predicting and monitoring the dryer
8 stresses as we're coming up on power ascension. The
9 -- those results are also fed over into the primary
10 stress analysis for the normal upset faulted condition
11 primary structural analyses, and then we compare those
12 results against the ASME code acceptance criteria for
13 those conditions.

14 Next slide. So when we got through the
15 fatigue analysis, we were basically at a factor of two
16 margin to the code limit for the -- for the fatigue
17 limit. We've got one component that was just a hair
18 under two, and so that was successful. That design is
19 successful. It's nice going into the power ascension
20 with this kind of margin. Yes?

21 MR. RICCARDELLA: So as I understand it,
22 this factor of two applies to the initial analysis up
23 to EPU conditions prior to the benchmarking, and then
24 once you do the -- and then benchmarking, you're
25 allowed to reduce that to one. Just out of curiosity,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on the Susquehanna plant, how much of that difference
2 between two and one was used up with the bias, the new
3 bias in uncertainty factors?

4 MR. PAPPONE: By the time we got -- got
5 all the way through -- through the -- through the
6 process, we were still -- we were still above the
7 limit. There was also some history in there in that
8 when we discovered errors and had gone back and
9 checked to confirm the operability for the previous
10 analyses, that -- but we're still above that -- above
11 the ASME limit.

12 MR. RICCARDELLA: Yes, but it was at 1.01, 13 or
14 1.1?

15 MR. PAPPONE: I don't remember --

16 MR. RICCARDELLA: Ballpark?

17 MR. PAPPONE: I don't remember -- well, it
18 was about 1.3 when we were done with the power
19 ascension.

20 MR. RICCARDELLA: Okay, okay.

21 MR. PAPPONE: But that -- in that case, we
22 were going in almost with -- with a blind set of
23 analysis tools because that was really the first time
24 we had gone through that process.

25 MR. RICCARDELLA: Yes. So we should do
better on --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PAPPONE: We should be doing -- we did
2 --

3 MR. RICCARDELLA: -- on this one.

4 MR. PAPPONE: We did quite a bit better on
5 Grand Gulf, so --

6 MR. RICCARDELLA: And for the record, that
7 ASME code limit has a factor in it, a factor of two in
8 it also, right?

9 MR. PAPPONE: Yes.

10 MR. RICCARDELLA: Thank you.

11 MR. PAPPONE: Actually, it's all of this
12 margin that we're putting in at the beginning that is
13 driving the replacement dryer, because we do have
14 dryer -- we do have plants that were -- had gone up to
15 EPU before with the original dryers with no
16 modifications, and there haven't been any issues
17 there. But it is the analysis, predictive analysis
18 world in the margin that is -- that is driving us to
19 this kind of a robust design, and the fact that we
20 don't want to have another Quad Cities.

21 So next slide, please. Now for the
22 primary stress evaluations, these are straightforward.
23 The original dryers were designed for the faulted
24 condition with the intent that if we had that margin
25 available to accommodate the accident loads, we had

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plenty of margin for the fatigue. Well, things have
2 kind of flipped a little. Now that we have gone and
3 put in all of this additional margin for the fatigue,
4 we've got plenty of margin for the accident
5 conditions.

6 And we'll go through the process. And
7 dryer is not a safety-related item. It has no active
8 safety function. We just need to make sure that
9 during an event, it maintains its structural
10 integrity, it doesn't generate any of those parts.
11 And then it's not a code component, it's not of course
12 a core component, but we're -- for all intents and
13 purposes, we are designing it as if it were a code
14 component.

15 Next slide. The power ascension
16 monitoring process we have also worked out over the
17 replacement dryer projects, and the process is
18 similar. For the lead unit, both the replacement
19 dryer and the steamlines will be instrumented, and as
20 we come up in power, we will be able to do the
21 benchmarking, the Browns Ferry-specific benchmarking,
22 of the analysis, come up with Browns Ferry-specific
23 bias and uncertainty factors that will then fold into
24 the power -- the limit curve monitoring and also into
25 the follow-on units.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The power ascension limit, the power
2 ascension limits for lead unit will be on the dryer
3 instrumentation, and when we do it, the main steamline
4 will be backed up in case we -- in the event that if
5 we lose too many instruments on the dryer, we will be
6 able to continue. And that brings -- that gets us to
7 the point of the factor of two that you had mentioned.
8 If we get through that Browns Ferry-specific
9 benchmarking, at that point, we will be working with
10 a benchmark model at that point, the power ascension.

11 CHAIRMAN BLEY: The Browns Ferry units, I
12 don't remember. I thought they were built at somewhat
13 different times.

14 Is the piping identical as you go from
15 unit to unit?

16 MR. PAPPONE: It's virtually identical.
17 There is one safety ruling valve standpipe that's in
18 a little bit different position.

19 But they're virtually identical as far as
20 the loads. And that shows up -- going into the
21 design, we had measures in all three units. And they
22 are quite similar.

23 CHAIRMAN BLEY: Thank you.

24 MR. PAPPONE: When we get up to -- when we
25 get up to the fully computed power in the lead unit,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we'll be performing -- taking data and performing
2 benchmarking there.

3 And performing a full scope, confirmatory
4 structural analysis for the FIB loads. And that
5 analysis will then be the basis -- used as the basis
6 for the follow on units for the limit curve
7 development.

8 The follow on units will only have the
9 main steam lines instrumented. It will be matching --
10 essentially matching the signatures going up on that
11 and addressing and using the differences in those
12 signatures to account for any response differences we
13 may be seeing.

14 And then when you get up to the fully
15 fueled for on the follow on units, we'll go through a
16 structural evaluation to confirm that each of those
17 dryers is also meeting the limits.

18 The extent of that, the follow on
19 evaluation will depend on how close the signatures are
20 to the lead unit.

21 CHAIRMAN BLEY: I'm curious. You gave us
22 a little history of how the designs evolved from plant
23 to plant.

24 When you did this kind of testing on the
25 other plants going up, did they all track pretty well

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from the first unit to the others?

2 MR. PAPPONE: It did. In fact PPL, the
3 two unit case we had before, where we were going
4 through in this level of detail was for the
5 Susquehanna. The two units in Susquehanna.

6 And we went through and did the power
7 ascension for the lead unit. PPL basically did the
8 power ascension for the follow on unit.

9 CHAIRMAN BLEY: Um-hum.

10 MR. PAPPONE: So -- and they did track
11 quite well.

12 CHAIRMAN BLEY: Okay.

13 MEMBER SKILLMAN: Dan, let me ask this.
14 The information on this stream dryer appears very
15 convincing. And I just wonder, can this create a
16 false sense of security?

17 And are you asking yourselves, what can go
18 wrong?

19 MR. PAPPONE: Well, I don't think it's a
20 false sense of security. Because we have put in so
21 many over -- so many replacement dryers over the time
22 period.

23 And we just -- we have not been having any
24 issues showing up. The -- and also go back to the
25 operating history for the original steam dryers,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 really it's been Quad Cities -- the Quad Cities in
2 Dresden that were in a way an outlier --

3 MEMBER SKILLMAN: They were the outliers.

4 MR. PAPPONE: Because of the specific
5 conditions for those plants. And partly, you know,
6 the -- partly the dryer design would push -- that
7 particular dryer design did have a limit.

8 Those dryers work fine for 30 years until
9 we raised the power. And the weak points showed up.

10 MEMBER RICCARDELLA: Also as I understand
11 it, there's plans for inspections on the first couple
12 of refueling outages to confirm that they're having
13 problems or not.

14 MR. DONAHUE: Also during start up, we do
15 have level one and level two criteria. Where we look
16 forward, project the readings that we do get at one
17 power level to the readings that we hope to get at the
18 next power level.

19 So, that will help us also to make sure
20 that we're not going to get into a power level that we
21 can't -- where we exceed the criteria.

22 MEMBER SKILLMAN: Thank you. Thanks.

23 MR. PAPPONE: All right. So the next
24 slide. The next slide is well, during the power
25 ascension we do have hold points for NRC review.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 When we get to today's current power,
2 we'll be base lining the methodology on Browns Ferry
3 specific bias and uncertainties. And there's a ten
4 day hold period for NRC in review of that
5 benchmarking.

6 And then a five percent power increments.
7 Going up we'll have four day hold points. This is the
8 same power ascension review plan that's been licensed
9 conditions for most of the replacement dryer projects.

10 Follow on units will follow the same basic
11 process. It will be a smaller scope because we won't
12 have -- won't be doing the same benchmarking.

13 It means we won't have the on dryer
14 instrumentation. Then once each of the units have --
15 reaches the fully queued power, they'll be a full
16 scope inspection for the following two cycles.

17 And that's also the same approach we've
18 been using in the other projects. After that long
19 term, the inspection plan lines up with the industry
20 guidance.

21 Then with that, any other questions?

22 MEMBER REMPE: But this part is the end of
23 the open part of the meeting. And I think we need to
24 ask if there's any members of the public at this point
25 that want to make a comment?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Or if there's any in the room as well as
2 on the line. And I believe the lines are open.

3 (No response)

4 MEMBER REMPE: I see no one in the public
5 or in the audience here who wants to make a comment.
6 And we don't -- I believe we confirm the line is open?

7 MEMBER STETKAR: Just ask.

8 MEMBER REMPE: Is the line open? And are
9 there any comments?

10 (No response)

11 MEMBER REMPE: While we're waiting to do
12 that, it might be good -- I believe we're going to
13 switch out, right? And so you could go ahead and do
14 the switch out if you wanted to.

15 (Off record comments)

16 MEMBER REMPE: Well, the public may --
17 should I close it before I let the public have their
18 chance to have comments? I think we need to let them
19 confirm there's no public --

20 (Off record comments)

21 MEMBER STETKAR: Mr. Brown, it sounds like
22 things are coming online rather than going off. Is
23 the line open?

24 MR. BROWN: No. The public is closed and
25 closed the lines open now.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER REMPE: Okay. So were there any
2 members of the public out there when I was calling for
3 it? Was it open?

4 MR. BROWN: It was open.

5 MEMBER REMPE: It was open. Okay. So at
6 this point, we are going to close the open session.
7 And I don't have a gavel. Okay.

8 (Whereupon, the above entitled matter
9 went off the record at 1:51 p.m. and
10 resumed at 3:16 p.m.)

11 CHAIRMAN BLEY: We are back in open
12 session with a new topic. Westinghouse shutdown seal.
13 So I turn the meeting over to Mr. Stetkar.

14 MEMBER STETKAR: Thank you Mr. Chairman.
15 I will first announce that we are going to run this
16 session similarly to the one that we just had.

17 We will have a rather short open session
18 where the staff will provide an overview of their
19 review. And Westinghouse or the PWR Owners Group will
20 provide a brief introduction.

21 And then we will go into closed session
22 because we need to hear details of the seal design and
23 the topical report and so forth that has proprietary
24 information in it.

25 Give you, the members who didn't attend

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the subcommittee meeting a little bit of the
2 background. The NRC staff back in, I don't recall,
3 earlier, has approved the use of the so called
4 Generation III shutdown seal for use in applications
5 of the flex mitigation strategies.

6 Saying that, the staff did not approve any
7 models for numerical data for failures of the seal for
8 use in any risk analysis that might support those
9 evaluations that are done in response to the orders.

10 PWR Owners Group has submitted a topical
11 report that contains information about the logic
12 structure, the PRA models, the success criteria,
13 consequences from success or failure of the seals, and
14 numerical values to be used for failure rates for the
15 seals.

16 That is what we're talking about today.
17 That topical report on the PRA models and failure
18 rates for the seals. And that's what the SER has
19 written against.

20 So it's not necessarily the design of the
21 seal itself. Although we obviously have to understand
22 how it works. But, I just wanted to make that clear
23 for the record.

24 As I said, we had a subcommittee meeting
25 on February 6 where we had pretty extensive

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 discussions about the topical report, the seals.

2 Since the subcommittee meeting, the Owners
3 Group has submitted a supplement to the topical
4 report. Which I understand will be included in the
5 approved version of the topical report after the
6 safety evaluation is issued.

7 So that what we're actually reviewing
8 today is the Rev 1 of the topical report that we had
9 available for the subcommittee meeting. Which
10 document has not changed, plus the supplemental
11 information that we've received about a month or so
12 ago now.

13 And with that, I have a couple of other
14 things to say once we go into closed session. But
15 let's proceed with the open session. And ask Sunil
16 Weerakkody from the staff to start. Sunil?

17 MR. WEERAKKODY: Yes. Thank you John.
18 Sunil Werrakkody. I'm the Acting Deputy Director in
19 the Division of Risk Assessment. And I really look
20 forward to this opportunity.

21 As John mentioned, you know, the
22 licensees, a number of licensees have already
23 installed the Gen III, what we call the Gen III
24 shutdown seals. And we are of the opinion that when
25 these seals operate as designed and as expected, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 core damage frequencies of these plants reduce. And
2 in some cases, significantly.

3 Because of that, we are very supportive of
4 efforts on the part of the licensees to implement this
5 modification at their plants. So, when NRC completes
6 the approval of this topical report, the licensees
7 will have and what I would call an acceptable method
8 for crediting these seals when they do their PRAs and
9 certainly their results to us in their risk-informed
10 applications.

11 So during the last three years, and that's
12 how long we have been developing this topical report,
13 the staff from the Division of Risk Assessment and the
14 Division of Engineering have expended a significant
15 amount of resources to provide a very thorough review
16 of this report. Which included multiple rounds of
17 REIs, numerous meetings, visits to Westinghouse test
18 specialty, and observing post-operational testing.

19 Then as John mentioned, this year, on
20 February 6, we briefed the ACRS subcommittee. We
21 provided a draft SER. And Westinghouse provided
22 significant details of the design and some of the old
23 designs.

24 And we received very valuable feedback
25 from the subcommittee. Even though the failure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 probability numbers did not change significantly, I
2 could say that based on the feedback from the
3 subcommittee and the number of meetings we had with
4 Westinghouse, I believe we have a draft SER. Which is
5 of, you know, higher quality. Which is more
6 comprehensive.

7 And as John mentioned, also on the part of
8 Westinghouse, they sent a supplemental -- they sent
9 supplemental information which became the basis for us
10 to revise our safety evaluation.

11 So we really want to thank you, thank the
12 subcommittee for their feedback. And we really look
13 forward doing this particular case. I'm not sure
14 whether the process requires that or not.

15 But, speaking for the staff, we really
16 look forward to a letter from the full committee after
17 this meeting. That's all I have to say. Thank you
18 and John, I think we go to the staff now.

19 MEMBER STETKAR: Yes. Please. And by the
20 way, we -- subject to approval by the full committee,
21 we are planning to write a letter on this topical
22 report and the SER.

23 MS. LYONS: Good afternoon. My name is
24 Sara Lyons. I'm a Reliability and Risk Analyst in the
25 Office of Nuclear Reactor Regulations, Division of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Risk Assessment.

2 And I'm here with two of my colleagues,
3 Ching Ng to my left is also with the Division of Risk
4 Assessment. And Bob Wolfgang is with the Division of
5 Engineering.

6 The three of us have been the primary
7 reviewers on this topical report. And so I'll discuss
8 the publically available information briefly here.

9 But before I get into that, I just wanted
10 to indicate, you know, as Sanil mentioned, this
11 topical report did come to us on July 2014. And we've
12 had a number of, you know, regulatory and technical
13 issues that we've had to work through during that
14 time.

15 So I'd like to acknowledge some of the
16 other areas where we had insight from the staff.
17 Including our division of Policy and Rulemaking, where
18 they've been helping with project management type of
19 support.

20 And other offices, Office of the General
21 Counsel, the Office of New Reactors, and the Office of
22 Nuclear Regulatory Research, where they provided some
23 insight for technical consistency. As well as the
24 Reliability and PRA Subcommittee.

25 And I'd like to echo Sanil's feedback that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we did get some valuable insight there. It made
2 changes to our SER as a result of that input. And
3 even added an extra limitation to our SER and are able
4 to bring a higher quality product to the full
5 committee today.

6 So on slide two, the topics that we're
7 going to discuss are the purpose of the review, the
8 background, the scope of the review, and the PRA model
9 review as well as staff conclusions.

10 So on slide three, the purpose of this
11 review again, as was stated earlier, it was to review
12 the probabilistic risk assessment model. Which will
13 allow licensees to credit their shutdown seal in risk-
14 informed activities.

15 The installation of the shutdown seal is
16 an important safety improvement that can mitigate
17 reactor coolant system inventory losses through the
18 reactor coolant pump seals. And a need for reactor
19 coolant system makeup to achieve a stable state.

20 So on slide four, here's a little bit more
21 background. A loss of seal coolant -- I'm sorry. A
22 seal loss of coolant accident or seal LOCA can occur
23 when the thermal barrier heat exchanger cooling and
24 the seal injection both fail.

25 According to the currently approved model,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the leakage could range from 21 to 480 gallons per
2 minute per pump. And when that shutdown seal is
3 installed and operates as it is intended to, the
4 leakage would reduce to less than one gallon per
5 minute for up to 168 hours.

6 Which can provide a significant reduction
7 in core damage frequency for some plants. It's really
8 plant specific. But it can provide, as was indicated
9 in an industry study referenced here, up to 50 percent
10 reduction in core damage frequency.

11 So on slide five, the PRA -- the scope of
12 the review included the PRA model. The topical report
13 PWR Owners OG-14001, Revision One, was submitted for
14 review and approval.

15 Which described the PRA model. But also
16 referenced a lot of the qualifications, testing
17 information that was provided in a separate document
18 previously, TR-FSE-14-1, Revision One.

19 The testing information was provided to
20 the NRC staff in response to the Order EA-12049 for
21 mitigating strategies. And the staff had previously
22 endorsed the use of the shutdown seal for the extended
23 loss of AC power evaluations that were performed in
24 accordance with that Order.

25 This topical report wasn't requesting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 approval of installation. That's going to be through
2 other -- performed through other processes such as 10
3 CFR 50.59.

4 And the plant specific considerations will
5 need -- there are plant specific considerations that
6 will be addressed in future license amendment requests
7 that weren't -- it wasn't appropriate to cover here
8 because it was very topical, a generic evaluation.

9 MEMBER SKILLMAN: Sara, on your third
10 bullet, are you communicating that 50.59 may not be
11 used? Or that the topical report is not approving
12 installation and that if a licensee wants to, the
13 licensee may use 50.59?

14 MS. LYONS: Right. The second one.

15 MEMBER SKILLMAN: The latter?

16 MS. LYONS: That latter one. And I think,
17 you know, a lot of plants have already installed
18 these.

19 MEMBER SKILLMAN: Under 50.59?

20 MS. LYONS: Under 50.59.

21 MEMBER SKILLMAN: Okay. Thank you.

22 MS. LYONS: Um-hum. So, on slide six, the
23 major PRA model review areas included consideration of
24 the Generation I and II shutdown seals, adequacy of
25 the qualification testing, statistical analysis of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 shutdown seal failure modes, common cause failure,
2 human reliability analysis, inadvertent actuation of
3 the shutdown seal, and performance monitoring.

4 And we'll go into more detail on those in
5 the closed session. And our conclusion, based on our
6 evaluation of PWR Owners Group 14001, Revision One, as
7 supplemented and various supplements referenced in the
8 AIC.

9 And used in accordance with the
10 limitations and conditions, we've concluded that the
11 safety eval -- I'm sorry. That the document is
12 acceptable.

13 And that licensees always have an option
14 of choosing to model their shutdown seal in a
15 different manner. But they would need to justify any
16 differences or deviations from what is approved and
17 their specific risk-informed license amendment
18 request.

19 MEMBER SKILLMAN: So let me go back to
20 slide five just so it's clear in my mind. You've
21 communicated that a licensee can implement this change
22 through 50.59.

23 But in the next bullet, you say that plant
24 specific considerations are in a license amendment
25 request. Well, what 50.59 does is it makes the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 licensee determine whether or not a licensed amendment
2 request is needed or not.

3 MS. LYONS: Okay. So what I meant by the
4 last bullet wasn't really related to the installation.
5 I can see how that's a little misleading the way we
6 have it on the slide there.

7 But, the last bullet was really related to
8 the implementation in the PRA. There is some
9 considerations on how the shutdown seal failure is
10 modeled in their PRA.

11 But it really needs to be handled on a
12 site specific basis.

13 MEMBER SKILLMAN: So a hardware mode can
14 be evaluated through 50.59 and successfully
15 implemented as a modification. But the PRA
16 implications come out through the LAR.

17 MS. LYONS: Right.

18 MEMBER SKILLMAN: Understand. Thank you.
19 Thank you. All right.

20 MS. LYONS: And that's all we have today.
21 So if there's any questions.

22 MEMBER STETKAR: Any questions for the
23 staff that pertain to something that we can discuss in
24 the open session?

25 (No response)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Okay. If not, we'll have
2 the Owners Group come up and give us an introduction
3 to the topic.

4 MR. LINTHICUM: I'm all set. Good
5 afternoon. Once again, similar to the staff, we
6 appreciate the opportunity to come back and discuss
7 our topical report with you.

8 And explain how we're planning on modeling
9 the shutdown seals in the PRA model. My name is Roy
10 Linthicum. I'm Chairman of the Risk Management
11 Committee within the PWR Owners Group.

12 We've actually been working on this
13 topical report longer than the staff has been
14 reviewing it. And we are very anxious to get an SE.

15 A lot of our members really are relying on
16 the SE to be able to move forward with some very
17 important risk informed licensing requests.

18 Next to me is Matt Degonish. He is -- is
19 that one? There we go. Matt is our primary PRA lead
20 for development of the model.

21 When we met here on February 6, Matt was
22 unable to attend. He's a new father. So we dragged
23 him away from his family to come down here today.

24 And Mike LaPresti is here. And he's one
25 of the principal design engineers responsible for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 shield.

2 My presentation will be even shorter than
3 the staff's until we get into the closed session. So,
4 just a quick overview.

5 The shutdown seal was developed by
6 Westinghouse to limit the leak rate from the RCPs
7 following a loss of all seal cooling. It allows us to
8 respond to a wide range of events such as station
9 blackout and things that would disrupt the power
10 supplies and cause a loss of all cooling.

11 The important thing in my mind is not only
12 do we get a significant benefit in our PRA models,
13 where we're talking orders of magnitude benefit in the
14 probabilities of seal leakage, but more importantly,
15 we don't challenge the operators as much when we have
16 the seal in place.

17 Because they don't have to worry about a
18 LOCA going on concurrent with the loss of offsite
19 power station blackout event. And that's probably the
20 most important element.

21 And with that said, we also want to make
22 sure we take credit for the PRA models that were
23 modeled in the plant. As closely as built as operated
24 as possible.

25 Plant's once they install the shutdown

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 seal will change their PRA models to credit the seal.
2 It's a fairly simple change to the model.

3 Once we agree on the failure
4 probabilities, it's an add onto the WOG2000 model,
5 which the staff described. Or any other model that we
6 may have.

7 We are actually looking at a possible
8 change to the WOG2000 model that will address some
9 things that aren't covered in that original model.
10 But that's not part of this discussion.

11 But, we wanted to make sure the SE was
12 written so we could -- that the report was written so
13 we can take advantage of those future models as well.

14 And once again, once you integrate it into
15 the PRA model, you do get a significant decrease in
16 core damage frequency. And if we go the next. I'm
17 actually just going to skip the next slide.

18 So, We're actually seeing over 50 percent
19 reduction of core damage frequency. Typically on the
20 order of 60 to 70 percent reduction.

21 Seal LOCAs have been probably the biggest
22 thorn in our side as far as the PRA modeling, as far
23 as our sequences that are concerned. So this really
24 does provide us a tremendous benefit.

25 And with that, I'll open up for questions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on the open session.

2 MEMBER SKILLMAN: Roy, why do you show
3 PWRA and PWRB?

4 MR. LINTHICUM: Those are just -- those
5 are two different plants.

6 MEMBER SKILLMAN: It just shows that for
7 two different plants that they're P's -- there's a
8 huge reduction.

9 MR. LINTHICUM: There's a huge reduction.
10 Right. They're slightly different designs. But
11 they're still -- there's still a huge reduction
12 regardless of what type of plant.

13 If you have a Westinghouse RCP pump,
14 regardless of whether or not you're a Westinghouse
15 plant, there's actually some BNW plants with
16 Westinghouse RCPs involved.

17 MEMBER SKILLMAN: Yes.

18 MR. LINTHICUM: Regardless of the plant
19 design, you get a very large reduction.

20 MEMBER SKILLMAN: Okay. You're saying if
21 it's a P and has a seal, that's what happens.

22 MR. LINTHICUM: That's what happens.

23 MEMBER SKILLMAN: Makes no difference
24 whether it's a --

25 MR. LINTHICUM: Correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: BNW or a --

2 MR. LINTHICUM: Correct.

3 MEMBER SKILLMAN: Westinghouse origin or
4 what's in origin.

5 MR. LINTHICUM: Yes. Well, I don't know
6 of any combustion plants that have Westinghouse pumps
7 that would have the seal design that are in the
8 WOG2000.

9 But there are some that may have.

10 MEMBER SKILLMAN: Is it strongly
11 influenced by whether it's a Byron Jackson pump or one
12 of the other --

13 MR. LINTHICUM: This seal only applies to
14 Westinghouse pumps.

15 MEMBER SKILLMAN: Only to Westinghouse
16 pumps.

17 MR. LINTHICUM: Only Westinghouse pumps,
18 right.

19 MEMBER SKILLMAN: Got it.

20 MR. LINTHICUM: The Byron Jackson pumps
21 that are in like the CE plants, have a different seal
22 design. And there's actually an approved topical on
23 the PRA model for those seals as well.

24 MEMBER SKILLMAN: And the Bingham pumps?

25 MR. LINTHICUM: That's all -- all the CE

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pumps are covered under that topical report on the CE
2 plants.

3 MEMBER SKILLMAN: Thank you Roy.

4 MR. LINTHICUM: Okay.

5 MEMBER STETKAR: Anything else for the
6 Owners Group in open session?

7 (No response)

8 MEMBER STETKAR: If not, are there any
9 people in the room who would like to make a comment
10 during the open session? If so, come up to the mic.
11 And I'll ask if there are any members of the public on
12 the bridge line who would like to make a comment.
13 Please identify yourself and make a comment, please.

14 MR. BROWN: Bridge open.

15 MEMBER STETKAR: Thank you. Hearing none,
16 We will now close the session and close the
17 transcript. If you could bang the gavel.

18 (Whereupon, the above-entitled matter went
19 off the record at 3:37 p.m.)

20


21

22

23

24

25



U.S. NRC
UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment

ACRS Full Committee Meeting

NRC Staff Review of Extended Power Uprate for Browns Ferry Nuclear Plant Units 1, 2, and 3



Opening Remarks

Kathryn Brock

Deputy Director

Division of Operating Reactor Licensing

Office of Nuclear Reactor Regulation

Background

- **Browns Ferry Proposed EPU:**
 - **3458 to 3952 Megawatts Thermal**
 - **14.3% increase from Current Licensed Thermal Power**
- **EPU Review done using Extended Power Uprate Review Standard, RS-001**
- **No open items in draft safety evaluation**



Introduction

Farideh Saba

Senior Project Manager

Division of Operating Reactor Licensing

Office of Nuclear Reactor Regulation



Review Schedule

- **September 21, 2015 – Application submitted to NRC.**
- **January 11, 2016 – Application accepted by NRC for review.**
- **May 3, 2017 – ACRS Subcommittee meeting**
- **NRC forecast for review completion July 2017**
- **TVA planned implementation dates:**
 - Unit 3 in Spring 2018**
 - Unit 1 in Fall 2018**
 - Unit 2 in Spring 2019**

Agenda

OPEN SESSIONS

- **TVA Presentations:**
 - **Background**
 - **Summary of Plant Modifications**
 - **Overview of Elimination of Credit for Containment Accident Pressure (CAP)**
 - **Overview of Replacement Steam Dryer**

CLOSED SESSIONS

- **NRC staff Presentations:**
 - **Review of Fuel and Reactor System**
 - **Review of CAP Credit Elimination**
 - **Review of Replacement Steam Dryers**



Browns Ferry Nuclear Plant
Extended Power Uprate License Amendment Request
Advisory Committee on Reactor Safeguards

June 7, 2017

Introductions

Browns Ferry Nuclear Plant Extended Power Uprate

Gerry Doyle

Director, Extended Power Uprate

and

Ed Schrull

TVA Corporate Fleet Licensing Manager

BFN EPU ACRS – Introductions

Agenda

- Introductions E. Schrull/G. Doyle
- Overview
 - Background S. Bono
 - Modifications Summary L. Hughes
- Elimination of credit for Containment Accident Pressure (CAP) in Net Positive Suction Head (NPSH) evaluations for Emergency Core Cooling System (ECCS) pumps P. Donahue
- Replacement Steam Dryer (RSD) Overview D. Pappone

BFN EPU ACRS – Introductions

Key Team Members Present

- Steve Bono – Browns Ferry Nuclear Plant (BFN) Site Vice President
- Lang Hughes – BFN General Manager, Site Operations
- Gerry Doyle – Director, Extended Power Uprate (EPU)
- Scott Hunnewell – BFN Director, Site Engineering
- Pete Donahue – EPU Senior Engineering Manager
- Denny Campbell – BFN Nuclear Plant Shift Operations Manager
- Bill Baker – EPU Senior Operations Manager
- Ed Schrull – Tennessee Valley Authority Corporate Fleet Licensing Manager
- Dan Green – EPU Senior Licensing Manager
- Michael Dick – EPU Project Engineer
- Greg Storey – EPU Project Engineer
- Jeff Lewis – EPU Project
- Bill Williamson – BFN Reactor Engineer

BFN EPU ACRS – Introductions

Key Team Members Present (continued)

- Dan Pappone – General Electric – Hitachi (GEH)
- Don Sampson– GEH
- David McBurney – AREVA
- Alan Meginnis – AREVA

BFN EPU ACRS Subcommittee – Introductions

BFN EPU Team

- The EPU Project Team is staffed with personnel having extensive Boiling Water Reactor (BWR) plant and EPU experience
 - TVA
 - Combination of dedicated project and plant resources
 - GEH (Nuclear Steam Supply System)
 - AREVA (Fuels)
 - Industry EPU experienced specialty contractors

BFN EPU ACRS Subcommittee – Introductions

BFN EPU Project Team Goals

- Present Nuclear Regulatory Commission (NRC) with a high quality License Amendment Request (LAR) consistent with RS-001 Standards
- Resolve Containment Accident Pressurization (CAP) credit issues
- Install Replacement Steam Dryers (RSD) for all three units
- Provide smooth transition to EPU for Plant Operations

Overview

Browns Ferry Nuclear Plant Extended Power Uprate

Steve Bono

Browns Ferry Nuclear Plant Site Vice President
and

Lang Hughes

Browns Ferry Nuclear Plant General Manager, Site Operations

BFN EPU ACRS – Overview

Background

- BFN
 - General Electric Boiling Water Reactor (BWR)/4 Mark I Containment
- Operating Licenses issued
 - Unit 1 - 12/20/1973, Unit 2 - 8/20/1974, Unit 3 - 8/18/1976
- Commercial Operation commenced
 - Unit 1 - 8/1/1974, Unit 2 - 3/1/1975, Unit 3 - 3/1/1977
- Renewed Licenses issued 5/4/2006 (Units 1, 2, and 3)
- Licensed Thermal Power History
 - Original Licensed Thermal Power (OLTP) - 3293 MWt
 - Stretch Uprate (105% OLTP) - 3458 MWt
 - Units 2 and 3 - 9/8/1998, Unit 1 - 3/6/2007
 - Proposed EPU (120% OLTP, 14.3% CLTP) - 3952 MWt

BFN EPU ACRS – Overview

Modifications Summary

- Remaining Modifications
 - Replacement Steam Dryer
 - New steam dryers to be installed to increase structural design margin to accommodate EPU operation
 - High Pressure Turbine Replacement
 - High pressure rotors to be replaced with rotors designed for increase flow associated with EPU
 - Feedwater Heaters
 - Tube bundle and channel head to be replaced in the number 4 Feedwater Heaters with design less susceptible to flow-induced vibration
 - Main Generator Hydrogen Pressure
 - Main generator hydrogen pressure to be increased to support EPU operation

BFN EPU ACRS – Overview

Modifications Summary

- Remaining Modifications (continued)
 - Standby Liquid Control (SLC) System
 - Increase Boron-10 enrichment from 63 to 94 atom percent in SLC Storage Tank solution to lower power faster during Anticipated Transient Without Scram (ATWS)
 - Hardened Wetwell Vent (HWWV)
 - Modify HWWV, as part of modifications for compliance with the Order on Reliable Hardened Containment Vents, to provide capacity of HWWV that is one percent of EPU thermal power
 - Self-Excited Generator Excitation System
 - Modify excitation system to a self-excited shaft driven alternator and modify the Automatic Voltage Regulator to address a transient stability issue resulting from increased electrical generation at EPU conditions (North American Electric Reliability Corporation issue)
 - Alternate Leakage Treatment Pathway
 - Modify the Alternate Leakage Treatment Pathway design to be consistent with the existing licensing basis dose calculations performed at EPU conditions

BFN EPU ACRS – Overview


Modifications Summary

- Remaining Instrumentation Changes to support EPU
 - Technical Specification Instrumentation Respan/Recalibration
 - Turbine first stage pressure scram bypass permissive setpoint to be recalibrated
 - Main steam line high flow isolation channel to be respanned
 - Average Power Range Monitor flow biased and setdown instrumentation to be respanned and setpoints recalibrated
 - Condenser Instrumentation Upgrade
 - Install nine new condenser vacuum pressure transmitters per unit (three on each condenser) and provide signals to electro-hydraulic control (EHC) system
 - Move condenser A/B/C low vacuum alarm, low vacuum turbine trip and low vacuum bypass trip functions to EHC logic
 - Perform hardware and software changes to EHC system to support alarm and trip functions

Elimination of Credit for Containment Accident Pressure in Net Positive Suction Head Evaluations for Emergency Core Cooling System Pumps

Pete Donahue
Extended Power Uprate Senior Engineering Manager

BFN EPU ACRS – Elimination of credit for CAP in NPSH Evaluations for ECCS pumps



BFN EPU ACRS – Elimination of credit for CAP in NPSH Evaluations for ECCS pumps

Background

- Opportunity to improve margins and address industry concerns associated with CAP credit
 - One of the EPU Project Team Goals
- Used guidance provided in SECY-11-0014, Use of Containment Accident Pressure in Analyzing Emergency Core Cooling System and Containment Heat Removal System Pump Performance in Postulated Accidents
- EPU NPSH evaluations for ECCS pumps demonstrate **credit for CAP is NOT required**

BFN EPU ACRS – Elimination of credit for CAP in NPSH Evaluations for ECCS pumps

Actions to Eliminate CAP Credit

- Performed comprehensive analyses of accidents and special events
- Increased Residual Heat Removal (RHR) Heat Exchanger factor (K-value) for all events
- Validated acceptability of increased RHR Heat Exchanger K-value by performing RHR Heat Exchanger Performance Tests on all 12 RHR Heat Exchangers at BFN (4 per unit)
 - To ensure that this level of RHR Heat Exchanger performance is maintained, a Technical Specification for the RHR Heat Exchanger Performance Monitoring Program will be added
- Increased SLC System Boron-10 enrichment for ATWS event
- Used Vendor supplied NPSH curves (NPSHr 3% curves)
- Used Technical Specification values for initial conditions in Design Basis Accident (DBA) Loss of Coolant Accident (LOCA) and Special Events analyses
 - Except for Fire Event
 - SECY-11-0014 allows use of nominal values for Special Events

BFN EPU ACRS – Elimination of credit for CAP in NPSH Evaluations for ECCS pumps

Results

- For all events
 - Net Positive Suction Head Available (NPSHa) is greater than Effective Net Positive Suction Head Required (NPSH_{eff})
- **No CAP credit required**
 - No additional operator actions required

Replacement Steam Dryer (RSD) Overview

Dan Pappone
GE – Hitachi Nuclear Energy

BFN EPU ACRS – RSD Overview

Summary

- Based on the curved hood six bank prototype replacement dryer first used in a BWR/4 reactor
- Design is significantly more robust than the original steam dryer it replaces
- BFN acoustic load definition developed using Main Steam Line (MSL) acoustic pressure measurements taken at the three BFN units
- The Flow Induced Vibration (FIV) fatigue evaluation and primary stress methodologies used for BFN RSD analysis has been reviewed in detail on BWR/6 RSD and Economic Simplified Boiling Water Reactor projects
- Analyzed for the applicable primary structural loads for normal operation and for transient and accident conditions

BFN EPU ACRS – RSD Overview

EPU RSD Experience

- Successful operating history for RSDs at EPU conditions
 - Quad Cities Units 1 and 2 RSDs
 - Dresden Units 2 and 3 RSDs
 - Vermont Yankee original dryer with modifications
 - Susquehanna Units 1 and 2 RSDs
 - Grand Gulf RSD


BFN EPU ACRS – RSD Overview

BFN RSD Design

- Changes to prototype dryer design
 - Dryer/vessel interface changes
 - Address Operating Experience lessons learned
 - Refine design details to reduce stresses

BFN EPU ACRS – RSD Overview

BFN RSD Analysis



BFN EPU ACRS – RSD Overview

BFN RSD FIV Analysis

- BFN RSD Finite Element Model (FEM)
 - Used to develop BFN-specific design improvements
 - FIV stress adjustments applied to FEM results
- BFN RSD Fatigue Analysis Results
 - BFN RSDs satisfy the NRC recommended minimum alternating stress ratio of 2.0 for all practical purposes

BFN EPU ACRS – RSD Overview

BFN RSD Primary Stress Evaluation

- RSD is a non-safety related item
 - Classified as an Internal Structure as defined in American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section III, Subsection NG, Paragraph NG-1122
- RSD is not an ASME Code component
- BFN RSD Primary Stress Results
 - RSD was evaluated for Normal, Upset, Emergency and Faulted conditions
 - Stresses for each load combination were compared to ASME Code, Section III, NG stress limits for all RSD components
 - The stresses for all structural components are below the ASME Code allowable limits at EPU operating conditions

BFN EPU ACRS – RSD Overview

BFN RSD Power Ascension Monitoring

- Power ascension monitoring process similar to previous RSD projects
 - Addressed in BFN License Conditions
- BFN Lead Unit
 - Both RSD and MSLS instrumented
 - Monitor using strain gauges, on-dryer pressure transducers, and accelerometer
 - Confirmatory structural analysis for lead unit at EPU based on on-dryer measurements
- Follow-on Units
 - MSLS instrumented
 - Confirmatory structural evaluation based on MSL measurements

BFN EPU ACRS – RSD Overview

BFN RSD Power Ascension Monitoring (continued)

- BFN License Conditions address
 - BFN Lead Unit Test Plan, including hold points for NRC review of data and evaluations
 - BFN Follow-on Units Test Plan, including hold points for NRC review of data and evaluations
 - BFN RSD Inspection Plan consistent with industry guidance

BFN EPU ACRS – Acronym List

- ASME – American Society of Mechanical Engineers
- AST – Alternative Source Term
- ATWS – Anticipated Transient Without Scram
- AVS – Acoustic Vibration Suppressors
- BFN – Browns Ferry Nuclear Plant
- BLEU – Blended Low Enriched Uranium
- BWR – Boiling Water Reactor
- CAP – Containment Accident Pressure
- CCW – Condenser Circulating Water
- CLTP – Current Licensed Thermal Power
- DBA – Design Basis Accident
- ECCS – Emergency Core Cooling System
- EHC – Electro-hydraulic Control
- EPU – Extended Power Uprate
- F – Fahrenheit
- FE – Finite Element
- FEM – Finite Element Model
- FIV – Flow Induced Vibration
- GEH – General Electric – Hitachi
- HWWV – Hardened Wetwell Vent
- LAR – License Amendment Request
- LOCA – Loss of Coolant Accident
- MSIVs – Main Steam Isolation Valves
- MSL – Main Steam Line
- MWt – Megawatts Thermal
- NPSH – Net Positive Suction Head
- NPSHa – Net Positive Suction Head Available
- $NPSH_{\text{eff}}$ – Effective Net Positive Suction Head Required
- NRC – Nuclear Regulatory Commission
- OLTP – Original Licensed Thermal Power
- PBLE – Plant Based Load Evaluation
- RHR – Residual Heat Removal
- RSD – Replacement Steam Dryer
- SLC – Standby Liquid Control
- SRV – Safety Relief Valve
- VPF – Vane Passing Frequency

BFN EPU ACRS – Questions/Comments