

Vogle PEmails

From: Kallan, Paul
Sent: Wednesday, June 28, 2017 10:50 AM
To: Vogle PEmails
Subject: Vogle Draft RAI for Vogle LAR 17-014.docx
Attachments: Vogle Draft RAI for Vogle LAR 17-014.docx

Hearing Identifier: Vogtle_COL_Docs_Public
Email Number: 118

Mail Envelope Properties (051440ece17b4b459dbee942fa8b27fc)

Subject: Vogtle Draft RAI for Vogtle LAR 17-014.docx
Sent Date: 6/28/2017 10:50:18 AM
Received Date: 6/28/2017 10:50:18 AM
From: Kallan, Paul

Created By: Paul.Kallan@nrc.gov

Recipients:
"Vogtle PEmails" <Vogtle.PEmails@nrc.gov>
Tracking Status: None

Post Office: HQPWMSMRS07.nrc.gov

Files	Size	Date & Time
MESSAGE	3	6/28/2017 10:50:18 AM
Vogtle Draft RAI for Vogtle LAR 17-014.docx		23840

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

DRAFT

Request for Additional Information (RAI) for License Amendment Request (LAR) 17-014
(Emergency Planning ITAAC Revisions)

13.3-1: Subject: Protective Response

[Basis: 10 CFR 50.47(b)(10), 10 CFR 52.97(b), 10 CFR Part 50 Appendix E,
NUREG-0800 Table 14.3.10-1, and NUREG-0654/FEMA-REP-1 Evaluation Criterion J.1]

VEGP Units 3 and 4 EP ITAAC E.3.9.07.01.02 verifies a program commitment to warn and advise onsite individuals of an emergency including those in areas controlled by the operator, including:

1. Employees not having emergency assignments,
2. Visitors,
3. Contractor and construction personnel, and
4. Other persons who may be in the public access areas, on or passing through the site, or within the owner controlled area.

The existing Inspection Tests and Analysis (ITA) criteria associated with VEGP Units 3 and 4 EP ITAAC E.3.9.07.01.02 states, "A test of the onsite warning and communication capability emergency implementing procedures (EIPs) including protective action guidelines, assembly and accountability, and site dismissal will be performed during a drill."

SNC proposed to change the ITA criteria associated with VEGP Units 3 and 4 EP ITAAC E.3.9.07.01.02 to state, "A test will be performed of the capabilities to warn and advise onsite individuals of an emergency, including those in areas controlled by the operator."

The NRC staff has reviewed SNC's Technical Evaluation for the proposed change to the ITA criteria associated with VEGP Units 3 and 4 EP ITAAC E.3.9.07.01.02 and has determined that additional information is needed. Please explain why the revised ITA criteria does not specifically include: 1) Employees not having emergency assignments, 2) Visitors, 3) Contractor and construction personnel, and 4) Other persons who may be in the public access areas, on or passing through the site, or within the owner controlled area, as part of the test so that the revised ITA criteria directly correlates to the existing program commitment and acceptance criteria for ITAAC E.3.9.07.01.02, as well as ensure consistence with the guidance in NUREG-0654/FEMA-REP-1, Evaluation Criterion J.1.