

## NuScaleDCRaisPEm Resource

---

**From:** Cranston, Gregory  
**Sent:** Wednesday, June 28, 2017 4:13 PM  
**To:** RAI@nuscalepower.com  
**Cc:** NuScaleDCRaisPEm Resource; Lee, Samuel; Chowdhury, Prosanta; Dias, Antonio; Li, Chang; Markley, Anthony  
**Subject:** Request for Additional Information No. 77, RAI 8895  
**Attachments:** Request for Additional Information No. 77 (eRAI No. 8895).pdf

Attached please find NRC staff's request for additional information concerning review of the NuScale Design Certification Application.

Please submit your response within 60 days of the date of this RAI to the NRC Document Control Desk.

If you have any questions, please contact me.

Thank you.

Gregory Cranston, Senior Project Manager  
Licensing Branch 1 (NuScale)  
Division of New Reactor Licensing  
Office of New Reactors  
U.S. Nuclear Regulatory Commission  
301-415-0546

**Hearing Identifier:** NuScale\_SMR\_DC\_RAI\_Public  
**Email Number:** 94

**Mail Envelope Properties** (f89e2841b2b748faa50ccd555da4acb4)

**Subject:** Request for Additional Information No. 77, RAI 8895  
**Sent Date:** 6/28/2017 4:13:20 PM  
**Received Date:** 6/28/2017 4:13:21 PM  
**From:** Cranston, Gregory

**Created By:** Gregory.Cranston@nrc.gov

**Recipients:**

"NuScaleDCRaisPEm Resource" <NuScaleDCRaisPEm.Resource@nrc.gov>  
Tracking Status: None  
"Lee, Samuel" <Samuel.Lee@nrc.gov>  
Tracking Status: None  
"Chowdhury, Prosanta" <Prosanta.Chowdhury@nrc.gov>  
Tracking Status: None  
"Dias, Antonio" <Antonio.Dias@nrc.gov>  
Tracking Status: None  
"Li, Chang" <Chang.Li@nrc.gov>  
Tracking Status: None  
"Markley, Anthony" <Anthony.Markley@nrc.gov>  
Tracking Status: None  
"RAI@nuscalepower.com" <RAI@nuscalepower.com>  
Tracking Status: None

**Post Office:** HQPWMSMRS08.nrc.gov

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	527	6/28/2017 4:13:21 PM
Request for Additional Information No. 77 (eRAI No. 8895).pdf		102493

**Options**

**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**

## **Request for Additional Information No. 77 (eRAI No. 8895)**

Issue Date: 06/28/2017

Application Title: NuScale Standard Design Certification - 52-048

Operating Company: NuScale Power, LLC

Docket No. 52-048

Review Section: 09.02.05 - Ultimate Heat Sink

Application Section: 9.2

### QUESTIONS

#### 09.02.05-2

10 CFR 52.47(a)(2) requires that a standard design certification applicant provide a description and analysis of the structures, systems, and components (SSCs) of the facility, with emphasis upon performance requirements, the bases, with technical justification therefor, upon which these requirements have been established, and the evaluations required to show that safety functions will be accomplished.

The staff reviewed FSAR Tier 2, Section 9.2.5, on the ultimate heat sink (UHS) design capacity for abnormal and accident conditions including the size and heat loads of the UHS to verify the adequacy of the long term UHS capacity. The heat loads identified in FSAR Table 9.2.5-2, "Ultimate Heat Sink Heat Loads: Boil off Event," as indicated in footnote 3, account for decay heat only. Table 9.2.5-2 does not indicate the inclusion of the sensible heat nor the heat loads from the stored spent fuels, which are discussed in FSAR Tier 2, Sections 9.2.5.2.3 and 9.2.5.4.

In order to better describe the UHS design capacity calculation, the applicant is requested to:

- clarify FSAR Tier 2, Table 9.2.5-2, on the heat loads used for the UHS design.
- provide in FSAR Tier 2, Section 9.2.5, "Ultimate Heat Sink," the amount of water in the UHS relating to the UHS design capacity.
- provide the thermal analysis for the UHS under the limiting case, including the methodology, and all the assumptions (e.g., the initial pool temperature, water level, etc.).

The FSAR should be modified accordingly.