



Commonwealth Edison
Dresden Nuclear Power Station
R.R. #1
Morris, Illinois 60450
Telephone 815/942-2920

January 8, 1993

CWS LTR: 93-03a

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Licensee Event Report 92-31-1 Docket No. 050237 is being submitted as required by Technical Specification 6.6, NUREG 1022, and 10 CFR 50.73(a)(2)(i)(B).

This revised report is being submitted to report exceeding the Technical Specification limit for Primary Containment Leakage, 0.6 La. Revision 0 of this report was submitted to report exceeding the administrative Primary Containment leakage limit of 85% 0.6 La, established in the 10 CFR 50, Appendix J testing exemption granted by NRR for Unit 2.

L. J. Hermer for
Charles W. Schroeder
Station Manager
Dresden Station.

CWS/slb

Enclosure

cc: A. Bert Davis, Regional Administrator, Region III
NRC Resident Inspector's Office
File/NRC
File/Numerical

120019

(g:\wpt\cws\ltr93\93-03a)

9301120277 930108
PDR ADDCK 05000237
S PDR

LEAD
11