



Commonwealth Edison
1400 Opus Place
Downers Grove, Illinois 60515

March 17, 1993

Dr. Thomas E. Murley
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attn: Document Control Desk

Subject: Dresden Nuclear Power Station Units 2 and 3
Response to Safety Evaluation Related to Relief
Request RV-02B, of the Third 10-Year Interval,
Inservice Testing (IST) Plan
NRC Docket Nos. 50-237 and 50-249

References: (a) J. Dyer letter to T. Kovach, dated December 17, 1992
(TAC Nos. M82898 and M82899).

Dr. Murley:

Section 2.2 of Reference (a) required that Relief Request RV-02B be reviewed by Commonwealth Edison (CECo) based upon the guidance provided in Section 3.2.1.3 of the associated Technical Evaluation Report (TER) to determine if RV-02B was still necessary. CECo was requested to provide a response to the NRC Staff within 90 days of receipt of Reference (a).

As a result of our review, CECo has determined that the Target Rock and Electromagnetic Relief Valves are tested in accordance with ANSI/ASME OM-1-1981. Based upon the NRC Staff guidance provided in Reference (a), Relief Request RV-02B is therefore no longer required and will be deleted in the next revision of the IST Plan. CECo will submit the next revision of the IST Plan to the NRC Staff by July 1, 1993.

PP/cah/ltr/1

9303220290 930317
PDR ADOCK 05000237
P PDR

A047 1/0


Dr. Murley

- 2 -

March 17, 1993

If there are any questions concerning this matter, please contact this office.

Sincerely,

A handwritten signature in cursive script, appearing to read "Peter L. Piet".

Peter L. Piet
Nuclear Licensing Administrator

cc: A.B. Davis, Regional Administrator - RIII
J.F. Stang, Project Manager - NRR
M.N. Leach, Senior Resident Inspector - Dresden
Office of Nuclear Facility Safety - IDNS

PP/cah/ltr/2