

Core Operating Limits Report
Dresden Station Unit 2 Cycle 14

October 1992

9304290227 930423
PDR ADOCK 05000237
P PDR

ISSUANCE OF CHANGES SUMMARY

| Affected Section | Affected Pages | Summary of Changes | Date |
|------------------|---------------------|--|-------|
| 2.2,3.2,4.2, | 2-1,2-3,3-1,3-2,4-1 | Removed all 8x8 data | 10/92 |
| 5.2 | 5-2 | Operating Limit MCPR change | 10/92 |
| 5.2 | 5-3 | Operating Limit MCPR change for Manual Flow Control | 10/92 |
| 5.2 | 5-4 | Operating Limit MCPR change for Automatic Flow Control | 10/92 |
| 3.2 | 3-2 | SLHGR data change | 10/92 |
| | | | |

TABLE OF CONTENTS

| | Page |
|--|------|
| References | iii |
| List of Figures | iv |
| List of Tables | v |
| | |
| 1.0 Control Rod Withdrawal Block Instrumentation (3/4.2.C) | 1-1 |
| 1.1 Technical Specification Reference | 1-1 |
| 1.2 Description | 1-1 |
| | |
| 2.0 Average Planar Linear Heat Generation Rate (3/4.5.I) | 2-1 |
| 2.1 Technical Specification Reference | 2-1 |
| 2.2 Description | 2-1 |
| 2.3 MAPLHGR Multipliers | 2-1 |
| | |
| 3.0 Local Steady State LHGR (3/4.5.J) | 3-1 |
| 3.1 Technical Specification Reference | 3-1 |
| 3.2 Description | 3-1 |
| | |
| 4.0 Local Transient LHGR (3/4.5.K) | 4-1 |
| 4.1 Technical Specification Reference | 4-1 |
| 4.2 Description | 4-1 |
| | |
| 5.0 Operating Limit Minimum Critical Power Ratio (3/4.5.L) | 5-1 |
| 5.1 Technical Specification Reference | 5-1 |
| 5.2 Description | 5-1 |

REFERENCES

1. Commonwealth Edison Company Docket No. 50-237, Dresden Nuclear Power Station, Unit 2, Facility Operating License DPR-19.
2. Letter, D.M. Crutchfield to All Power Reactor Licensees and Applicants, Generic Letter 88-16, Concerning the Removal of Cycle-Specific Parameter Limits from Technical Specifications.

LIST OF FIGURES

| Figure | Title/Description | Page |
|--------|---|------|
| 2.2-1 | MAPLHGR Limit vs. Bundle Average Exposure for SPC 9x9 Fuel | 2-2 |
| 3.2-1 | Steady State Linear Heat Generation Rate (SLHGR) Limit vs. Planar Exposure for SPC 9x9 Fuel | 3-2 |
| 4.2-1 | Transient Linear Heat Generation Rate (TLHGR) Limit vs. Planar Exposure for SPC 9x9 Fuel | 4-2 |
| 5.2-1 | MCPR Limit vs. Measured Scram Time to 90% Insertion - Rated Flow Conditions | 5-2 |
| 5.2-2 | Operating Limit MCPR for Manual Flow Control | 5-3 |
| 5.2-3 | Operating Limit MCPR for Automatic Flow Control | 5-4 |

LIST OF TABLES

| Table | Title/Description | Page |
|-------|---|------|
| 1.2-1 | Control Rod Withdrawal Block Instrumentation Setpoints | 1-2 |
| 2.3-1 | MAPLHGR Multipliers | 2-4 |

1.0 CONTROL ROD WITHDRAWAL BLOCK INSTRUMENTATION

1.1 Technical Specification Reference

Technical Specification 3.2.C - Control Rod Block Actuation

1.2 Description

The Rod Block Monitor Upscale Instrumentation Setpoints are determined from the relationships shown in Table 1.2-1.

TABLE 1.2-1

CONTROL ROD WITHDRAWAL BLOCK INSTRUMENTATION SETPOINTS

TRIP FUNCTION:

TRIP LEVEL SETTING:

| | |
|--|---|
| Rod Block Monitor Upscale (Flow Bias) | |
| Dual Loop Operation | Less than or equal to (0.65 W_d plus 48) * |
| Single Loop Operation | Less than or equal to (0.65 W_d plus 44) * |

* W_d - percent of drive flow required to produce a rated core flow of 98 Mlb/hr.

2.0 AVERAGE PLANAR LINEAR HEAT GENERATION RATE

2.1 Technical Specification References

Section 2.2: Technical Specification 3.5.1 - Average Planar LHGR
Section 2.3: See Table 2.3-1


2.2 Description

The Maximum Average Planar Linear Heat Generation Rates (MAPLHGR) versus Bundle Average Exposure for SPC 9x9 fuel is determined from Figure 2.2-1.

2.3 MAPLHGR Multipliers

The appropriate multiplicative factors to apply to the base MAPLHGR limits specified in Section 2.2 are shown in Table 2.3-1.

Figure 2.2-1
 MAPLHGR Limit vs. Bundle Average Exposure
 SPC 9x9 Fuel



| Bundle Average Exposure, GWD/MTU | MAPLHGR Limit, kW/ft |
|----------------------------------|----------------------|
| 0 | 11.40 |
| 5 | 11.75 |
| 10 | 11.40 |
| 15 | 10.55 |
| 20 | 9.70 |
| 25 | 8.85 |
| 30 | 8.00 |
| 35 | 7.15 |
| 40 | 6.30 |

Table 2.3-1
MAPLHGR Multipliers

| Specification | Title of TS | Scenario | Multiplicative Factors, SPC 9x9 |
|----------------------|---|---------------------------------------|------------------------------------|
| 3.5.D.2 | Automatic Pressure Relief Subsystems | One Relief Valve Out Of Service (OOS) | 0.76 |
| 3.5.I & 3.6.H.3.f | Average Planar LHGR Recirculation Pump Flow Limitations | Single Loop Operation (SLO) | 0.91 |
| 3.5.I & 3.6.H.3.f | Average Planar LHGR Recirculation Pump Flow Limitations | One Relief Valve OOS & SLO | 0.76 |

3.0 LOCAL STEADY STATE LHGR


3.1 Technical Specification Reference

Technical Specification 3.5.J - Local Steady State LHGR

3.2 Description

The Local Steady State LHGR (SLHGR) limit versus Average Planar Exposure for SPC 9x9 fuel is determined from Figure 3.2-1.

Figure 3.2-1
 Steady State LHGR (SLHGR) vs.
 Planar Exposure for SPC 9x9 Fuel



| Exposure (GWD/MTU) | LHGR (kW/ft) |
|--------------------|--------------|
| 0 | 14.5 |
| 5.0 | 14.5 |
| 25.2 | 10.8 |
| 48.0 | 7.2 |

4.0 LOCAL TRANSIENT LHGR


4.1 Technical Specification Reference

Technical Specification 3.5.K - Local Transient LHGR

4.2 Description

The Local Transient LHGR (TLHGR) limit versus Average Planar Exposure for SPC 9x9 fuel is determined from Figure 4.2-1.

Figure 4.2-1
 Transient LHGR (TLHGR) vs.
 Planar Exposure for SPC 9x9 Fuel



| Exposure (GWD/MTU) | LHGR (kW/ft) |
|--------------------|--------------|
| 0.0 | 19.2 |
| 25.4 | 16.9 |
| 43.2 | 10.8 |
| 48.0 | 10.0 |

5.0 OPERATING LIMIT MINIMUM CRITICAL POWER RATIO


5.1 Technical Specification References

Technical Specification 3.5.L - Minimum Critical Power Ratio (MCPR)

5.2 Description

- a. The Operating Limit MCPR at rated output versus measured scram time is shown in Figure 5.2-1. The Operating Limit MCPR is 1.43 or greater whenever the measured 90% insertion time is 3.50 seconds or less.
- b. During Manual Flow Control, the Operating Limit MCPR at reduced core flow conditions can be determined from:
 - i. Figure 5.2-2 using the appropriate flow rate, or
 - ii. The Operating Limit MCPR determined from Figure 5.2-1, whichever is greater.
- c. During Automatic Flow Control, the Operating Limit MCPR at reduced flow rates can be determined from Figure 5.2-3 using the appropriate flow rate and the Operating Limit MCPR, which is obtained from Figure 5.2-1. Linear interpolation between the curves on Figure 5.2-3 is permissible.

Figure 5.2-1
MCPR Limit vs. Measured Scram Time
to 90% Insertion




The above graph demonstrates the following dependence of the Operating Limit MCPR versus measured scram time to 90% insertion for all resident fuel types:

$$\text{MCPR LCO} = 1.43$$


Note that the Operating Limit MCPR is not a function of scram time assuming the Technical Specification scram time limit of 3.50 seconds to 90% insertion (3.3.C) is met.

Figure 5.2-2
 Operating Limit MCPR
 For Manual Flow Control



| Total Core Flow (% Rated) | Operating Limit MCPR |
|---------------------------|----------------------|
| 100 | 1.16 |
| 90 | 1.24 |
| 80 | 1.32 |
| 70 | 1.40 |
| 60 | 1.48 |
| 50 | 1.56 |
| 40 | 1.65 |

Figure 5.2-3
 Operating Limit MCPR
 For Automatic Flow Control



| Recirculating Flow (% Rated) | MCPR Limit | | |
|---------------------------------|------------|------|------|
| | 1.39 | 1.43 | 1.47 |
| 100 | 1.39 | 1.43 | 1.47 |
| 90 | 1.46 | 1.50 | 1.54 |
| 80 | 1.52 | 1.56 | 1.61 |
| 70 | 1.59 | 1.63 | 1.68 |
| 60 | 1.65 | 1.70 | 1.75 |
| 50 | 1.69 | 1.74 | 1.80 |
| 40 | 1.79 | 1.84 | 1.90 |