



Commonwealth Edison
Dresden Nuclear Power Station
R.R. #1
Morris, Illinois 60450
Telephone 815/942-2920

April 27, 1993

CWS PMLTR 93-0167

U. S. Nuclear Regulatory Commission
Document Control Clerk
Washington, D.C. 20555

Licensee Event Report 92-15-02, Docket 050249. This revised report is being submitted to change the expected supplemental LER due date because the test on LPCI Loop II System has not been completed.

Att. Schroeder for 4.28.93

Charles W. Schroeder
Station Manager
Dresden Station

CWS/slb

enclosure

cc: A. Bert Davis, Regional Administrator, Region III
NRC Resident Inspector's Office
File/NRC
File/Numerical

(p:\plntmgr\cws93\0167.93)

030050

9305040016 930427
PDR ADDCK 05000249
S PDR

IF22
11

SUPPLEMENTAL REPORT TO DIR/LER

DVR NO.				SYSTEM AFFECTED	
STA	UNIT	YEAR	NO.		
D - 12	- 3	- 92	- 015	1500	
<u>PART 1</u>	TITLE OF EVENT			<u>OCCURRED</u>	
	LPCI Minimum Flow Valve M03- 1501-13A Auto Closure During Valve Operability Test Due to Unknown Cause			6/14/92	1915
				DATE	TIME
REASON FOR SUPPLEMENTAL REPORT					
A supplemental report will be issued upon completion of LPCI Loop II system test due to incomplete test.					
<u>PART 2</u>					
ACCEPTANCE BY STATION REVIEW				<i>[Signature]</i>	
DATE				4-25-93	4/25/93
SUPPLEMENTAL REPORT APPROVED AND AUTHORIZED FOR DISTRIBUTION				<i>[Signature]</i>	4-26-93
				STATION MANAGER	DATE