

NOTICE OF VIOLATION

Commonwealth Edison Company  
Dresden Station, Units 2 and 3

Dockets No. 50-237; 50-249  
License Nos. DPR-19; DPR-25

During an NRC inspection conducted from July 12 - 29, 1993, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violation is listed below:

Technical Specification 6.11.1 requires that procedures for personnel radiation protection be approved, maintained, and adhered to for all operations involving personnel radiation exposure.

Procedure DRP 1160-03, Revision 5, "RADIOLOGICAL SIGNS, LABELS, SIGNALS, AND CONTROLS," states that radioactive material tags and labels shall contain the maximum measured contact dose rate on the item or container.

Contrary to the above, on July 19, 1993, radioactive material labels on numerous bags in Bay 7 of the radwaste building barrelling area did not contain the maximum measured contact dose rate.

This is a Severity Level IV violation (Supplement IV).

Pursuant to the provisions of 10 CFR 2.201, Commonwealth Edison Company is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington D.C. 20555 with a copy to the U. S. Nuclear Regulatory Commission, Region III, 799 Roosevelt Road, Glen Ellyn, Illinois, 60137, and a copy to the NRC Resident Inspector at the Dresden Nuclear Generating Station within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order or a Demand For Information may be issued as to why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Glen Ellyn, Illinois  
this 18 day of August 1993

*Charles E. Norelius*  
\_\_\_\_\_  
Charles E. Norelius, Director  
Division of Radiation Safety  
and Safeguards