SUMMARY OF MEETING ON INDIVIDUAL PLANT EXAMS FOR EXTERNAL EVENTS

CEC

DRESDEN 2

G.

50-237

REC'D W/LTR DTD 09/23/93...9310010137

-NOTICE-

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE INFORMATION & REPORTS MANAGEMENT BRANCH. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RE-CORDS & ARCHIVES SERVICES SEC-TION P1-22 WHITE FLINT. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE RE-FERRED TO FILE PERSONNEL.

-NOTICE-

ENCLOSURE 1

LIST OF ATTENDEES

SEPTEMBER 14, 1993, MEETING ON

INDIVIDUAL PLANT EXAMINATIONS FOR EXTERNAL EVENTS

NAME

AFFILIATION

Byron Siegel L. B. Marsh David Jeng Robert Rothman Goutam Bagchi Phyllis Sobel Yong Kim John Chen Charles Ader John Flack Edward Rodrick Nilesh Chokshi Roger Kenneally Carlos Diaz Stephen Stimac S. Kong Wang G. T. Klopp T. Lechton Farid Zikria Nayeem Farukhi George Wrobel

NRR/PDIII-2 NRR/CBLA NRR/DE/ECGB NRR/DE/ECGB NRR/DE/ECGB NRR/DE/ECGB NRR/DE/ECGB **RES/SAIB RES/SAIB RES/SAIB** RES/SAIB RES/SSEB **RES/SSEB** CECo/NETS CECo/NETS CECo/NETS CECO/NETS CECo/NETS NUS NUMARC Rochester Gas & Electric

COMMONWEALTH EDISON'S APPROACH TO IPEEE



T. Lechton G. Klopp K. Wang C. Diaz

September 14, 1993

OVERVIEW

- O HISTORY
 - O TEAM STRUCTURE

o AGENDA

O PURPOSE

•

<u>HISTORY</u>

6/28/91 Generic Letter 88-20 Supplement 4 issued.

12/24/91 CECo submits response to GL-88-20 Sup.4. Agrees to walkdowns and careful screening analysis. Considers integration with SQUG effort.

7/27/92 NRC acknowledges CECo's proposal of use of alternate method. Additional information sought.



9/18/92

CECo provides details on approach utilizing IPEs, expert walkdowns and focused scope PRAs.

10/15/92 Presentation made by CECo to NRC on use of , screening approach.

12/14/92

NRC requested additional information on program to obtain better understanding of methodology and schedule. SQUG/IPEE Project Team



* The LaSalle IPEEE was performed by Sandia Labs

SQUG/IPEEE PROJECT TEAM

Terri Lechton - BS Mechanical Engineering/MBA

13 Years industry experience in plant testing, operations, and engineering. Certified SRO.

George Klopp - BS/MS Mechanical Engineering

28 Years experience in areas of engineering, plant testing, operations, and PRA. 14 Years experience in PRA. Experience at all 6 CECo nuclear stations. Participated extensively in IDCDR program and NUMARC Accident Management activities. Author of a number of publications on PRA. Listed as IAES expert on PRA.

S. Kong Wang - BS/MS/PhD Nuclear Engineering

8 Years industry experience. Assessed safety-related systems and containment integrity as A/E. Performed analytical studies in LWR severe accidents for a national laboratory.

Carlos Diaz - BS Fire Protection Engineering

9 Years fire protection experience. Performed fire protection studies for 2 national laboratories.

Neil Smith - BS Electrical Engineering/MBA

Registered Professional Engineer. Chairman of SQUG for 11 years. Served on the EPRI Seismic Center Committee, NUMARC Seismic Issue Working Group, and EPRI seismicity Owners Group.

Bruce Lory - BS Mechanical Engineering

14 Years experience in seismic and environmental qualification. Technical Chairman for SQURTS.

Paul Donavan - BS Mechanical Engineering

17 Years industry experience specializing in piping analysis for snubber reduction and pipe transient analysis. Serves on several codes & standards committee for piping.

Jim Wethington - BS Mechanical Engineering 11 Years industry experience, Licensed SRO, Station Mechanical Lead.

Doug Beutel - BS Mechanical Engineering Registered Professional Engineer. 13 Years industry experience in seismic analysis (11 as A/E).

Don Robinson - BS Electrical Engineering 21 Years industry experience. IPE Program Engineer for Byron Station.

Dan Christiana - BS Mechanical Engineering 15 Years industry experience in engineering, construction, and startup.

Leslie Wright - BS Chemical Engineering 11 Years industry experience in engineering.

MEETING AGENDA COMMONWEALTH EDISON'S APPROACH TO IPEEE TUESDAY, SEPTEMBER 14, 1993

- Overview of Previous Commitments/ T. Lechton Meetings, and Team Approach Being Used at CECo. (15 mins.)
- 2. Introduction to the IPEEE Matrix G. Klopp Approach for Screening and Evaluation , (30 mins.)

•

- 3. Application of the Approach to Seismic K. Wang Examples (30 mins.)
- 4. Application of the Approach to Fire C. Diaz Examples (30 mins.)
- 5. Overview of Completion Schedule T. Lechton (15 mins.)
- 6. Discussion and Questions All (60 mins.)

PURPOSE

- * Describe the IPE structure & features.
- * Describe the derivation of the matrix model.
- * Describe general approach to the use of the matrix model for IPEEE.
- Describe the multi-stage screening and evaluation process for the seismic and fire events.
- * Show, by example, how the matrix model can be applied to seismic and fire applications.
- * Describe planned dates for IPEEE and SQUG walkdowns.
- * Obtain feedback on the matrix model approach.
- * Obtain NRC confidence in the usage of the matrix model approach as an alternate means of addressing IPEEE.

COMMONWEALTH EDISON IPEEE PROGRAM

IPE BASED MATRIX FORMULATION FOR IPEEE

GEORGE KLOPP SENIOR TECHNICAL EXPERT PRA

EDISON IPE FEATURES

١

1. SUPPORT STATE MODEL

- A. SUPPORT STATE EVENT TREE
- **B. SUPPORT SYSTEM FAULT TREES**
- C. EXPLICIT SUPPORT SYSTEM DEPENDENCY , ON THE INITIATING EVENT
- D. DUAL UNIT REPRESENTATION
- E. FULL SUPPORT SYSTEM INTER-DEPENDENCY MODEL

- 2. LARGE PLANT RESPONSE TREE MODEL (EVENT TREE MODEL)
 - A. FRONT LINE SYSTEMS
 - **B. EOP MANDATED OPERATOR ACTIONS**
 - C. REALISTIC SUCCESS CRITERIA
 - D. INTEGRATED CONTAINMENT AND CONTAINMENT SYSTEMS RESPONSE MODELLING
- 3. EXTENSIVE USE OF MAAP CODE (HUNDREDS OF RUNS) TO ENVELOP THE REALISTIC PLANT BEHAVIOR

;

- 4. IPE REPRESENTS A HUGE BODY OF KNOWLEDGE ON PLANT SEVERE ACCIDENT BEHAVIOR
- 5. PLANT RESPONSE TO ALMOST ALL EXTERNALLY INITIATED EVENTS WILL BE AVAILABLE IN THE IPE ITSELF

EDISON IPE STRUCTURE

- 1. INITIATING EVENT LIST
- 2. SUPPORT STATE EVENT TREES
- 3. PLANT RESPONSE TREES
- 4. SUPPORT SYSTEM FAULT TREES
- 5. FRONT LINE SYSTEM FAULT TREES
- 6. HRA FOR TOP EVENT EOP RESPONSES

IPE TYPICAL

. ,

.

INITIATING EVENT LIST

Event	Frequency
1. LARGE LOCA	3E-4/YR
2. MEDIUM LOCA	8E-4/YR
3. SMALL LOCA	3E-3/YR
•	•
•	•
•	•
•	•
•	•

10. LOSS OF DC POWER 8.7E-4/YR

SUPPORT STATE EVENT TREES

1. Number of Trees - function of initiating event groupings.

(Example: LOCA's tend to use same tree)

4

- 2. Top events or nodes are success/fail for support systems such as:
 - AC power Bus XXX
 - DC power Bus <u>YYY</u>
 - Diesel Generator <u>WWW</u>
 - Service Water Supply
 - Closed Cooling Water Supply
- 3. Typical Tree up to 20 nodes
- 4. Output: Each Event Tree Branch is a Unique Support State
- 5. Quantify a Support State Event Tree for each initiating event



PLANT RESPONSE TREES (PRT)

- 1. One plant response Tree for each initiating event.
- 2. Top events, or nodes, are success/fail for Front Line Systems & EOD Mandated Operator Actions such as:
 - High Pressure Injection Functions
 - Auxiliary Feedwater Functions
 - Operator Acts to De-Pressurize RCS
 - Steam Generator PORV Functions
 - Containment Fan Coolers Function
- 3. Typical PRT has up to 30 Top Events or Nodes
- 4. Quantify PRT for <u>Each</u> Support State.
- 5. Output: Each Branch Point is a Plant State. Many duplications.

Each Branch Point is the culmination of a unique accident sequence.



^ln

Numl (1)	ber Frequency (2)	(3)	Damage Sta (4)	te Event (5) Value (6)	Description (7)
1	8.18E-06	44.15%	DLCOM	SPC	8.70E-04	LOSS OF DC POWER IE SPC FAILS: 24, 29, 281 AVAILABLE
2	1.67E-06	9.02%	DLCOM	LDC	8.70E-04 2.10E-03	LOSS OF DC POWER IE OPTR FAILS TO ALIGN FOR SPC
3	5.05E-07	2.73%	MLCOM	MLOCA	8.00E-04	MLOCA IE OPTRE FAILS TO ALIGN FOR SPC
4	4.28E-07	2.31%	LLCOM	LOOP	9.60E-02	
				24 OMUP	7.80E-03	LOSS OF BUS 24/24-1 AVALABLE, 24HR
				ROP1	1.00E+00	
	12 895 07		MEARM	SPC	1.00E+00	
ľ	0.032-07	2.10%		OAD HP2	9.80E-03 5.18E-02	OPTR FALS TO INITIATE ADS HP FAILS: ALL SUPPORTS AVAILABLE MANUAL START
6	3.74E-07	2.02%	LLCOM	LOOP	9.60E-02 9.50E-02	LOSS OF OFFSITE POWER IE LOSS OF DG2/3, 6 HRS
	1			24 MUP	7.80E-03	LOSS OF BUS 24/24-1 AVAILABLE, 24HR
		1		ROP1	1.00E+00	EVENT FAILURE
	_			SPC	1.00E+00 1.00E+00	EVENT FAILURE
7	3.71E-07	2.00%	BLABM	DLOOP	1.60E-02 9.50E-02	LOSS OF OFFSITE POWER IE LOSS OF DG2/3, 6 HRS
ļ				DG2	1.56E-01	LOSS OF DG2 AFTER DG2/3, 6 HRS
			}	SBO?	1.00E+00	SBO IN UNIT 3, SBO IN UNIT 2
		1		OIC2	2.05E-02 1.00E+00	OPTR FAILS TO PREVENT LODO FLR OF IC
8	3.03E-07	1.63%	LLCOM	LOOP	9.60E-02	LOSS OF OFFSITE POWER IE
				OMUP	7.90E-03	OPTR FAILS TO PROVIDE MU TO IC
	1			LP	1.00E+00	LP B SUCCEEDS [1-(2L)-LL2-)]
	2 42 E-07	1.30%			5.49E-03	SPC FAILS; 24, 28, 29, 2R1 AVALABLE
-		1.20%		HP1	2.88E-02	HP FALLS; 2M1 FLD
10	2.23E-07	1.20%	MEABM	MLOCA	8.00E-04	MLOCA IE
				HP1 OAD	2.88E-02 9.80E-03	HP FAILS; ALL SUPPORTS AVAILABLE OPTR FAILS TO INITIATE ADS
11	2.07E-07	1.12%	MLCOM	MLOCA SPC	8.00E-04 2.71E-04	MLOCA IE SPC FAILS: ALL SUPPORTS AVAILABLE
12	1.97E-07	1.06%	DLCOM		8.70E-04	LOSS OF DC POWER IE SPC FAILS: 24, 29, 2P1 AVAILABLE
	1	1	1	SVW	2.43E-02	SMALL TORUS VENT FAILS: 29, 39 AVAILABLE
13	1.86E-07	1.00%	LIABM	LOOP	9.60E-02	LOSS OF OFFSITE POWER IE
				OMUP HP1	7.90E-03 2.88E-02	OPTR FAILS TO PROVIDE MU TO IC INP FAILS: ALL SUPPORTS AVAILABLE
	1			OAD BOP1	1.20E-02	OPTR FAILS TO INITIATE ADS
14	1.77E-07	0.96%	BLAYN	DLOOP	1.60E-02	LOSS OF OFFSITE POWER IE
	1	1		DG8 DG2	9.50E-02 1.56E-01	LOSS OF DG2/3, 6 HRS LOSS OF DG2 AFTER DG2/3, 6 HRS
	j	ĺ	1	DG3 SBO2	1.19E-01	LOSS OF DG3 AFTER DG2/3 AND DG2, 6 HRS SRO IN UNIT 3, SBO IN UNIT 2
			1	ROP1	2.05E-02	FAILURE TO REC OSP TO PREVENT CM (46 HRS)
				ROP2	3.22E-01	FALURE TO REC OSP TO PREVENT CF (NR IN 0-5 HRS)
15	1.61E-07	0.87%	BLABM	LOOP G	0.60E-02	LOSS OF OFFSITE POWER IE LOSS OF DG2/3, 6 HRS
				DG2	.56E-01	LOSS OF DOZ AFTER DOZ/3, 6 HRS
				SBO? 1	.00E+00	SEO OCCURS IN UNIT 2
				0102 1	.00E+02	OPTR FALLS TO PREVENT LODC FLR OF IC
16	1.59E-07	0.85%	DIBON		.00E+00	LP A SUGGEEDS (1-(ZLI-LL1-)) LOSS OF DC POWER IE
-				241 1 I P 1	99E-04	LOSS OF BUS 24-1, GIVEN BUS 24 AVALABLE
				cs i	.00E+00	EVENT FAILURE
	1.46E-07	0.79%	LLCOM	LOOP 9 OMUP 7	.60E-02 90E-03	LOSS OF OFFSITE POWER IE OPTR FAILS TO PROVIDE MU TO IC
1		1		ROP1 1. SPC 2.	00E+00	EVENT FAILURE SPC FAILS: ALL SUPPORTS AVAILABLE
			<u> </u>			

Number (1)	Frequency (2)	Percent (3)	Damage State (4)	Event (5)	Value (6)	Description (7)
98	1.21E-08	0.07%	LLCOM	DLOOP OMUP ROP1 OSPC	1.60E-02 7.90E-03 1.00E+00 1.60E-04	LOSS OF OFFSITE POWER IE OPTR FAILS TO PROVIDE MU TO IC EVENT FAILURE OPTR FAILS TO ALIGN FOR SPC
99	1.16E-08	0.06%	BIABM	LOOP DGB DG2 241 SBO? OIC RVC LP	9.60E-02 9.50E-02 1.56E-01 8.78E-03 1.00E+00 3.70E-02 2.70E-02 1.00E+00	LOSS OF OFFSITE POWER IE LOSS OF DG2/3, 6 HRS LOSS OF DG2 AFTER DG2/3, 6 HRS LOSS OF BUS 24-1, GIVEN 34-1 CROSSTIE AVAILABLE SBO OCCURS IN UNIT 2 OPTR FAILS TO INITIATE IC (SBO, LOOP RVC FAILS TO INITIATE IC (SBO, LOOP RVC FAILS; RELIEF VALVES CLOSING (TRANS) LP A SUCCEEDS [1-(2LI-LL1-)]
100	1.16E-08	0.06%	TEERF	ATWS MC RCFM RPT1 WW/DW	2.28E-04 1.37E-01 3.33E-01 6.00E-03 2.16E-01	ATWS INITIATOR MAIN COND FAILS (GIVEN FW FAILS) AFTER ATWS FRAC OF RPS FAILURES THAT ARE MECHANICAL AUTO RPT FAILS; ALL SUPPORTS AVAILABLE FRAC OF CONT FLRS IN DW (VS. WW)

Notes:

1.

- 1. "Number" refers to accident sequence ranking in the top 100 sequences.
- 2. "Frequency" is the frequency per year that this sequence is expected to occur.
- 3. "Percent" is the percent of total core damage represented by this single sequence.
- 4. "Damage St" is the plant damage state to which this sequence belongs. The fifth character presents the release associated with this type of sequence and is manually assigned at the end of the analysis in presentations of dominant sequences.
- 5. "Event" is the list of PRT and support system event tree top events which have failed in this sequence.
- 6. "Value" is frequency (for initiators) or probability (for failures) associated with each event.
- 7. "Description" defines the "Event" label.

FAULT TREES & HRA

- 1. Fault trees combine <u>component failures</u> in specific systems to fail system.
- Fault tree output is frequency of system failure (failure to meet success criteria)
- 3. HRA, human reliability analysis, evaluates <u>operator performance</u>, task by task, in performing EOP mandated activities.
- 4. HRA output is frequency of failure to perform task correctly (eg failure of function/system due to operator error).

DERIVATION OF MATRIX MODEL OF IPE

- 1. The matrix methodology was developed as a tool for living PRA
- 2. Derivation starts with "Dominant Accident Sequence Report"
- 3. Involves Top 100 Sequences
- 4. Uses Standard, Readily Available, Matrix Mathematic & Personal Computer Tools





Numbi (1)	r Frequency (2)	Percent (3)	Damage State (4)	Event (5)	Value (6)	Description (7)
1	8.18E-06	44.15%	DLCOM	LDC SPC	8.70E-04	LOSS OF DC POWER IE ISPC FAILS: 24, 29, 281 AVAILABLE
2	1.67E-06	9.02%	DLCOM	LDC	8.70E-04 2.10E-03	LOSS OF DC POWER IE OPTR FAILS TO ALIGN FOR SPC
3	5.05E-07	2.73%	MLCOM	MLOCA	8.00E-04	MLOCA IE OPTE FAILS TO ALIEN FOR SPC
+	4.28E-07	2.31%	LLCOM .	LOOP DGB 24 OMUP ROP1 LP SPC	9.60E-02 9.50E-02 7.80E-03 7.90E-03 1.00E+00 1.00E+00 1.00E+00	LOSS OF OFFSITE POWER IE LOSS OF DG23, 6 HRS LOSS OF BUS 24/24-1 AVAILABLE, 24HR OPTR FAILS TO PROVIDE M/U TO IC EVENT FAILURE LP B SUCCEEDS [1-(2LI-LL2-)] EVENT FAILURE
5	3.89E-07	2.10%	MEABM	MLOCA OAD HP2	8.00E-04 9.80E-03 5.18E-02	MLOCA IE OPTR FAILS TO INITIATE ADS IMP FAILS: ALL SUPPORTS AVAILABLE MANUAL START
6	3.74E-07	2.02%	ШСОМ	LOOP DGB 24 MUP ROP1 LP SPC	9.60E-02 9.50E-02 7.80E-03 6.97E-03 1.00E+00 1.00E+00	LOSS OF OFFSITE POWER IE LOSS OF DG2/3, 6 HRS LOSS OF BUS 24/24-1 AVAILABLE, 24HR MUP FAILS; 25 FLD EVENT FAILURE LP B SUCCEEDS [1-(2L)-LL2-)] EVENT FAILURE
7	3.71E-07	2.00%	BLABM	DLOOP DGB DG2 DG3 SBO? ROP1 OIC2	1.60E-02 9.50E-02 1.56E-01 1.19E-01 1.00E+00 2.05E-02 1.00E+00	LOSS OF OFFSITE POWER IE LOSS OF DG2/3, 6 HRS LOSS OF DG2 AFTER DG2/3, 6 HRS LOSS OF DG3 AFTER DG2/3 AND DG2, 6 HRS SBO IN UNIT 3, SBO IN UNIT 2 FAILURE TO REC OSP TO PREVENT CM (4-6 HRS) OPTR FAILS TO PREVENT LODC FLR OF IC
8	3.03E-07	1.63%		LOOP DGB OMUP ROP1 LP SPC	9.60E-02 9.50E-02 7.90E-03 1.00E+00 1.00E+00 5.49E-03	LOSS OF OFFSITE POWER IE LOSS OF DG2/3, 6 HRS OPTR FAILS TO PROVIDE MU TO IC EVENT FAILURE LP B SUCCEEDS (1-(2L)-LL2-)) SPC FAILS; 24, 28, 29, 2R1 AVAILABLE
9	2.42E-07	1.30%	DLCOM	LDC HP1 SPC	8.70E-04 2.88E-02 1.03E-02	LOSS OF DC POWER IE HP FAILS; 2M1 FLD SPC FAILS; 24, 29, 2R1 AVAILABLE
10	2.23E-07	1.20%	MEABM	MLOCA HP1 OAD	8.00E-04 2.88E-02 9.80E-03	MLOCA IE HP FAILS; ALL SUPPORTS AVAILABLE OPTR FAILS TO INITIATE ADS
11	2.07E-07	1.12%	MLCOM	MLOCA SPC	8.00E-04 2.71E-04	MLOCA IE SPC FAILS: ALL SUPPORTS AVAILABLE
12	1.97E-07	1.06%	DLCOM	LDC SPC SVW SVD	8.70E-04 1.03E-02 2.43E-02 9.70E-01	LOSS OF DC POWER IE SPC FAILS: 24, 29, 2R1 AVAILABLE SMALL TORUS VENT FAILS: 29, 39 AVAILABLE SMALL DRYWELL VENT FAILS: 29, 39 AVAILABLE
13	1.86E-07	1.00%	LIABM	LOOP OMUP HP1 OAD ROP1	9.60E-02 7.90E-03 2.88E-02 1.20E-02 1.00E+00	LOSS OF OFFSITE POWER IE OPTR FAILS TO PROVIDE MU TO IC HP FAILS: ALL SUPPORTS AVAILABLE OPTR FAILS TO INITIATE ADS EVENT FAILURE
14	1.77E-07	0.96%	BLAYN	DLOOP DGB DG2 DG3 SBO? ROP1 OIC2 ROP2	1.60E-02 9.50E-02 1.56E-01 1.19E-01 1.00E+00 2.05E-02 1.00E+00 3.22E-01	LOSS OF OFFSITE POWER IE LOSS OF DG2/3, 6 HRS LOSS OF DG2 AFTER DG2/3, 6 HRS LOSS OF DG3 AFTER DG2/3 AND DG2, 6 HRS SBO IN UNIT 3, SBO IN UNIT 2 FAILURE TO REC OSP TO PREVENT CM (4-6 HRS) OPTR FAILS TO PREVENT LODC FLR OF IC FAILURE TO REC OSP TO PREVENT CF (NR IN 0-6 HRS)
15	1.61E-07	0.87%	ELABM	LOOP DGB DG2 241 SBO? ROP1 DIC2 P	9.60E-02 9.50E-02 1.56E-01 8.78E-03 1.00E+00 2.05E-02 1.00E+00 1.00E+00	LOSS OF OFFSITE POWER TE LOSS OF DG2/3, 6 HRS LOSS OF DG2 AFTER DG2/3, 6 HRS LOSS OF BUS 24-1, GIVEN 34-1 CROSSTIE AVAILABLE SBO OCCURS IN UNIT 2 FAILURE TO REC OSP TO PREVENT CM (4-6 HRS) OPTR FAILS TO PREVENT LODC FLR OF IC LP A SUCCEEDS [1-(2L1-LL1-)]
6	1.59E-07	0.86%		DC 8 241 1 P 1 CS 1	3.70E-04 1.99E-04 1.00E+00 1.00E+00	LOSS OF DC POWER IE LOSS OF BUS 24-1, GIVEN BUS 24 AVAILABLE EVENT FAILURE EVENT FAILURE
,	1.46E-07	0.79%		00P 9 0MUP 7 10P1 1 3PC 2	0.60E-02 7.90E-03 1.00E+00 2.71E-04	LOSS OF OFFSITE POWER IE OPTR FAILS TO PROVIDE M/U TO IC EVENT FAILURE SPC FAILS: ALL SUPPORTS AVAILABLE

,

Numbe (1)	r (Frequency (2)	Percent (3)	Damage State (4)	Event (5)	Value (6)	Description (7)
			·•••			
				•.		
						·.
-						
8	1	1.63%			9 60 F-02	
				DGB OMUP ROP1	9.50E-02 7.90E-03 1.00E+00	LOSS OF DG2/3, 6 HRS OPTR FAILS TO PROVIDE MU TO IC EVENT FAILURE
ç	A 105			LP SPC	1.00E+00 5.49E-03	LP B SUCCEEDS [1-(2L)-LL2-)] SPC FAILS: 24. 28. 29. 2R1 AVAILABLE
•						
i						-
i						-

	Numb (1)	er Frequency (2)	Percent (3)	Damage State (4)	Event (5)	Velue (6)	Description (7)
						_	
	,						
ł							
ł				•			,
		1		 			
		3.032-07	1.037.				
5							
ŀ							
							4
h							
Ļ							
ī							
1							
īi							
							1

Number (1)	Frequency (2)	Percent (3)	Damage State (4)	Event (5)	Value (6)	Description (7)
			·•• ···			
			·	••.		
						· · · · · · · · · · · · · · · · · · ·
						· · · · · · · · · · · · · · · · · · ·
	3.03E-07	1.63%	LLCOM		ı	
					.50E-02	LOSS OF DC2/3. 6 HRS
;,	60P 4-		·	/	-	
			L	- TDFN	TTTN	
				AND	DEVELO	PING SUPPORT STATE LABELS
				FOR	THE SU	PPORT STATE MATRIX
				(I.E WITH	. Loop A Con	; SUPPORT STATE # 4; D. FREQUENCY OF 9.5E-2)
				-	-	

TABLE 4.5.3-1 DOMINANT ACCIDENT SEQUENCES FOR BASE IPE MODEL QUANTIFICATION Number Frequency (1) (2) Damage State Event (5) Value (6) Percent Description (7) (4) (3) 5 13.03E-07 LLCOM 1.63% OMUP ROP1 LP OPTR FAILS TO PROVIDE MU TO IC 7.90E-03 1.00E+00 LP 8 SUCCEEDS (1-(2LJ-LL2-)) SPC FAILS; 24, 28, 29, 2R1 AVALABLE 1.00E+00 SPC 5.49E-03 IDENTIFYING FAILED FRONT-LINE SYSTEMS AND OPERATOR ACTIONS FOR THE PLANT STATE MATRIX SINGLE SEQUENCE INPUT (I.E. LOOP; SS # 4; PS LLCOM WITH A COND. FREQUENCY OF 4.34E-5)

- --

....

NEXT:

- 1. Repeat sequence breakdown for all 100 sequences.
- 2. Enter initiating event list (same as in base IPE document) as scalar values
- 3. <u>For each initiator</u>: Develop a support state list & table of <u>conditional</u>
 frequencies. Enter as a row vector.
- 4. For each initiator: Develop a list of sequences for each support state & plant state noted above & establish a conditional frequency of sequences (e.g. product of front line system failures & operator actions) Sum sequence conditional frequencies by support states & plant states & enter in matrix.

DEVELOPING THE SUPPORT STATE VECTOR

.

1,

INITIATING EVENT: <u>LOOP</u> SS1 . . 4 . . . 19 S7 = [. . . 9.5E-2 . . .]

· •

DEVELOPING THE PLANT STATE MATRIX

INITIATING EVENT: LOOP



VALUE IS THE SUM OF THE PRODUCTS OF CONDITIONAL FREQUENCIES OF FAILED FRONT LINE SYSTEMS AND OPERATOR ACTIONS FOR LOOP INITIATED SEQUENCES IN SUPPORT STATE 4 FROM THE TOP 100 SEQUENCES FOR PLANT STATE LLCOM

RESULTS:

٠

DRESDEN MATRICE

44

AS AN

EXAMPLE

DRESDEN STATION IPE: MATRIX FORMULATION 5/21/93; G. T. KLOPP

This matrix formulation follows the same approach used for the Zion Station IPE formulation. Since Dresden's IPE did not employ "support states" per-se, the top 100 sequences have been carefully reviewed for support state occurrence. It was found that 20 such states exist with no "impact vector" evaluations at all. Therefore, the 20 states are used as the foundation for the "S" matrices in this work. The 20 states are defined in attachment 1 to this work.

INITIATING EVENT SCALARS:

II := 3-10 ⁻⁴	FOR LLOCA	I6 = 7.4	FOR GTR
I2 := 8·10 ⁻⁴	FOR MLOCA	I7 = 9.6 10 ⁻²	FOR LOOP
I3 = 3 10 ⁻³	FOR SLOCA	I8 := 1.6·10 ⁻²	FOR DLOOP
I4 = 1.1.10 ⁻⁷	FOR ISLOCA	I9 := 2.28·10 ⁻⁴	FOR ATWS
$15 = 7.1 \cdot 10^{-2}$	FORIORV	II0 := 8.7·10 ⁻⁴	FOR LODC

SUPPORT STATE ROW MATRICES (VECTORS):

S1 = .9998	FOR LLOCA
S2 := .9998	FOR MLOCA
S3 = 0	FOR SLOCA
S4 :=0	FOR ISLOCA
S5 =.9998	FOR IORV

SS 1 13

 $S6 = (.9998 \ 2.4 \cdot 10^{-6})$ FOR GTR

SS 1 3 4 5 7 9 11 12 12 15 16 19 5 10 3 3.25 10 5 1.39 10 1 1.3 10 4 2.35 10 4 1.16 10 4 1.48 10 2 3.34 10 7 7.8 10 3 3.25 10 5 1.50 5

FOR LOOP

SS 1 3 4 6 7 9 17 18 S8 := $(.9998 \ 7.41 \cdot 10^{-4} \ 9.5 \cdot 10^{-2} \ 1.76 \cdot 10^{-3} \ 1.3 \cdot 10^{-4} \ 2.35 \cdot 10^{-4} \ 1.6 \cdot 10^{-4} \ 2.2 \cdot 10^{-2})$ FOR DLOOP

S9 = .9998 FOR ATWS

SS 2 8 10 14 20 S10 = $(1.0 \ 1.99 \ 10^{-4} \ 1.18 \ 10^{-4} \ 4.14 \ 10^{-5} \ 1.13 \ 10^{-4})$ FOR LODC

PLANT STATE MATRICES:

P1 = 7.48 10⁻⁵ FOR LLOCA; ALCOM; SS 1

PS MLCOM MEABM

 $P2 := (9.5 \cdot 10^{-4} \ 7.9 \cdot 10^{-4})$ FOR MLOCA; SS 1

- P3 =0 FOR SLOCA
- P4 =0 FOR ISLOCA

P5 = 2.44 10⁻⁶ FOR IORV; ILCOM; SS 1

```
PS TLCOM TIABM SS
P6 = \begin{pmatrix} 1.25 \cdot 10^{-8} & 1.86 \cdot 10^{-9} \\ 5.49 \cdot 10^{-3} & 0 \end{pmatrix} 1
13
```

PS LLCOM LIABM BLABM BLAYN LICOM LLABM LIBON BIABM

SS

	5.59·10 ⁻⁶	4.16·10 ⁻⁶	0	0	4.78·10 ⁻⁷	4.09·10 ⁻⁷	0	0	1
	1.79.10-2	0	0	0	2.28·10 ⁻⁴	0	0	0	3
	7.12.10-5	2.73·10 ⁻⁶	0	0	0	0	0	0	4
	3.4·10 ⁻⁶	2.73·10 ⁻⁶	0	0	0	0	0	0	5
	0	0	2.05·10 ⁻²	6.6·10 ⁻³	0	0	0	9.99 [.] 10 ⁻⁴	7
P7 =	1.74.10-2	0	0	0	0	0	0	0	9
	1.74.10-2	0	0	0	0	0	0	0	11
	7.12.10-5	0	0	0	0	0	0	0	12
	· 0	0	0	0	0	0	1.0	0	15
	8.7·10 ⁻⁵	0	0	0	0	0	0	0	16
	1.49.10-5	0	0	0	0	0	0	0	10

FOR LOOP
PS	LLCOM	BLABM B	LAYN E	BIABM LLA	BM	SS	
	3.4-10 ⁻⁶	0	0	0	2.73·10 ⁻⁶]1	
	1.738·10 ⁻²	0	0	0	0	3	
P8 :=	7.12·10 ⁻⁵	0	0	0	Ο.	4	
	о	2.126 10-2	6.6·10 ⁻³	9.99 10 ⁻⁴	. 0	6	
	0	2.05 10 ⁻²	0	0	• 0	7	FOR DLOOP
	1.487·10 ⁻²	0	0	0	0	9	
	1.487·10 ⁻²	0	0	0	0.	17	-
	4.35-10 ⁻⁵	0	0	0	0	18	•.

PS TEEQF TEERF P9 = (2.33 · 10⁻³ 3.06 · 10⁻⁴) FOR ATWS; SS 1

PS I	DLCOM DI	BON	DIABM	DIBMS	SS	
	1.321-10-2	0	1.96 10 4	7.74·10 ⁻⁹	52	
	0	1.0	0	0	8	EO
P10 =	0	1.0	0	0	10	FU
	0	1.0	0	0	4	
	1.0	0	0	0	20	

FOR LODC

10

FEATURES OF MATRIX MODEL

 Retains "Component" level information through access to sequence information. Road map in form of flow charts.

4

DRESDEN IPE MATRIX FLOW CHARTS

TABLE OF CONTENTS

4

FLOW CHART #1 *** SUPPRESSION POOL COOLING FLOW CHART #2 *** HIGH PRESSURE INJECTION FLOW CHART #3 *** FEEDWATER FLOW CHART #4 *** ISOLATION CONDENSER FLOW CHART #5 *** MAKEUP TO I.C. FLOW CHART #6 *** LOW PRESSURE INJECTION FLOW CHART #7 *** RELIEF VALVE CLOSING FLOW CHART #8 *** ALTERNATE ROD INSERT. FLOW CHART #9 *** RECIRC. PUMP TRIP FLOW CHART #10 ** LPCI INJECTION VALVES FLOW CHART #11 ** OPER. ACT. - OSPC FLOW CHART #12 ** OPER. ACT. - OHX

FLOW CHART #13 ** OPER. ACT. - OSBCS FLOW CHART #14 ** OPER. ACT. - OAD FLOW CHART #15 ** OPER. ACT. - OMUP FLOW CHART #16 ** OPER. ACT. - OIC FLOW CHART #17 ** OPER. ACT. - OSL FLOW CHART #18 ** OPER. ACT. - ORP

**

DRESDEN IPE FLOW CHART #1

SPC (SUPPRESSION POOL COOLING)

NOTE: THIS CHART IS BROKEN DOWN INTO 8 SHEETS ORGANIZED AS ⁵ FOLLOWS:

SHEET 1: COMPONENT/FAULT TREES

SHEET 2: INITIATORS/PRT'S

SHEETS 3 MATRICES/SEQ. THRU 8:

FLOW CHART #1

·SHEET 1

SS # 1, 5; FT 2LI-LL-8; 2.71E-4

HX PLUGGED	51%
MOV 1501-20A&B	7
MOV 1501-38A&B	7
MOV 1501-11A&B	7

7

3.7

MOV 1501-3A&B

PUMPS

 SS # 4,13,16,18; FT 2LI-LLA

 &LL9; 5.5E-3

 HX VLV 2A 1503
 34%

 VALVE 2 1501-3A
 34

 MOV 1501-11A & B
 20.4

 - 3A & B
 2.5

 PUMPS
 4.8

SS # 2; FT 2LI-LL9A 8 1.03E-2	& B				
VALVE 2-1501-20A	18.2%	MOV MAINT.	5.5		لاست ب
VALVE 2-1501-38A	18.2	1501-38A & D 1501-20B		- SPC	;
HX 2A 1503 VLV	18.2	MOV MAINT 1501-118	5.5	╎└┯	
VALVE 2-1501-3A	18.2	1501-03BM 1501-11AM			,
MOV MAINT.	5.5			SHEE	ET
1501-20B		MOV MAINT	5.5		
1501-38B 1501-20A		1501-3A & B 1501-11B			



• .

FLOW CHART #1

SHEET 6



FEATURES OF MATRIX MODEL (CONT'D)

- Fast PRA Manipulation
- Permits rapid screening of changes or variations in terms of impact on result.

•

 Provides a "Skeleton" on which additions to the model, covering "new" sequences, can be made as required (simply add elements or even matrices if the existing structure does not accommodate.)

DETAILS OF USE FOR IPEEE PROGRAM

- 1. Apply to seismic & fire initiators
- 2. Use to "screen out" insignificant contributors
- 3. Use to add "new" sequences or modify frequencies of existing sequences as required
- 4. Next 2 speakers will provide detail on the use of the matrix methodology
- 5. Each speaker will discuss examples of the screening methodology and how it will identify items for detailed analysis

- The matrix approach is the equivalent to a truncated seismic or fire PRA using a best estimate approach. This method does not account for mathematical uncertainties.
- We believe that this approach is more comprehensive and useful than the seismic margins approach and only slightly less detailed than a full, formal PRA.

4

COMMONWEALTH EDISON IPEEE PROGRAM

,

SEISMIC EVALUATION

2

KONG WANG SENIOR PRA ENGINEER

SEISMIC IPEEE SCREENING/EVALUATION

STAGE I

Multiple screening analyses based on IPE data and structures starting with conservative and moving toward realistic screening.

STAGE II

Plant walkdowns and expert judgement.

STAGE III

Focused analyses using deterministic and/or probabilistic methods. Evaluation of the impact of event on CDFs using IPE matrix modelling.



FLOWCHART FOR `` SEISMIC IPEEE SCREENING/EVALUATION

* STAGE I: PRE-SCREENING

1. Identify and review reference materials for pre-screening:

Basic IPE FSAR/UFSAR Special seismic studies Previous PRA work, etc.

STAGE I (Continued)

2A. Develop site seismic hazard curve:

Using the EPRI seismicity curve and past seismic amplification factors, develop the accelerations at various levels for each plant for the screening level event.



7.2-18

STAGE I (Continued)

2B. Compare to IPE component failure frequencies:

Components with frequencies of annual seismic exceedance smaller than the IPE random failure frequencies are prescreened out.

This is very conservative since the component failure frequencies due to seismic, i.e., fragilities, are assumed to be "1.0" in this screening stage. Example: Diesel Generator

IPE random failure:

exceedance rate:

Unavail. due to maint.: 1.4E-2 Fail to run: 1.8E-2 , Fail to start: 8.2E-3

Total random failure rate: **4E-2** Seismic annual

5E-5

Therefore, DG can be screened out.

STAGE I (Continued)

3A. Generate component fragilities

Previous seismic studies and expert judgement.

3B. Generate component failure frequencies due to seismic

frequency = hazard * fragility

3C. Compare to IPE component random failure frequencies for the components which are not pre-screened out during the Step 2B.



7.2-19

tttachment J

Example: RCFC duct

1 1

IPE Random Failure:

Seg. C unavail. due to maint.: 8.5E-3
Valve 1MOV-SW0009 fail to open: 3.5E-3
1C fan fail to start: 3.3E-3*
Div. 17 relay fails: 5.6E-4

Total random failure freq.: <u>1.6E-2</u>

Failure due to seismic:

(annual exceedance freq. X fragility)

= 5E-5 X 5E-2

= 2.5E-6

Therefore, RCFC duct can be pre-screened out.

STAGE II

- 4. Walkdowns
 - * Confirm pre-screened out components configuration
 - * Anticipate two types of issues:
 - 1. Confirm plant as-built configuration,
 - 2. Subtle problems found by seismic experts such as potential tank failures via buckling.
 - * Expert judgement (e.g., develop component fragilities, estimate spatial interaction, etc.)
 - * Gather data for final analysis on non-screened out components.

STAGE III

- 5. Focused analyses
 - * Topics derived from screening analyses and walkdowns.
 - * Verification of subtle problems identified during walkdown, e.g., the loss of a tank due to failure of support buckling in conjunction with the loss of other similar identified components will be modeled as modifications to the base IPE along with appropriate random failures.
 - * Both primary effects(e.g., seismic induced loss of ssc) and secondary effects (e.g., flood from ruptured tank) will be considered in IPEEE work.

STAGE III (Continued)

- 6. Apply IPE matrix model and evaluate impact due to seismic
 - * Develop IPE matrix structure
 - * Evaluate impact on IPE matrix structure (i.e., initiating event matrix and support state matrix.)
 - * Evaluate impact on plant state matrix (i.e., impact due to the inclusion of the seismic failure as an additional failure cutset on component level.)
 - * Evaluate impact on CDFs.



Example of evaluation using Matrix Modeling:

Assume a seismic induced failure rate (i.e., hazard X fragility) , for LPI pump = 5E-5

Look into the top 36 dominant accident sequences of the Zion IPE, the sequences associated with LPI system are 2, 13, 15, 25, and 32.

TABLE 4.5.3-1 DOMINANT ACCIDENT SEQUENCES FOR BASE IPE MODEL QUANTIFICATION

• •

;

1. 6.087E-007 15.21% 1 AE98 LLOCA 3.000E-004 LARGE LOCA INTIATING EVENT 2. 4.092E-007 10.23% 1 AE98 LLOCA 3.000E-004 LARGE LOCA INTIATING EVENT 2. 4.092E-007 10.23% 1 AE98 LLOCA 3.000E-004 LARGE LOCA INTIATING EVENT 2. 4.092E-007 8.69% 88 LIOCA 3.000E-004 LARGE LOCA INTIATING EVENT 3. 3.962E-007 8.69% 98 LIOS DLOOP 1.400E-002 DUAL UNIT LOSS OF OFFSITE POWER INITIATING EVENT 4. 3.691E-007 8.69% 98 LIOS DLOOP 1.400E-002 DUAL UNIT LOSS OF OFFSITE POWER INITIATING EVENT 4. 3.691E-007 8.73% 1 RLP SGTA 8.02E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 5. 2.751E-007 8.68% 1 RLP SGTA 8.02E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 6. 2.472E-007 6.18% 1 RLP SGTA 8.02E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 6. 2.472E-007 6.1		FREQUENCY	PERCENT	SS#	BIN	EVENTS	VALUE	DESCRIPTION
2. 4.092E-007 10.23% 1 AE9S LLOCA 3.000E-004 LARGE LOCA INITIATING EVENT 1/2 (20) PRESSURE IN PUMPS TO 2/3 COLD LEGS ALL POWER 3. 3.962E-007 9.80% 98 LI9S DLOOP 1/400E-002 DUAL UNIT LOSS OF OFFSITE POWER INITIATING EVENT 4. 3.962E-007 9.80% 98 LI9S DLOOP 2/230E-002 DUAL UNIT LOSS OF OFFSITE POWER INITIATING EVENT 4. 3.962E-007 9.80% 98 LI9S DLOOP 2/230E-002 DUAL UNIT LOSS OF OFFSITE POWER INITIATING EVENT 4. 3.891E-007 9.73% 1 RL9T SGTR 9.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 5. 2.751E-007 6.86% 1 RL9T SGTR 9.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 0.6 2.472E-007 6.16% 1 RL9T SGTR 9.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 0.7 1.748E-007 1.819T SGTR 9.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 0.7 1.748E-007 6.16% 1 RL9T SGTR 9.020E-003 STEAM GE	1.	6.087E-007	15.21%	1	AE9S	LLOCA ORC	3.000E-004 2.160E-003	LARGE LOCA INITIATING EVENT OPERATOR ACTION - ESTABLISH LOW PRESSURE ECC RECIRCULATION (I LOCA W/SPRAY)
LPI 1.450E-003 1/2 LOW PRESSURE INL PUMPS TO 28 COLD LEGS ALL POWER 3. 3.962E-007 9.90% 98 LI9S DLO2 1.400E-002 ARWST REFILL NOT POSSIBLE FOR LARGE LOCA WITH CURRENT EOPs 3. 3.962E-007 9.90% 98 LI9S DLO2 1.400E-002 AC POWER WITH DLOSP OF CPFSITE POWER INITIATING EVENT 4. 3.891E-007 9.73% 1 RL9T SGTR 0.202E-003 OPERATOR ACTION - REFILL THE RWST (POWER UNAVAILABLE) 5. 2.751E-007 6.88% 1 RL9T SGTR 0.202E-003 OPERATOR ACTION - REFILL THE RWST 6. 2.472E-007 6.88% 1 RL9T SGTR 0.202E-003 OPERATOR ACTION - MINIMIZE HOLE INITIATING EVENT 00R 1.160E-002 OPERATOR ACTION - REFILL THE RWST COLING 5. 2.751E-007 6.88% 1 RL9T SGTR 0.202E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 00R 1.160E-003 OPERATOR ACTION - NEFILL THE RWST 0.800E-002 OPERATOR ACTION - NEFILL THE RWST 6. 2.472E-007 6.18% 1 RL9T SGTR 0.202E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 018 1.160E-003 <td>2.</td> <td>4.092E-007</td> <td>10.23%</td> <td>1</td> <td>AE9S</td> <td>LLOCA</td> <td>3.000E-004</td> <td>LARGE LOCA INITIATING EVENT</td>	2.	4.092E-007	10.23%	1	AE9S	LLOCA	3.000E-004	LARGE LOCA INITIATING EVENT
OHT 1000E+000 RWST REFILE NOT POSSIBLE FOR LARGE LOCA WITH CURRENT EOPs 3. 3.962E-007 9.90% 98 LI9S DLOOP 1.400E-002 DUAL UNIT LOSS OF OFFSITE POWER INITIATING EVENT AFW 1.400E-002 DUAL UNIT LOSS OF OFFSITE POWER INITIATING EVENT AFW AFW AFW 4. 3.891E-007 9.73% 1 RLST SGTR 9.020E-003 OPERATOR ACTION - SG DEPRESSURIZATION TO 24 COLD LEGS NO POWER 5. 2.751E-007 8.8% 1 RLST SGTR 9.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 6. 2.472E-007 8.18% 1 RLST SGTR 9.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 7. 1.748E-007 8.18% 1 RLST SGTR 9.020E-003 OPERATOR ACTION - REFILL THE RWST 6. 2.472E-007 8.18% 1 RLST SGTR 9.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 7. 1.748E-007 4.37% 1 RLST SGTR 9.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 7. 1.748E-007						LPI	1.450E-003	1/2 LOW PRESSURE INJ PUMPS TO 2/3 COLD LEGS ALL POWER
3. 3.962E-007 9.90% 98 LI98 DLOOP 1.400E-002 DUAL UNIT LOSS OF OFFSITE POWER INITIATING EVENT AC POWER WITH DLOSP 146,149 FAIL AC POWER WITH DLOSP 146,149 FAIL AC POWER WITH DLOSP 146,149 FAIL AC POWER WITH DLOSP 146,149 FAIL AC POWER WITH DLOSP 146,149 FAIL AC POWER WITH DLOSP 146,149 FAIL AC POWER WITH DLOSP 146,149 FAIL 4. 3.891E-007 9.73% 1 RL9T SGTR 0.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 5. 2.751E-007 0.88% 1 RL9T SGTR 0.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 6. 2.472E-007 0.88% 1 RL9T SGTR 0.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 7. 1.748E-007 4.19 RL9T SGTR 0.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 7. 1.748E-007 4.37% 1 RL9T SGTR 0.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 7. 1.748E-007 4.37% 1 RL9T SGTR 0.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 7. 1.748E-007					•	ORT	1.000E+000	RWST REFILL NOT POSSIBLE FOR LARGE LOCA WITH CURRENT EOPS
BUS AFW2.230E-003 1.450E-002AC POWER WITH DLOSP 148,149 FAIL 1.430X FEED PUMPS TO 4/4 SG NO POWER 1/3 AUX FEED PUMPS TO 4/4 SG NO POWER 1/3 AUX FEED PUMPS TO 4/4 SG NO POWER 2/5 FAN COOLERS HPR 1.000E+000AC POWER WITH DLOSP 148,149 FAIL 1/3 AUX FEED PUMPS TO 4/4 SG NO POWER 	3.	3.962E-007	9.90%	98	LI9S	DLOOP	1.400E-002	DUAL UNIT LOSS OF OFFSITE POWER INITIATING EVENT
AFW 1.450E-002 13 AUX FEED PUMPS TO 4/4 SG NO POWER FC 9.847E-001 2/5 FAN COOLERS HPR 1.000E+000 14 HGH PRESSURE RECIRCULATION TO 2/4 COLD LEGS NO POWER A. 3.891E-007 8.73% 1 RL9T SGTR 9.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 5. 2.751E-007 8.88% 1 RL9T SGTR 9.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 6. 2.472E-007 8.88% 1 RL9T SGTR 9.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OFERATOR ACTION - REFILL THE RWST 6.88% 1 RL9T SGTR 9.020E-003 OPERATOR ACTION - REFILL THE RWST 6. 2.472E-007 8.88% 1 RL9T SGTR 9.020E-003 OPERATOR ACTION - REFILL THE RWST 8. 2.472E-007 8.18% 1 RL9T SGTR 9.020E-003 OPERATOR ACTION - MINIMIZE ECCS FLOW OFFATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING 7. 1.748E-007 4.1817 SGTR 9.020E-003 STEAM GE						BUS	2.230E-003	AC POWER WITH DLOSP 148 149 EAU
FC HPR 1.000E+000 HTK9.447E-001 1.000E+000 HPR TIX2/5 FAN COOLERS HIGH PRESSURE RECIRCULATION TO 2/4 COLD LEGS NO POWER RECIRCULATION TO 2/4 COLD LEGS NO POWER HOWER UNAVAILABLE)4. 3.891E-0079.73%1RL9T ODS ODS ODS OTH8.020E-003 3.800E-002STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING 0PERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING 0PERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING 2.510E-0026. 2.472E-0078.18%1RL9T SGTR ODS 1.150E-003STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING DEPRATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING DEPRATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING RTK 2.510E-0027. 1.748E-0074.37%1RL9T RTKSGTR 2.510E-002STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - MINIMIZE ECCS FLOW RTK8.1.528E-0073.81%1ML9S MLOCA1.100E-003 2.510E-002STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 2.510E-0029.1.448E-0073.82%1AE99 ALLOCA A3.000E-004 2.910E-001MEDIUM LOCA INITIATING EVENT 12 LOW PRESSURE RECIRCULATION TO 2/A C						AFW	1.450E-002	1/3 AUX FEED PUMPS TO A(A SG NO POWER
HPR RTK1.000E+000 1.000E+0001/4 High PRESSURE RECIRCULATION TO 2/4 COLD LEGS NO POWER EQUIPMENT TO REFILL THE RWST (POWER UNAVAILABLE)4.3.891E-0078.73%1RL9T SGTR ODS ODS ORT9.020E-003 1.150E-003 OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING OPERATOR ACTION - REFILL THE RWST5.2.751E-0076.88%1RL9T SGTR ORT9.020E-003 SITEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - NEFILL THE RWST6.2.472E-0076.16%1RL9T SGTR ODS RTK9.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING OPERATO						FC	9.847E-001	2/5 FAN COOLERS
A: 3.891E-007 8.73% 1 RL9T SGTR ODS ORT 9.020E-003 3.800E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - REFILL THE RWST 5. 2.751E-007 6.88% 1 RL9T SGTR ORT 9.020E-003 3.800E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - REFILL THE RWST 5. 2.751E-007 6.88% 1 RL9T SGTR ORT 9.020E-003 3.800E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - REFILL THE RWST 6. 2.472E-007 6.18% 1 RL9T SGTR ODS RTK 9.020E-003 3.800E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - REFILL THE RWST 7. 1.748E-007 6.18% 1 RL9T SGTR OIR RTK 9.020E-003 2.510E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT ODS RTK 02.6100-002 8. 1.528E-007 8.18% 1 RL9T SGTR OIR RTK 9.020E-003 2.510E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT ODS RTK 02.6100-002 8. 1.528E-007 8.18% 1 RL9T SGTR S.200E-004 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OIR RTK 1.100E-003 2.510E-004 MEDIUM LOCA INITIATING EVENT OPERATOR ACTION - MINIMIZE ECCS FLOW PECOUPMENT TO REFILL THE RWST						HPR	1.000E+000	1/4 HIGH PRESSURE RECIRCULATION TO 2/4 COLD LEGG NO POWER
4. 3.891E-007 9.73% 1 RL9T SGTR ODS ORT 8.020E-003 3.800E-02 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING OPERATOR ACTION - REFILL THE RWST 5. 2.751E-007 8.8% 1 RL9T SGTR ORT 9.020E-003 8.140E-004 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - REFILL THE RWST 6. 2.472E-007 6.18% 1 RL9T SGTR ODR 9.020E-003 8.140E-004 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - REFILL THE RWST 7. 1.748E-007 6.18% 1 RL9T SGTR OIR RTK 9.020E-003 2.510E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING EQUIPMENT TO REFILL THE RWST (SGTR) 7. 1.748E-007 4.37% 1 RL9T SGTR OIR RTK 9.020E-003 2.510E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - MINIMIZE ECCS FLOW OPERATOR ACTION - MINIMIZE ECCS FLOW EQUIPMENT TO REFILL THE RWST (SGTR) 8. 1.526E-007 3.81% 1 ML9S ML0CA LPR RTK 1.100E-003 5.200E-004 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 1/2 LOW PRESSURE RECIRCULATION TO 2/4 COLD LEGS ALL POWER (COND) EQUIPMENT TO REFILL THE RWST FOR LOCAs						RTK	1.000E+000	EQUIPMENT TO REFILL THE RWST (POWER UNAVAILABLE)
ODS ORT 1.150E-003 3.800E-002 OPERATOR ACTION - SQ DEPRESSURIZATION FOR PRIMARY COOLING OPERATOR ACTION - REFILL THE RWST 5. 2.751E-007 6.88% 1 RL9T SGTR OIR 9.020E-003 8.140E-004 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - REFILL THE RWST 6. 2.472E-007 6.18% 1 RL9T SGTR OIR 9.020E-003 8.140E-004 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - REFILL THE RWST 7. 1.748E-007 6.18% 1 RL9T SGTR OIR 9.020E-003 8.140E-004 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT ODERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING PERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING 7. 1.748E-007 4.37% 1 RL9T SGTR OIR RTK 9.020E-003 2.510E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - MINIMIZE ECCS FLOW EQUIPMENT TO REFILL THE RWST (SGTR) 8. 1.526E-007 3.81% 1 ML9S ML0CA LPR 5.200E-004 1.100E-003 5.200E-004 MEDIUM LOCA INITIATING EVENT 1/2 LOW PRESSURE RECIRCULATION TO 2/4 COLD LEGS ALL POWER (COND) EQUIPMENT TO REFILL THE RWST FOR LOCA9 9. 1.448E-007 3.82% 1 AE98 LL0CA 3.000E-004 3.000E-004 LARGE LOCA INITIATING EVENT	4.	3.891E-007	9.73%	1	RL9T	SGTR	9.020E-003	
ORT 3.800E-002 OPERATOR ACTION - REFILL THE RWST 5. 2.751E-007 6.88% 1 RL9T SGTR OIR 9.020E-003 8.140E-004 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - MINIMIZE ECCS FLOW OPERATOR ACTION - REFILL THE RWST 6. 2.472E-007 6.18% 1 RL9T SGTR ODS RTK 9.020E-003 2.510E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - REFILL THE RWST 7. 1.748E-007 4.37% 1 RL9T SGTR OIR RTK 9.020E-003 2.510E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING EQUIPMENT TO REFILL THE RWST (SGTR) 7. 1.748E-007 4.37% 1 RL9T SGTR OIR RTK 9.020E-003 2.510E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - MINIMIZE ECCS FLOW PERATOR ACTION - MINIMIZE ECCS FLOW PERATOR ACTION - MINIMIZE ECCS FLOW 8. 1.528E-007 3.81% 1 ML9S MLOCA LPR S200E-004 1.100E-003 2.910E-001 MEDIUM LOCA INITIATING EVENT 1/2 LOW PRESSURE RECIRCULATION TO 2/4 COLD LEGS ALL POWER (COND) EQUIPMENT TO REFILL THE RWST FOR LOCA* 9. 1.448E-007 3.82% 1 AE9S LLOCA 3.000E-004 LARGE LOCA INITIATING EVENT						ODS	1.150E-003	OPERATOR ACTION - SG DEPRESSIBILATION FOR DRIMARY COOLING
5. 2.751E-007 6.89% 1 RL9T SGTR ORT 9.020E-003 8.140E-004 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - REFILL THE RWST 6. 2.472E-007 6.18% 1 RL9T SGTR ODS RTK 9.020E-003 9.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING 7. 1.748E-007 4.37% 1 RL9T SGTR ODS RTK 9.020E-003 9.510E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING 7. 1.748E-007 4.37% 1 RL9T SGTR RTK 9.020E-003 9.020E-003 8.140E-004 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - MINIMIZE ECCS FLOW OPERATOR ACTION - MINIMIZE ECCS FLOW COPERATOR ACTION - MINIMIZE ECCS FLOW COPERATOR ACTION - MINIMIZE ECCS FLOW EQUIPMENT TO REFILL THE RWST (SGTR) 8. 1.526E-007 3.81% 1 ML9S ML0CA LPR RTK 1.100E-003 5.200E-004 MEDIUM LOCA INITIATING EVENT 1/2 LOW PRESSURE RECIRCULATION TO 2/4 COLD LEGS ALL POWER (COND) EQUIPMENT TO REFILL THE RWST FOR LOCAs 9. 1.448E-007 3.62% 1 AE99 LL0CA 3.000E-004 LARGE LOCA INITIATING EVENT						ORT	3.800E-002	OPERATOR ACTION - REFILL THE RWST
OIR OIR ORT8.140E-004 3.800E-002OPERATOR ACTION - MINIMIZE ECCS FLOW OPERATOR ACTION - REFILL THE RWST6.2.472E-0076.18%1RL9TSGTR ODS RTK9.020E-003 2.510E-002STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING EQUIPMENT TO REFILL THE RWST (SGTR)7.1.748E-0074.37%1RL9TSGTR OIR RTK9.020E-003 2.510E-002STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING8.1.526E-0073.81%1ML9S RTKMLOCA 2.510E-002STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - MINIMIZE ECCS FLOW EQUIPMENT TO REFILL THE RWST (SGTR)8.1.526E-0073.81%1ML9S RTK1.100E-003 2.900E-004MEDIUM LOCA INITIATING EVENT 1/2 LOW PRESSURE RECIRCULATION TO 2/4 COLD LEGS ALL POWER (COND) EQUIPMENT TO REFILL THE RWST FOR LOCAs9.1.448E-0073.62%1AE99 LLOCA3.000E-004 3.000E-004LARGE LOCA INITIATING EVENT 1/2 LOW PRESSURE RECIRCULATION TO 2/4 COLD LEGS ALL POWER (COND) EQUIPMENT TO REFILL THE RWST FOR LOCAs	5 .	2.751E-007	6.88%	1	RL9T	SGTR	9.020E-003	
ORT 3.800-002 OPERATOR ACTION - REFILL THE RWST 6. 2.472E-007 6.18% 1 RL9T SGTR ODS RTK 9.020E-003 2.510E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING 7. 1.748E-007 4.37% 1 RL9T SGTR OIR RTK 9.020E-003 2.510E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING 8. 1.748E-007 4.37% 1 RL9T SGTR OIR RTK 9.020E-003 2.510E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - MINIMIZE ECCS FLOW EQUIPMENT TO REFILL THE RWST (SGTR) 8. 1.526E-007 3.81% 1 ML9S ML0CA LPR RTK 1.100E-003 5.200E-004 MEDIUM LOCA INITIATING EVENT 1/2 LOW PRESSURE RECIRCULATION TO 2/4 COLD LEGS ALL POWER (COND) EQUIPMENT TO REFILL THE RWST FOR LOCAs 9. 1.448E-007 3.62% 1 AE99 LLOCA 3.000E-004 LARGE LOCA INITIATING EVENT						OIR	8.140E-004	OPERATOR ACTION AMINIMIZE ECCERTION
6. 2.472E-007 6.18% 1 RL9T SGTR ODS RTK 9.020E-003 2.510E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING EQUIPMENT TO REFILL THE RWST (SGTR) 7. 1.748E-007 4.37% 1 RL9T SGTR OIR RTK 9.020E-003 2.510E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING EQUIPMENT TO REFILL THE RWST (SGTR) 8. 1.748E-007 4.37% 1 RL9T SGTR OIR RTK 9.020E-003 8.140E-004 2.510E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - MINIMIZE ECCS FLOW EQUIPMENT TO REFILL THE RWST (SGTR) 8. 1.526E-007 3.81% 1 ML9S ML0CA LPR RTK 1.100E-003 5.200E-004 MEDIUM LOCA INITIATING EVENT 1/2 LOW PRESSURE RECIRCULATION TO 2/4 COLD LEGS ALL POWER (COND) EQUIPMENT TO REFILL THE RWST FOR LOCAs 9. 1.448E-007 3.62% 1 AE9S LL0CA LD0CA 3.000E-004 LARGE LOCA INITIATING EVENT						ORT	3.800E-002	OPERATOR ACTION - REFILL THE RWST
7. 1.748E-007 4.37% 1 RL9T SGTR OTR 9.020E-003 8.140E-004 STEAM GENERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING EQUIPMENT TO REFILL THE RWST (SGTR) 7. 1.748E-007 4.37% 1 RL9T SGTR OTR OTR RTK 9.020E-003 2.510E-002 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - MINIMIZE ECCS FLOW RTK 8. 1.526E-007 3.81% 1 ML9S MLOCA LPR RTK 1.100E-003 2.910E-001 MEDIUM LOCA INITIATING EVENT 1/2 LOW PRESSURE RECIRCULATION TO 2/4 COLD LEGS ALL POWER (COND) 9. 1.448E-007 3.62% 1 AE9S LLOCA LDCA 3.000E-004 LARGE LOCA INITIATING EVENT	6.	2.472E-007	6.18%	1	RL9T	SGTR	9 0205-003	
7. 1.748E-007 4.37% 1 RL9T SGTR OIR RTK 9.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - MINIMIZE ECCS FLOW EQUIPMENT TO REFILL THE RWST (SGTR) 8. 1.526E-007 3.81% 1 ML9S MLOCA LPR RTK 1.100E-003 5.200E-004 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - MINIMIZE ECCS FLOW EQUIPMENT TO REFILL THE RWST (SGTR) 8. 1.526E-007 3.81% 1 ML9S MLOCA LPR RTK 1.100E-003 5.200E-004 MEDIUM LOCA INITIATING EVENT 1/2 LOW PRESSURE RECIRCULATION TO 2/4 COLD LEGS ALL POWER (COND) 9. 1.448E-007 3.62% 1 AE99 LLOCA 3.000E-004 LARGE LOCA INITIATING EVENT				•	11201	ODS	1 1505-003	OPERATOR ACTION TO BE RUPTURE INITIATING EVENT
7. 1.748E-007 4.37% 1 RL9T SGTR OIR RTK 9.020E-003 8.140E-004 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - MINIMIZE ECCS FLOW EQUIPMENT TO REFILL THE RWST (SGTR) 8. 1.526E-007 3.81% 1 ML9S MLOCA LPR RTK 1.100E-003 5.200E-004 MEDIUM LOCA INITIATING EVENT 1/2 LOW PRESSURE RECIRCULATION TO 2/4 COLD LEGS ALL POWER (COND) 9. 1.448E-007 3.62% 1 AE9S LLOCA 3.000E-004 LARGE LOCA INITIATING EVENT						RTK	2 510E-002	EQUIDMENT TO DEFINE THE DWGS (1227) TO FOR PRIMARY COOLING
7. 1.748E-007 4.37% 1 RL9T SGTR 9.020E-003 STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 0IR 8.140E-004 OPERATOR ACTION - MINIMIZE ECCS FLOW OPERATOR STEAM GENERATOR TUBE RUPTURE INITIATING EVENT 8. 1.526E-007 3.81% 1 ML9S MLOCA 1.100E-003 MEDIUM LOCA INITIATING EVENT 9. 1.448E-007 3.62% 1 AE9S LLOCA 3.000E-004 LARGE LOCA INITIATING EVENT	-						2.0102-002	ENDIFMENT TO REFILE THE HWST (SGTR)
OIR RTK 8.140E-004 2.510E-002 OPERATOR ACTION - MINIMIZE ECCS FLOW EQUIPMENT TO REFILL THE RWST (SGTR) 8. 1.526E-007 3.81% 1 ML9S MLOCA LPR S.200E-004 1.100E-003 5.200E-004 MEDIUM LOCA INITIATING EVENT 1/2 LOW PRESSURE RECIRCULATION TO 2/4 COLD LEGS ALL POWER (COND) 9. 1.448E-007 3.62% 1 AE9S LLOCA 3.000E-004 LARGE LOCA INITIATING EVENT	7.	1.748E-007	4.37%	1	RLOT	SGTR	9.020E-003	STEAM GENERATOR TUBE RUPTURE INITIATING EVENT
RTK 2.510E-002 EQUIPMENT TO REFILL THE RWST (SGTR) 8. 1.526E-007 3.81% 1 ML9S MLOCA 1.100E-003 MEDIUM LOCA INITIATING EVENT 9. 1.448E-007 3.62% 1 AE9S LLOCA 3.000E-004 LARGE LOCA INITIATING EVENT						OIR	8.140E-004	OPERATOR ACTION - MINIMIZE ECCS FLOW
B. 1.526E-007 3.81% 1 ML9S MLOCA 1.100E-003 MEDIUM LOCA INITIATING EVENT 1. 1. 1.00E-003 1.00E-003 MEDIUM LOCA INITIATING EVENT 1. 1. 1.00E-003 1.2 LOW PRESSURE RECIRCULATION TO 2/4 COLD LEGS ALL POWER (COND) 9. 1.448E-007 3.62% 1 AE9S LLOCA 3.000E-004 LARGE LOCA INITIATING EVENT						RTK	2.510E-002	EQUIPMENT TO REFILL THE RWST (SGTR)
LPR 5.200E-004 1/2 LOW PRESSURE RECIRCULATION TO 2/4 COLD LEGS ALL POWER (COND) RTK 2.910E-001 EQUIPMENT TO REFILL THE RWST FOR LOCAs 9. 1.448E-007 3.62% 1 AE9S LLOCA 3.000E-004 LARGE LOCA INITIATING EVENT	8.	1.526E-007	3.81%	1	ML9S	MLOCA	1.100E-003	MEDIUM LOCA INITIATING EVENT
9. 1.448E-007 3.62% 1 AE9S LLOCA 3.000E-004 LARGE LOCA INITIATING EVENT						LPR	5.200E-004	1/2 LOW PRESSURE RECIRCULATION TO 2/4 COLD LEGS ALL DOWED (COND)
9. 1.448E-007 3.62% 1 AE9S LLOCA 3.000E-004 LARGE LOCA INITIATING EVENT						RTK	2.910E-001	EQUIPMENT TO REFILL THE RWST FOR LOCAS
	9.	1.448E-007	3.62%	1	AE9S	LLOCA	3.000E-004	LARGE LOCA INITIATING EVENT
						LPR	5.150E-004	1/2 LOW PRESSURE RECIRCULATION TO 1/2 COLD LEGR ALL DOWED (COND)
ORT 1.000E+000 RWST REFILL NOT POSSIBLE FOR LARGE LOCA WITH CURPENT FOR						ORT	1.000E+000	RWST REFILL NOT POSSIBLE FOR LARGE LOCA WITH CURRENT FOR-

WP1169-3:1D/040692

4 - 161

*

Example (Continued)

.

Example (Continued)

The elements which contain LPI system in the plant state matrix are: P(1,1), P(1,4), P(1,7), and P(1,10).

٠,

٠. STATES PLANT AE9S ML9S SL9S AE9F 2 4E-3 .. 3.3E-4 .. 1.5E-5 .. 1.4E-4 1 Ρ 12 Ρ 63 R ! ____ Т S 1 ı. A T E S

P ;=

Example (Continued)

Let's look element P(1,1):

P(1,1) represents (at 4E-3) the likelihood of plant state AE9S given a LLOCA and support state 1. For this case in point, there are three sequences of interest: #1, #2, and #9. (Note that only #2 contains LPI.)

<u>Seq. #1</u>

Failure is ORC, operator action to establish ECCS recirculation, with a frequency of 2.16E-3.

<u>Seq. #2</u>

Failures are LPI, with a frequency of 1.45E-3 and ORT, operator action on RWST refill with a frequency of 1.0

<u>Seq. #9</u> Failures are LPR, with a frequency of 4.3E-4 and ORT with a frequency of 1.0.

Zion TABLE 4.5.3-1

DOMINANT ACCIDENT SEQUENCES FOR BASE IPE MODEL QUANTIFICATION

1

٠.

#	FREQUENCY	PERCENT	SS#	BIN	EVENTS	VALUE	DESCRIPTION
1.	6.087E-007	15.21%	1	AE9S	LLOCA ORC	3.000E-004 2.160E-003	LARGE LOCA INITIATING EVENT OPERATOR ACTION - ESTABLISH LOW PRESSURE ECC RECIRCULATION (LLOCA W/SPRAY)
2.	4.092E-007	10.23%	1	AE9S	LLOCA LPI ORT	3.000E-004 1.450E-003 1.000E+000	LARGE LOCA INITIATING EVENT 1/2 LOW PRESSURE INJ PUMPS TO 2/3 COLD LEGS ALL POWER RWST REFILL NOT POSSIBLE FOR LARGE LOCA WITH CURRENT EOPS
3.	3.962E-007	9.90%	98	Li9S	DLOOP BUS AFW FC HPR RTK	1.400E-002 2.230E-003 1.450E-002 9.847E-001 1.000E+000 1.000E+000	DUAL UNIT LOSS OF OFFSITE POWER INITIATING EVENT AC POWER WITH DLOSP 148,149 FAIL 1/3 AUX FEED PUMPS TO 4/4 SG NO POWER 2/5 FAN COOLERS 1/4 HIGH PRESSURE RECIRCULATION TO 2/4 COLD LEGS NO POWER EQUIPMENT TO REFILL THE RWST (POWER UNAVAILABLE)
4 .	3.891E-007	9.73%	1	AL9T	SGTR ODS ORT	9.020E-003 1.150E-003 3.800E-002	STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING OPERATOR ACTION - REFILL THE RWST
5.	2.751E-007	6.88%	1	RL9T	Sgtr Oir Ort	9.020E-003 8.140E-004 3.800E-002	STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - MINIMIZE ECCS FLOW OPERATOR ACTION - REFILL THE RWST
6.	2.472E-007	6.18%	t	RL9T	Sgtr Ods Rtk	9.020E-003 1.150E-003 2.510E-002	STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - SG DEPRESSURIZATION FOR PRIMARY COOLING EQUIPMENT TO REFILL THE RWST (SGTR)
7.	1.748E-007	4.37%	1	RL9T	Sgtr Oir Rtk	9.020E-003 8.140E-004 2.510E-002	STEAM GENERATOR TUBE RUPTURE INITIATING EVENT OPERATOR ACTION - MINIMIZE ECCS FLOW EQUIPMENT TO REFILL THE RWST (SGTR)
8.	1.526E-007	3.81%	1	ML9S	Mloca LPR RTK	1.100E-003 5.200E-004 2.910E-001	MEDIUM LOCA INITIATING EVENT 1/2 LOW PRESSURE RECIRCULATION TO 2/4 COLD LEGS ALL POWER (COND) EQUIPMENT TO REFILL THE RWST FOR LOCA 9
9.	1.448E-007	3.82%	1	AE98	LLOCA LPR ORT	3.000E-004 5.150E-004 1.000E+000	LARGE LOCA INITIATING EVENT 1/2 LOW PRESSURE RECIRCULATION TO 1/3 COLD LEGS ALL POWER (COND) RWST REFILL NOT POSSIBLE FOR LARGE LOCA WITH CURRENT EOPS

WP1169-3:1D/040692

4 - 161

 \mathbf{v}

INITIATING EVENT SCALAR (I) :

LLOCA I1 = 3E-4

SUPPORT STATE VECTOR (S) :

LLOCA $S1 = (0.9996 \quad 5.2E-5 \quad 2E-4)$

PLANT STATE MATRIX (P):

LLOCA \mathbf{PS} AE9S AE7S AE9F AE7K AE7F SS4E-30.0 1.6E - 40.0 0.0 1 1.0 0.0 0.0 P1 = 0.0 0.0 61 1.0 3E-2 0.0 0.0 4E-2 63

>>

. .

DERIVATION OF PLANT STATE ELEMENTS

EXAMPLE : P1 (1,1) = 4E-3



1

Example (Continued)

Now, we need to decompose these interim (system) results down to component level. Looking at the ECCS fault tree notebook, for support state 1, we find the dominant failure contributors for LPI failure to be:

ComponentFreq.Check valve 1SI89571.3E-3FTOCheck valve 1SI89587.4E-5Check valve 1SI89587.4E-5FTODiv. 18 & 19 R2 fail7.9E-6Other contributors6.8E-5Total1.45E-3Seismic failure freq.5E-5	Combined failure freq.	<u>1.5E-3</u>
ComponentFreq.Check valve 1SI89571.3E-3FTO1.3E-5Check valve 1SI89587.4E-5FTO7.9E-6Div. 18 & 19 R2 fail7.9E-6Other contributors6.8E-5Total1.45E-3	Seismic failure freq.	5E-5
ComponentFreq.Check valve 1SI89571.3E-3FTOCheck valve 1SI89587.4E-5Check valve 1SI89587.4E-5FTODiv. 18 & 19 R2 fail7.9E-6Other contributors6.8E-5	Total	1.45E-3
ComponentFreq.Check valve 1SI89571.3E-3FTOCheck valve 1SI89587.4E-5FTODiv. 18 & 19 R2 fail7.9E-6	Other contributors	<u>6.8E-5</u>
ComponentFreq.Check valve 1SI89571.3E-3FTOFTOCheck valve 1SI89587.4E-5FTO	Div. 18 & 19 R2 fail	7.9E-6
ComponentFreq.Check valve 1SI89571.3E-3FTO	Check valve 1SI8958 FTO	7.4E-5
	<u>Component</u> Check valve 1SI8957 FTO	Freq. 1.3E-3

Example (Continued)

Now, let's estimate the impact on the element **P(1,1)** of the plant state matrix due to seismic induced failure of LPI. The element in plant state is represented by

2

$$P = \sum_{i}^{l} \left(\prod_{j}^{m} \left[\sum_{k}^{n} C_{k} \right]_{j} \right)_{i}$$

where

- l = number of sequences contributing to this element, m = number of systems or
 - operator failures defining the sequence,
- n = number of components in the system, and C_k= component failure rate
 - for component k.
Example (Continued)

Therefore, element **P(1,1)** is modified to be:

P(1,1) =

(2.16E-3(ORC))_{seq. #1} + (1.5E-3(LPI)*1.0(ORT))_{seq. #2} + (5.15E-4(LPR)*1.0(ORT))_{seq. #9} = 4.12E-3

Comparing to the old value of P(1,1) which is 4E-3, this is only an increase of 3% due to seismic induced failure. The final CDF due to the impact of seismic induced failure of LPI can be evaluated by modifying other elements.

7. Final Touch

- Importance of component * failures due to seismic events can be ranked by evaluating the impact of the individual component.
- * The impact on the final CDF, due to all the components which may have higher failure rates than random failure frequencies can be evaluated collectively by modifying all the component failure frequencies and carrying out matrix manipulation.
- Look for insights and * potential improvements.



COMMONWEALTH EDISON IPEEE PROGRAM

FIRE PROTECTION EVALUATION

1.

CARLOS DIAZ PRINCIPAL FIRE PROTECTION ENGINEER

FIRE IPEEE SCREENING/EVALUATION

Stages

I. Multi-step prescreening evaluation based on IPE structures.

II. Detailed plant walkdowns aimed at validating assumptions and identifying potential concerns not previously considered.

III. Focused final
 evaluation using
 deterministic and/or
 probabilistic approach.



FLOWCHART FOR FIRE IPEEE SCREENING/EVALUATION * EVALUATION PROCESS

Stage I

1. Identification and review of key reference materials for the identification of fire areas and other fire protection features:

Fire Hazards Analysis Safe Shutdown Analysis FIVE Methodology

2. Identification of "Key Equipment" in each fire area:

"Key Equipment" will be derived from the IPE components, IPE support systems, and the Safe Shutdown Analysis.

',

3. First Pre-Screening Phase

Screen out any area which does not contain any "key equipment".

4. Develop Failure Frequency Due to Fire:

For each area that could not be screened out, calculate the failure frequency due to fire for each key component within the area. The FIVE data base will be used to generate the failure frequencies.

5. Second Pre-Screening Phase

Screen out those components whose fire failure rate is less than the random failure rate of the component used in the IPE matrices.

1

6. Develop Plant Specific Failure Rates Due To Fire

Develop realistic failure rates using specific plant information.

7

7. Third Pre-Screening Phase

Screen out those components whose failure rate due to fire (as derived from realistic data) is less than the failure rate of the component in the IPE.

STAGE II

- 8. Validation of Findings From Stages I and II
 - Walkdown all the areas to:
 - 1) Verify the failure rates due to fire used in stages I & II, and
 - 2) Address the Fire Risk Scoping Study Issues as discussed in the FIVE methodology, and
 - 3) Identify any potential new hazards discerned from physical inspection.



STAGE III

Focused Analysis

1. Where appropriate, construct detailed fire modelling for selected matrix element contributors and evaluate as needed.

and/or

2.

Modify the IPE matrixes by including the fire failure rates of those areas not screened out. Modify the matrices to include any new hazards identified in the walkdown.



3. Perform appropriate matrix manipulations to assess the impact of fire modelling through the foregoing stages.

. i.

Example of Matrix Modelling:

To illustrate utilization of the matrix approach used in the third stage, we will assume that we are evaluating the 1A RHR pump and that it has not been screened out in stages I &II. Among the top 36 dominant accident sequences of the Zion IPE, the sequences associate with RHR system are:

Sec no.	q. <u>I.E.</u>	<u>S.S</u>	BIN	RHR Failure <u>rate</u>	<u>P(i,j)</u>
2	LLOCA	1	AE9S	1.45E-3	P(1,1)=4.0E-3
8	MLOCA	1	ML9S	5.2E-4	P(1,4)=3.3E-4 ~
9	LLOCA	1	AE9S	5.15E-4	P(1,1)=4.0E-3
13	SLOCA	1	SL9S	4.2E-5	P(1,7)=1.5E-5
15	MLOCA	1	ML9S	1.65E-4	P(1,4)=3.3E-4
20	MLOCA	1	ML9S	5.2E-4	P(1,4)=3.3E-4
25	LLOCA	1	AE9F	1.45E-3	P(1,10)=1.4E-4
32	SLOCA	1	SL9S	4.2E-5	P(1,7)=1.5E-5
36	SLOCA	1	SL9S	4.48E-4	P(1,7)=1.5E-5

By including the failure rate due to fire, the revised failure rates are listed below:

<u>Seq. #</u>	Old RHR <u>failure rate</u>	New RHR <u>failure rate</u>
2	1.45E-3	1.51E-3
8	5.2E-4	5.7E-4
9	5.2E-4	5.7E-4
13	4.2E-5	5.4E-5
15	1.65E-4	2.13E-4
20	5.2E-4	5.7E-4
25	1.45E-3	3.45E-3
32	4.22E-5	5.4E-5
36	4.48E-4	4.88E-4

Now, let's estimate the impact on the plant state matrix. Remember that any element in the plant state matrix can be represented by

$$P = \sum_{i}^{l} \left(\prod_{j}^{n} \left[\sum_{k}^{n} C_{k} \right]_{j} \right)_{i}$$

where I denotes the number of sequences contributing to the element, m denotes the number of systems, components, or operator failures defining the sequences, and C_k denotes the component failure rate for component k. Modifying element P(1,1) results in:

P =

(2.16E-3(Old value of Seq. 1 which is not affected by RHR)) $_{seq. 1}$

+ (1.51E-3(New LPI) * 1.0(ORT))seq. 2

+ (5.7E-4(New LPR) * 1.0(ORT))seq. 9

= 4.24E-3

Comparing to the old value of P(1,1) which is 4.0E-3, this is only an increase of 6% due to combining RHR pump 1A random failure and fire. Similarly, other elements, i.e., P(1,4), P(1,7), and P(1,10), can be updated as well. The final impact on the plant CDF can thus be estimated by modifying the other elements.

SUMMARY OF NUCLEAR STATION REFUELING SCHEDULE





Major Task/Resp. Individuals	Evaluation Process Development	Matrix Development	Pre-Screening Process .
Station Representative	0056		003
PRA Engineers	00000	0 0	2 4 5 6 7 8
Fire Protection Engineers	00000		0 2 3
PRA Augmented Staff		0	
Seismic/Fire Experts	0		60
Licensing/Reg. Assurance	3		
Site VP	S 6		
Proj. Team Leader	3 0 5		
	 Development of Process Station Critique NRC Presentation Development of Project Plan Alternatives Presentation to Station/Site VP Selection of Method of Implementation 	 IPE Completion Develop Matrices 	 ① Identify Fire Areas ② Identify Equip. in Fire Area ③ Assign Fire Freq. ④ IPE Fire Comparison ③ Identify Key Components ⑥ Develop Site Hazard Curves ⑦ Generate Equip. Fragilities ④ IPE Seismic Comparison

-

IPEEE PROJECT/TASK MATRIX

Major Task/Resp. Individuals	Walkdown	Focused Analysis	Documentation
Station Representative	0 3 5 6 7		
PRA Engineers	0 2 3 4 6 7 8	0 2 3 4	0 2 3 4
Fire Protection Engineers	23678	0	
PRA Augmented Staff		0 2 3 4	0 2 3 4
Seismic/Fire Experts	0 0 7 8	0	
Licensing/Reg. Assurance			6
Site VP			6
Proj. Team Leader			
	 ① Identify Sample of Pre- Screened Items for Walkdown ② Develop Proc./Guidelines ③ Schedule Equip. to Walkdown ④ Schedule Expert Time ⑤ Access Arrangements ⑤ Walkdown Packets Assemble ⑦ Coordinate Walkdown Support ⑧ Record Results 	 Initial Matrix Run Detailed Seismic & Fire Analysis Final Matrix Run Analyze Other External Events [Tornado, Flood, Etc.] 	 Modify IPE Matrices Compile Results Identify Potential Improvements Write Report Senior Management Review Submit to NRC



Major Task/Resp. Individuals	SSEL Completion	Relay SSEL Completion	Walkdown Planning	
Station Representative	0	0 2 4 5 6	003560	
Operations Dept.	0			
SSEL Cognizant Eng.	3			
Relay SSEL Cognizant Eng.		4 5 6 7 8		
Seismic Capability Eng.		006	0000	
A/E or Specialty A/E	Ø 3	@ \$ \$ 7 ®	6 Ø	
Third Party SQUG Expert		3	@	
Licensing/Reg. Assurance				
Site Eng. & Const. Manager		2		
Site VP			03	
Proj. Team Leader		0 2	0 0	
	 Ops. Review On Existing SSEL Finish SSEL After Ops. Review Review & Sign-Off SSEL 	 Prepare Options for Relay List Completion Present/Select Relay List Completion Option Give Relay SSEL SQUG Training Screen Out Non-Essential Relays Screen Out Seismically Insensitive Relays Evaluate Remaining Relays Initial Fill-Out of G.U. Forms Review & Sign-Off 	 Development of Project Plan of Alternatives Presentation to Station/Site VP Selection of Method of Implementation Give Walkdown Training Coordinate Walkdown Support at Station Prepare, Review & Issue Project/Plan Guidelines to Perform SQUG Walkdowns Prepare Walkdown Folders 	



Major Task/Resp. Individuals	SQUG Walkdown	Anchorage Evaluation	Outlier Resolution	SQUG Report Submittal
Station Representative			0 2	0 3
Mechanical Maintenance	3			
Operations Dept.				
SSEL Cognizant Eng.				
Relay SSEL Cognizant Eng.				
Seismic Capability Eng.	000	003	D	0
A/E or Specialty A/E	000	000	0	0
Third Party SQUG Expert	0			0
Licensing/Reg. Assurance				3
Site Eng. & Const. Manager				
Site VP				3
Proj. Team Leader				
	 Pilot Walkdown Perform Walkdown Anchor Bolt Torque Testing Fill Out SEWS & SVDS 	 Sketch Out Anchorage Pattern Analyze Anchorage Pattern Document Results 	 Develop Solution Identify Follow-Up Actions 	 Prepare Report Independent Audit CECo Approve & Submit Report to NRC

SUMMARY

۱_Ce

- * CECo's IPEEE program will fulfill NRC's IPEEE objectives.
- * Matrix modelling is a proven technology. Applications to PRA date back to the early 1980's (Zion Probabilistic Safety Study).
- * Matrix modelling represents an innovative application for evaluating IPEEE.
- * CECo's multi-step screening is realistic and conservative.
- * Matrix methodology will produce a comprehensive evaluation of seismic and fire events at each of the CECo plants.