

October 15, 1993

Docket Nos. 50-237
and 50-249

DISTRIBUTION:
NRC & Local PDRs
J. Roe
J. Dyer
J. Stang
ACRS(10)
T. Le

Docket File
PDIII-2 r/f
J. Zwolinski
C. Moore
OGC
B. Clayton RIII
B. Perch

Mr. D. L. Farrar
Manager, Nuclear Regulatory Services
Commonwealth Edison Company
Executive Towers West III, Suite 500
1400 OPUS Place
Downers Grove, Illinois 60515

Dear Mr. Farrar:

SUBJECT: COMPLIANCE WITH SUPPLEMENT 1 OF BULLETIN 90-01, "LOSS OF FILL-OIL IN TRANSMITTERS MANUFACTURED BY ROSEMOUNT" (TAC NOS. M85383 AND M85384)

On December 22, 1992, the U. S. Nuclear Regulatory Commission (NRC) issued Supplement 1 to NRC Bulletin 90-01 (Bulletin) concerning the loss of fill-oil in transmitters manufactured by Rosemount. The actions described in the supplement supersede the actions requested in the original bulletin. By letter dated March 5, 1993, Commonwealth Edison Company (CECo) responded indicating that with replacement of three transmitters, Dresden, Units 2 and 3, would be in full compliance with the recommended actions of the Bulletin. Based on a recent inspection, it was confirmed that the three transmitters had been replaced. Therefore, the NRC staff finds that Dresden, Units 2 and 3, is in compliance with Supplement 1 to Bulletin 90-01. We consider actions under TAC Nos. M85383 and M85384 to be complete. Please retain any records of your actions in response to this Bulletin, as subsequent inspection activities may be conducted in regards to this issue.

Sincerely,

Original signed by:

John F. Stang, Project Manager
Project Directorate III-2
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

cc: See next page

OFC	LA/PDIII-2	PM/PDIII-2	D:PDIII-2			
NAME	CMOORE	JSTANG	JDYER JM			
DATE	10/15/93	10/15/93	10/15/93	/ /93	/ /93	/ /93
COPY	(YES/NO)	(YES/NO)	(YES/NO)	YES/NO	YES/NO	YES/NO

NRC FILE CENTER COPY

9310220038 931015
PDR ADOCK 05000237
G PDR

JEOL
1/0

Mr. D. L. Farrar
Commonwealth Edison Company

Dresden Nuclear Power Station
Unit Nos. 2 and 3

cc:

Michael I. Miller, Esquire
Sidley and Austin
One First National Plaza
Chicago, Illinois 60690

Mr. G. Spedl
Plant Manager
Dresden Nuclear Power Station
6500 North Dresden Road
Morris, Illinois 60450-9765

U. S. Nuclear Regulatory Commission
Resident Inspectors Office
Dresden Station
6500 North Dresden Road
Morris, Illinois 60450-9766

Chairman
Board of Supervisors of
Grundy County
Grundy County Courthouse
Morris, Illinois 60450

Regional Administrator
Nuclear Regulatory Commission, Region III
799 Roosevelt Road, Bldg. #4
Glen Ellyn, Illinois 60137

Illinois Department of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704

Robert Neumann
Office of Public Counsel
State of Illinois Center
100 W. Randolph
Suite 11-300
Chicago, Illinois 60601