



Commonwealth Edison
Dresden Nuclear Power Station
6500 North Dresden Road
Morris, Illinois 60450
Telephone 815/942-2920

May 31, 1994

GFSLTR 94-0175

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Licensee Event Report 93-017-01, Docket 50-249 is being submitted to correct typographical errors found in the original report.

Sincerely,

Gary F. Spedl
Station Manager
Dresden Station

GFS/GP:cfq

Enclosure

cc: J. Martin, Regional Administrator, Region III
NRC Resident Inspector's Office
File/NRC
File/Numerical

gfs9410175.94

000062

9406080316 940531
PDR ADDCK 05000249
S PDR

JE22/1

DAP FORM 02-08C
 SUPPLEMENTAL REPORT TO LER

DVR NO.					SYSTEM AFFECTED	
	STA	UNIT	YEAR	NO.		
D	- 12	- 3	- 93	- 017	2300	
<u>PART 1</u> TITLE OF EVENT					<u>OCCURRED</u>	
High Pressure Coolant Injection Declared Inoperable Due to Broken Room Cooler Drive Belts					11/01/93	2250
					DATE	TIME
REASON FOR SUPPLEMENTAL REPORT						
To correct typographical errors found in the original report.						
<u>PART 2</u>						
ACCEPTANCE BY STATION REVIEW					<i>[Signature]</i>	<i>[Signature]</i>
DATE					6-2-94	6/2/94
SUPPLEMENTAL REPORT APPROVED AND AUTHORIZED FOR DISTRIBUTION					<i>[Signature]</i>	6/2/94
					STATION MANAGER	DATE