

July 1, 1994

Docket Nos. 50-237
and 50-249

Mr. D. L. Farrar, Manager
Nuclear Regulatory Services
Commonwealth Edison Company
Executive Towers West III, Suite 500
1400 OPUS Place
Downers Grove, Illinois 60515

Dear Mr. Farrar:

SUBJECT: EVALUATION OF REQUEST FOR RELIEF RELATED TO THE THIRD TEN-YEAR
INTERVAL INSERVICE INSPECTION PROGRAM FOR DRESDEN NUCLEAR POWER
STATION, UNITS 2 AND 3 (TAC NOS. M89315 AND M89316)

By letter dated February 24, 1994, as supplemented by letter dated April 6, 1994, you submitted Revision 3 to the third ten-year interval inservice inspection (ISI) program plan. Revision 3 requests the staff's review and approval of Relief Request PR-14, Revision 1, PR-18 and CR-17.

The staff has reviewed the relief requests. The staff's evaluation and conclusions are contained in the enclosed Safety Evaluation (SE). The staff has concluded that the alternative testing proposal in Relief Request PR-18 is acceptable and relief is authorized pursuant to 10 CFR 50.55a(a)(3)(ii). Use of Relief Request PR-18 for joints not classified as hard joints is denied.

Relief request PR-14 was previously granted by letter dated May 25, 1994. Relief request CR-17 and specific changes in Revision 3 of the ISI program plan will be evaluated under separate cover.

Sincerely,
Original signed by:

John F. Stang, Project Manager
Project Directorate III-2
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

9408080059 940701
PDR ADDCK 05000237
P PDR

Enclosure:
Safety Evaluation

cc w/enclosure:
See next page

DISTRIBUTION:

Docket File OGC
NRC & Local PDRs BClayton, RIII
PDIII-2 R/F JRoe
JZwolinski RCapra
JStang CMoore
ACRS (10) 040023 JStrosnider, EMCB

NRC FILE CENTER COPY

*SEE PREVIOUS CONCURRENCE

OFC	LA: PDIII-2	RM: PDIII-2	EMCB	OGC	D: PDIII-2
NAME	CMoore	JStang	JStrosnider*	MYoung*	RCapra*
DATE	7/5/94	7/5/94	07/01/94	07/01/94	07/01/94
COPY	YES/NO	YES/NO	YES/NO	YES/NO	YES/NO

AA3

DFD 1

Mr. D. L. Farrar
Commonwealth Edison Company

Dresden Nuclear Power Station
Unit Nos. 2 and 3

cc:

Michael I. Miller, Esquire
Sidley and Austin
One First National Plaza
Chicago, Illinois 60690

Mr. G. Spedl
Plant Manager
Dresden Nuclear Power Station
6500 North Dresden Road
Morris, Illinois 60450-9765

U. S. Nuclear Regulatory Commission
Resident Inspectors Office
Dresden Station
6500 North Dresden Road
Morris, Illinois 60450-9766

Chairman
Board of Supervisors of
Grundy County
Grundy County Courthouse
Morris, Illinois 60450

Regional Administrator
U. S. NRC, Region III
801 Warrenville Road
Lisle, Illinois 60532-4351

Illinois Department of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704