



Commonwealth Edison
1400 Opus Place
Downers Grove, Illinois 60515

August 23, 1994

Mr. William Russell
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Document Control Desk

Subject: Braidwood Station Units 1 and 2
Byron Station Units 1 and 2
Dresden Station Units 2, and 3
LaSalle County Station Units 1 and 2
Quad Cities Station Units 1 and 2
Zion Station Units 1 and 2

Commonwealth Edison Company Position on Molded Case
Circuit Breaker Certification In Accordance with Bulletin 88-10

NRC Dockets 50-454 and 50-455
NRC Dockets 50-456 and 50-457
NRC Dockets 50-237 and 50-249
NRC Dockets 50-373 and 50-374
NRC Dockets 50-254 and 50-265
NRC Dockets 50-295 and 50-304

- References: (1) NRC Bulletin 88-10: Nonconforming Molded Case Circuit Breakers, dated Nov. 22, 1988
- (2) M. H. Richter (ComEd) letter to USNRC dated April 4, 1989 providing ComED's response to Bulletin 88-10
- (3) NRC Bulletin 88-10, Suppl 1: Nonconforming Molded Case Circuit Breakers, dated August 3, 1989
- (4) M. H. Richter (ComEd) letter to USNRC dated September 13, 1989 providing ComED's response to Bulletin 88-10, Suppl. 1

k:dave:bul8810:1

500038

9409020161 940823
PDR ADOCK 05000237
E PDR

IF 11/0

Mr. William Russell

(2)

August 23, 1994

The purpose of this letter is to inform the Commission of a change in Commonwealth Edison's methodology for meeting Action 7 of references (1) and (3). This letter modifies the method of dedication of molded case circuit breakers described in Action 7 in accordance with the following:


Only MCCBs that meet the criteria of Action 7 are being maintained as stored spares for future use in safety-related applications at all stations. Present breaker orders (and all future procurements) require that the vendor is to provide documentation establishing traceability to the breaker manufacturer.

Any breaker not purchased under a 10 CFR 21 Appendix B Program which are intended to be used in safety-related applications will be dedicated under our current approved program governed by ENC-QE-70 Procedures.

This program meets or exceeds the requirements set forth in the subject bulletin.

If there are any questions or comments, please contact me at (708) 663-7292.

Sincerely,



Martin J. Vonk
Generic Issues Administrator
Nuclear Regulatory Services

cc: J. Martin, Regional Administrator-RIII
R. Capra, Director of Directorate III, NRR
G. Dick, ComEd Generic Issues Project Manager, NRR