3.3 LIMITING CONDITIONS FOR OPERATION BASES

Reactivity Limitations Α.

Verified using

an insequence

control rod withdrawal at

the beginning-

9410170368 94101;

ADOCK 05000237

PDR

PDR

of-life fuel

Reactivity margin - core loading 1.

> The core reactivity limitation is a restriction to be applied principally to the design of new fuel which may be loaded in the core or into a particular refueling pattern. Satisfaction of the limitation can only be demonstrated at the time of loading and must be such that it will apply to the entire subsequent fuel cycle. The generalized form is that the reactivity of the core loading will be limited so the core can be made subcritical by at least R + 0.25% Δk in the most reactive condition during the operating cycle, with the strongest control rod fully withdrawn and all others fully inserted. The value of R in $\% \Delta k$ is the amount by which the core reactivity, at any time in the operating cycle, is calculated to be greater than at the time of the check; i.e., the initial loading. R must be a positive quantity or zero. A core which contains temporary control or other burnable neutron absorbers may have a reactivity characteristic which increases with core lifetime, goes through a maximum, and decreases thereafter.

The value of R is the difference between the calculated core reactivity at the beginning of the operating cycle and the calculated value of the core reactivity any time later in the cycle where it would be greater than at the beginning. The value of Rshall include the potential shutdown margin loss assuming full $B_{\sigma}C$ settling in all inverted poison tubes present in the core. A new value of R must be determined for each new fuel cycle.

cycle conditions The 0.25% Δk in the expression R + 0.25% Δk is provided as a finite, demonstrable, subcriticality margin. This margin is demonstrated by full withdrawal of the strongest rod and partia withdrawal of an-adjacent-rod to a position-calculated_to insert-at least R-+ 0.25% Ak in reactivity. Observation of subcriticality τ his in this condition assures subcriticality with not only the stongest rod fully withdrawn but a margin of at least R + 0.25% Δk beyond this.

> 2. Reactivity margin - stuck control rods

> > Specification 3.3.A.2 requires that a rod be taken out of service if it cannot be moved with drive pressure. If the rod is fully inserted and then disarmed electrically, (Note: To disarm the drive electrically, four amphenol type plug connectors are removed from the drive insert and withdrawal solenoids, rendering the drive immovable. This procedure is equivalent to valving out the drive

Amendment No. 114

3.3 LIMITING CONDITIONS FOR OPERATION BASES

A. Reactivity Limitations

using

This

an insequence control rod withdrawal at the beginning-of-life

verified

1. Reactivity margin - core loading

The core reactivity limitation is a restriction to be applied principally to the design of new fuel which may be loaded in the core or into a particular refueling pattern. Satisfaction of the limitation can only be demonstrated at the time of loading and must be such that it will apply to the entire subsequent fuel cycle. The generalized form is that the reactivity of the core loading will be limited so the core can be made subcritical by at least R + 0.25% Δk in the most reactive condition during the operating cycle, with the strongest control rod fully withdrawn and all other fully inserted. The value of R in $\%\Delta k$ is the amount by which the core reactivity, at any time in the operating cycle, is calculated to be greater than at the time of the check; i.e., the initial loading. R must be a positive quantity or zero. A core which contains temporary control or other burnable neutron absorbers may have a reactivity characteristic which increases with core lifetime, goes through a maximum, and decreases thereafter.

fuel cycle conditions The value of R is the difference between the calculated core reactivity at the beginning of the operating cycle and the calculated value of the core reactivity any time later in the cycle where it would be greater than at the beginning. The value of R shall include the potential shutdown margin loss assuming full B₄C settling in all inverted poison tubes present in the core. A new value of R must be determined for each new fuel cycle.

> The 0.25% Δk in the expression R + 0.25% Δk is provided as a finite, demonstrable. subcriticality margin. This margin is demonstrated by full withdrawal of the strongest rod and partial withdrawal of an adjacent rod to a position calculated to inset at least R + 0.25% Ak in reactivity. Observation of-subcriticality in this condition assures subcriticality with not only the strongest rod fully withdrawn but a margin of at least \mathbf{R} + 0.25% $\Delta \mathbf{k}$ beyond this.

2. Reactivity margin - stuck control rods

Specification 3.3.A.2 requires that a rod be taken out of service if it cannot be moved with drive pressure. If the rod is fully inserted and then disarmed electrically, (Note: To disarm the drive electrically, four amphenol type plug connectors are removed from the drive insert and withdrawal solenoids, rendering the drive immovable. This procedure is equivalent to valving out the drive and is preferred, as drive water cools and minimizes crud accumulation in the drive.), it is in a safe position of maximum contribution to shutdown reactivity. If it is disarmed electrically in a nonfully inserted position, that position shall be consistent with the shutdown reactivity limitation stated in Specification 3.3.A.1. This assures that the core can be shut down at all times with the remaining control rods, assuming the strongest operable control rod does not insert. An allowable pattern for control rods valved out of service, which shall meet the specification, will be available to the operator. The number of rods permitted to the inoperable could be many more than the eight allowed by the specification, particularly late in the operation cycle; however, the occurrence of more than eight could be indicative of a generic control rod drive problem and the reactor will be shut down.

Also if damage within the control rod drive mechanism and in particular, cracks in drive internal housings, cannot be ruled out, then a generic problem affecting a number of drives cannot be ruled out. Circumferential cracks resulting from stress assisted intergranular corrosion have occurred in the collect housing of drives at several BWR's. This type of cracking could occur in a number of drives and if the cracks propagated until severance of the collet housing occurred, scram could be prevented in the affected rods. Limiting the period of operation with a potentially severed collet housing and requiring increased surveillance after detecting one stuck rod will assure that the reactor will not be operated with a large number of rods with failed collet housings.

DRESDEN II Amendment No. 82 DPR-19

3.3 LIMITING CONDITION FOR OPERATION BASES

Α. Reactivity Limitations

> 1. Reactivity margin--core loading

> > The core reactivity limitation is a restriction to be applied principally to the design of new fuel which may be loaded in the core or into a particular refueling pattern. Satisfaction of the limitation can only be demonstrated at the time of loading and must be such that it will apply to the entire subsequent fuel cycle. The generalized form is that the reactivity of the core loading will be limited so the core can be made sub-critical by at least R + 0.25% delta k in the most reactive condition during the operating cycle, with the strongest control rod fully withdrawn and all others fully inserted. The value of R in % delta k is the amount by which the core reactivity, at any time in the operating cycle, is calculated to be greater than at the time of the check; i.e., the initial loading. R must be a positive quantity or zero. A core which contains temporary control or other burnable neutron absorbers may have a reactivity characteristic which increases with core lifetime, goes through a maximum and then decreases thereafter. See Figure 3.3.2 of the SAR for such a curve.

The value of R is the difference between the calculated core reactivity at the beginning of the operating cycle and the calculated value of core reactivity any time later in the cycle where it would be greater than at the beginning. For the first fuel cycle, R was calculated to be not greater than 0.10% delta k. A new value of R must be determined for each fuel cycle.

The 0.25% delta k in the expression R + 0.25% delta k is provided as a finite, demonstrable, sub-criticality marging This margin is demonstrated by full withdrawal of the strongest rod and partial withdrawal of an adjacent Fod-to-a-position-calculated-to-insert-at-least R + 0.25% delta k.in_reactivity.--Observation_of_sub-criticality_in this condition assures sub-criticality with not only the strongest rod-fully-withdrawn-but at least a R-+-0.25% -delta k margin_beyond_this.

This margin is verified using an insequence control rod withdrawal at the beginning-of-life fuel cycle conditions. This assures subcriticality with not only the strongest rod fully withdrawn with not only the strongest rod fully withdrawn but at least a R+0.25% delta k margin beyond this.

B 3/4.3-14

SDEN III Amendment No. 50, 63, 75

DPR-25

3.3 LIMITING CONDITION FOR OPERATION BASES

Reactivity Limitations Α.

1. Reactivity margin--core loading

The core reactivity limitation is a restriction to be applied principally to the design of new fuel which may be loaded in the core or into a particular refueling pattern. Satisfaction of the limitation can only be demonstrated at the time of loading and must be such that it will apply to the entire subsequent fuel cycle. The generalized form is that the reactivity of the core loading will be limited so the core can be made sub-critical by at least R + 0.25% delta k in the most reactive condition during the operating cycle, with the strongest control rod fully withdrawn and all others fully inserted. The value of R in % delta k is the amount by which the core reactivity, at any time in the operating cycle, is calculated to be greater than at the time of the check; i.e., the initial loading. R must be a positive quantity or zero. A core which contains temporary control or other burnable neutron absorbers may have a reactivity characteristic which increases with core lifetime, goes through a maximum and then decreases thereafter. See Figure 3.3.2 of the SAR for such a curve.

The value of R is the difference between the calculated core reactivity at the beginning of the operating cycle and the calculated value of core reactivity any time later in the cycle where it would be greater than at the beginning. The value of R shall include the potential shutdown margin loss assuming full B₄C setting in all inverted poison tubes present in the core. A new value of R must be determined for each fuel cycle.

The 0.25% delta k in the expression R + 0.25% delta k is provided as a finite, demonstrable, sub-criticality margin. This margin is demonstrated by full withdrawal of the strongest rod-and partial withdrawal of an adjacent. rod to a position calculated to insert at least R + 0.25% delta k in reactivity. Observation of sub-criticality inthis condition assures sub-criticality with not only the strongest rod fully withdrawn but at least a R-+ 0.25% delta k-margin-beyond this.

NOTE: This change issued by letter dated 08/27/75 which noted that 0.02% delta k should be included in the value.

B 3/4.3-14

This margin is verified using an insequence control rod withdrowal at the beginning-of-life fuel cycle conditions, this assures subcriticality with not only the strongest rod fully withdrawn but at least a R+0.25% delta E margin. beyond this,

QUAD-CITIES **DPR-29**

3.3 LIMITING CONDITIONS FOR OPERATION BASES

A. **Reactivity Limitations**

1. Reactivity Margin -- core loading

The core reactivity limitation is a restriction to be applied principally to the design of new fuel which may be loaded in the core or into a particular refueling pattern. Satisfaction of the limitation can only be demonstrated at the time of loading and must be such that it will apply to the entire subsequent fuel cycle. The generalized form is that the reactivity of the core loading will be limited so the core can be made subcritical by at least R + 0.25% k in the most reactive condition during the operating cycle, with the strongest control rod fully withdrawn and all others fully inserted. The value of R in % k is the amount by which the core reactivity, at any time in the operating cycle, is calculated to be greater than at the time of the check; i.e., the initial loading. R must be a positive quantity or zero. A core which contains temporary control or other burnable neutron absorbers may have a reactivity characteristic which increases with core lifetime, goes through a maximum, and decreases thereafter.

The value of R is the difference between the calculated core reactivity at the beginning of the operating cycle and the calculated value of the core reactivity any time later in the cycle where it would be greater than at the beginning. The value of R shall include the potential shutdown margin loss assuming full B₄C settling in all inverted poison tubes present in the core. A new value of R must be determined for each new fuel cycle.

The 0.25% k in the expression R + 0.25% k is provided as a finite, demonstrable, subcriticality margin. This margin is verified using an insequence control rod withdrawal at the beginning-of-life fuel cycle conditions. This assures subcriticality with not only the strongest rod fully withdrawn but a margin of at least R + 0.25% k beyond this.

2. Reactivity margin -- stuck control rods

Specification 3.3.A.2 requires that a rod be taken out of service if it cannot be moved with drive pressure. If the rod is fully inserted and then disarmed electrically, (Note: To disarm the drive electrically, four amphenol type plug connectors are removed from the drive insert and withdrawal solenoids, rendering the drive immovable. This procedure is equivalent to valving out the drive

3.3/4.3-9

Amendment No. 114

Bases change per 10/13/94

letter, G.Benes to

USNRC

3.3 LIMITING CONDITIONS FOR OPERATION BASES

- A. Reactivity Limitations
 - 1. Reactivity Margin -- core loading

The core reactivity limitation is a restriction to be applied principally to the design of new fuel which may be loaded in the core or into a particular refueling pattern. Satisfaction of the limitation can only be demonstrated at the time of loading and must be such that it will apply to the entire subsequent fuel cycle. The generalized form is that the reactivity of the core loading will be limited so the core can be made subcritical by at least R + 0.25% k in the most reactive condition during the operating cycle, with the strongest control rod fully withdrawn and all others fully inserted. The value of R in % k is the amount by which the core reactivity, at any time in the operating cycle, is calculated to be greater than at the time of the check; i.e., the initial loading. R must be a positive quantity or zero. A core which contains temporary control or other burnable neutron absorbers may have a reactivity characteristic which increases with core lifetime, goes through a maximum, and decreases thereafter.

The value of R is the difference between the calculated core reactivity at the beginning of the operating cycle and the calculated value of the core reactivity any time later in the cycle where it would be greater than at the beginning. The value of R shall include the potential shutdown margin loss assuming full B_4C settling in all inverted poison tubes present in the core. A new value of R must be determined for each new fuel cycle.

Bases change perThe 0.25% k in the expression R + 0.25% k is provided as a finite, demonstableBases change persubcriticality margin. This margin is verified using an insequence control rod10/13/94 letter,withdrawal at the beginning-of-life fuel cycle conditions. This assures subcriticality withG. Benes to USNRCnot only the strongest rod fully withdrawn but a margin of at least R + 0.25% k beyond this.

2. Reactivity margin -- stuck control rods

Specification 3.3.A.2 requires that a rod be taken out of service if it cannot be moved with drive pressure. If the rod is fully inserted and then disarmed electrically, (Note: To disarm the drive electrically, four amphenol type plug connectors are removed from the drive insert and withdrawal solenoids, rendering the drive immovable. This procedure is equivalent to valving out the drive and is preferred, as drive water cools and minimizes crud accumulation in the drive), it is in a safe position of maximum contribution to shutdown reactivity. If it is disarmed electrically in a nonfully inserted position, that position shall be consistent with the shutdown reactivity limitation stated in specification 3.3.A.1. This assures that the core can be shut down at all times with the remaining control rods, assuming the strongest operable control rod does not insert. An allowable pattern for control rods valved out of service, which shall meet the specification, will be available to the operator. The number of rods permitted to the inoperable could be many more than the eight allowed by the specification, particularly late in the operation cycle; however, the occurrence of more than eight could be indicative of a generic control rod drive problem and the reactor will be shut down.

Also, if damage within the control rod drive mechanism and in particular, cracks in drive internal housings, cannot be ruled out, then a generic problem affecting a number of drives cannot be ruled out. Circumferential cracks resulting from stress assisted intergranular corrosion have occurred in the collet housing of drives at several BWR's. This type of cracking could occur in a number of drives and if the cracks propagated until severance of the collet housing occurred, scram could be prevented in the affected rods. Limiting the period of operation with a potentially severed collet housing and requiring increased surveillance after detecting one stuck rod will assure that the reactor will not be operated with a large number of rods with failed collet housings.

DRESDEN II DPR-19 AMENDMENT NO. 82

3.3 LIMITING CONDITION FOR OPERATIONS BASES

A. Reactivity Limitations

1. Reactivity margin -- core loading

The core reactivity limitation is a restriction to be applied principally to the design of new fuel which may be loaded in the core or into a particular refueling pattern. Satisfaction of the limitation can only be demonstrated at the time of loading and must be such that it will apply to the entire subsequent fuel cycle. The generalized form is that the reactivity of the core loading will be limited so the core can be made sub-critical by at least R + 0.25% delta k in the most reactive condition during the operating cycle, with the strongest control rod fully withdrawn and all others fully inserted. The value of R in % delta k is the amount by which the core reactivity, at any time in the operating cycle, is calculated to be greater than at the time of the check; i.e., the initial loading. R must be a positive quantity or zero. A core which contains temporary control or other burnable neutron absorbers may have a reactivity characteristic which increases with core lifetime, goes through a maximum and then decreases thereafter. See Figure 3.3.2 of the SAR for such a curve.

The value of R is the difference between the calculated core reactivity at the beginning of the operating cycle and the calculated value of core reactivity any time later in the cycle where it would be greater than at the beginning. For the first fuel cycle, R was calculated to be not greater than 0.10% delta k. A new value of R must be determined for each fuel cycle.

Bases change per 10/13/94 letter, G. Benes to USNRC The 0.25% delta k in the expression R + 0.25% delta k is provided as a finite, demonstrable, sub-criticality margin. This margin is verified using an insequence control rod withdrawal at the beginningof-life fuel cycle conditions. This assures sub-criticality with not only the strongest rod fully withdrawn but at least a R + 0.25% delta k margin beyond this.

B 3/4.3-14

DRESDEN III DPR-25 AMENDMENT NO. 50, 93, 75

3.3 LIMITING CONDITION FOR OPERATIONS BASES

A. Reactivity Limitations

1. Reactivity margin -- core loading

The core reactivity limitation is a restriction to be applied principally to the design of new fuel which may be loaded in the core or into a particular refueling pattern. Satisfaction of the limitation can only be demonstrated at the time of loading and must be such that it will apply to the entire subsequent fuel cycle. The generalized form is that the reactivity of the core loading will be limited so the core can be made sub-critical by at least R + 0.25% delta k in the most reactive condition during the operating cycle, with the strongest control rod fully withdrawn and all others fully inserted. The value of R in % delta k is the amount by which the core reactivity, at any time in the operating cycle, is calculated to be greater than at the time of the check; i.e., the initial loading. R must be a positive quantity or zero. A core which contains temporary control or other burnable neutron absorbers may have a reactivity characteristic which increases with core lifetime, goes through a maximum and then decreases thereafter. See Figure 3.3.2 of the SAR for such a curve.

The value of R is the difference between the calculated core reactivity at the beginning of the operating cycle and the calculated value of core reactivity any time later in the cycle where it would be greater than at the beginning. The value of R shall include the potential shutdown margin loss assuming full B_4C settling in all inverted poison tubes present in the core. A new value of R must be determined for each fuel cycle.

Bases change per 10/13/94 letter, G. Benes to USNRC The 0.25% delta k in the expression R + 0.25% delta k is provided as a finite, demonstrable, sub-criticality margin. This margin is verified using an insequence control rod withdrawal at the beginning-of-life fuel cycle conditions. This assures sub-criticality with not only the strongest rod fully withdrawn but at least a R + 0.25% delta k margin beyond this.

B 3/4.3-14

NOTE: This change issued by letter dated 08/27/75 which noted that 0.02% delta k should be included in the value.