U. S. NUCLEAR REGULATORY COMMISSION

REGION III

Reports No. 50-237/94016(DRS); No. 50-249/94016(DRS)

Licenses No. DPR-19; No. DPR-25

Licensee: Commonwealth Edison Company Executive Towers West III 1400 Opus Place - Suite 300 Downers Grove, IL 60515

Docket Nos. 50-237; 50-249

Facility Name: Dresden Nuclear Power Station - Units 2 and 3

Inspection At: Dresden Nuclear Power Station. Morris, IL

Inspection Conducted: August 15 through September 16, 1994

Inspection Team: D. Butler, Team Leader R. Winter, Assistant Team Leader

NRC Consultants: P. Eshleman, Parameter, Inc. J. Leivo, Parameter, Inc.

David S. Butler Approved By:

Approved By:

Ronald N. Gardner, Chief

Plant Systems Section

 $\frac{10/20/94}{\text{Date}}$

Inspection Summary

Inspection on August 15 - September 16, 1994 (Reports No. 50-237/94016(DRS); No. 50-249/94016(DRS))

Areas Inspected: Special announced systems based instrumentation and control inspection (SBICI) performed in accordance with NRC Inspection Procedure 93807.

<u>Results</u>: The team considered the design and operation of the instrumentation and control (I&C) loops reviewed and the I&C engineering and technical support to be adequate. A summary of strengths and weaknesses in I&C system design and engineering support are provided in the Executive Summary. The team identified one violation with two examples of inadequate post modification testing (Section 4.2). In addition, seven inspection followup items were identified (Sections 3.2.1.b, 3.2.2, 3.3.1.b, 3.3.2.b, 3.4.1, 3.5.1, and 3.7.1.b).

TABLE OF CONTENTS

			<u>Page</u>
Executive Summaryi			
1.0	Introd	luction	1
2.0	Action	on Previously Identified Inspection Items	1
3.0	Instru	ment Loops Reviewed	3
	3.1	Setpoint Calculation Methodology	5
	3.2	Suppression Pool (Torus) Temperature and Indication	6
	3.3	HPCI Initiation	7
	3.4	HPCI Turbine Trips	10
	3.5	HPCI Isolation Trips	10
	3.6	Condensate Storage Tank Level	11
	3.7	ATWS Recirculation Pump Trip and ARI	11
	3.8	ATWS Manual Initiation	11
	3.9	LPCI Initiation	12
	3.10	Reactor Water Level Narrow Range Indication	12
	3.11	Standby Gas Treatment Initiation	13
4.0	Engine	ering and Technical Support	13
5.0	Inspec	tion Followup Items	16
6.0	Exit M	eeting	16
Append	ix A -	Personnel Contacted	

Appendix B - Requests for Information

•

EXECUTIVE SUMMARY

During August 15 through September 16, 1994, a U. S. Nuclear Regulatory Commission (NRC) inspection team conducted a system based instrumentation and control inspection (SBICI) at the Dresden Nuclear Power Station, Units 2 and 3. The inspection focused on the design and configuration of selected safety related and important to safety instrumentation and control (I&C) systems and components. The inspection purpose was to: (1) determine if selected instrument setpoints were properly derived such that automatic actions would occur to prevent safety limits from being exceeded; (2) determine if calculations, supporting these setpoints, considered all appropriate uncertainties; (3) determine if setpoint calculation methods were technically consistent with accepted standards; and (4) evaluate I&C related activities, engineering and technical support (E&TS), and self assessment.

Instrument loop selection was based on the predominant accident scenarios identified in Dresden's individual plant examination (IPE) and updated final safety analysis report (UFSAR).

The team considered the design and operation of the instrument and control loops reviewed and I&C engineering technical support to be adequate. However, the team identified the following weaknesses:

· . :

- Several instrument setpoint calculations contained various unverified assumptions, carried inconsistent number precision through the calculations, or utilized calibration procedure and calculation tolerances that did not always agree.
- Several instrument calculations did not identify the setpoint analytical limit, or the environmental conditions that the I&C loops would encounter in the event of an accident.
- Two post modification tests did not demonstrate that modified systems would perform satisfactorily in service.

The team concluded that increased management attention was warranted in I&C design control areas, specifically in setpoint calculations.

The team identified the following positive attributes:

- The counterpart team was knowledgeable and experienced.
- The HPCI design basis document was good.
- The setpoint methodology used was technically sound and reflected current industry practices.

DETAILS

1.0 <u>Introduction</u>

Selected instrumentation and control (I&C) setpoints were examined in detail, including their design basis requirements, assumptions, calculations, and component configuration. In particular, the setpoint methodology (uncertainties or errors) associated with the selected instrumentation loops were evaluated to determine if setpoints were correct and adequate safety margin existed.

Instrument loop selection was based on the predominant accident scenarios identified in the individual plant examination (IPE) and the updated final safety analysis report (UFSAR).

The team walked down originally installed and as-modified I&C equipment for configuration and equipment types, reviewed component qualifications, testing, and calibration records. The team also assessed the licensee's engineering and technical support (E&TS) organization's capability with respect to personnel qualification and staffing, timely and adequate root cause analyses for failures and recurring problems, and involvement in design modifications and operations.

The areas reviewed and the concerns identified are described in Sections 3.0 and 4.0 of this report. Personnel who attended the exit meeting on September 16, 1994, are listed in Appendix A. A complete list of the team's requests for information are listed in Appendix B.

2.0 <u>Action on Previously Identified Inspection Findings</u>

a. <u>(Closed) Open Items (237/92028-03; 249/92028-03)</u>: The inspectors identified during fuse verification walkdowns that several control room porcelain fuse holders were identified as "withstand rated 10,000 Amps. rms." However, the fuses installed were short circuit rated (withstand capability) to 200,000 amperes.

In response, the licensee provided Calculation No. D-0050EF which identified the maximum available short circuit current as 1,487 amperes. Other than the porcelain fuse holders discussed in this open item, no others have been identified with a 10,000 ampere rating. The licensee is developing a fuse list. Approximately 80% of the known fuse population have been walked down. No other fuse holder discrepancies have been identified. The fuse list is tentatively scheduled for completion by December 1995. The team reviewed Dresden Administrative Procedure (DAP) No. 11-27, "Control and Maintenance of Fuses and The Fuse List," and concluded the licensee was adequately controlling fuses. This item is considered closed.

b. <u>(Closed) Open Item (237/91038-06)</u>: The EDSFI team was concerned that the swing (Unit 2/3 EDG) diesel room was excessively hot. The EDG generator, exciter and relays are rated for a maximum 122°F temperature. The swing diesel room was not provided with any forced ventilation when in the standby mode.

In response, the licensee now monitors the swing diesel room temperature once per shift. If the room temperature exceeds 118.4°F, the operator manually starts the room fan and runs the fan until the room temperature drops below 114.8°F. The team reviewed the outdoor afternoon temperatures recorded at Dresden during June 1994 and compared them to the swing diesel room temperatures. The highest outdoor afternoon temperature was 94.64°F and the room temperature was 98°F. The team concluded the licensee adequately addressed the swing diesel temperature concern. This item is considered closed.

c. <u>(Closed) Unresolved Items (237/91038-05; 249/91042-05; 249/92023-05)</u>: The licensee was unable to provide documentation to support that electrical cables were not thermally overloaded.

• , :

In response, the licensee completed a Cable Tray Temperature Measurement Program at Dresden and Quad Cities Stations. Eighteen routing point cable tray temperatures were measured and compared to a computer model. The measured and computed temperatures agreed very closely. The licensee intends to change the Sargent and Lundy Interactive Cable Engineering (SLICE) program to better reflect the actual cable tray thermal conditions. This program is tentatively scheduled for completion by June 1995. The team reviewed preliminary program results. The cable temperatures were adjusted based on a 40°C ambient temperature. No cable routing points exceeded their 90°C cable rating. The maximum cable temperature identified was $\approx 62°C$. The team concluded the licensee was adequately addressing potential cable overloading. These items are considered closed.

d. <u>(Closed) Violation (237/92028-02: 249/92028-02)</u>: The licensee failed to take corrective actions to replace improperly sized fuses used to protect safety related components and circuits. For example, two 30A fuses and one 40A fuse were installed in the Unit 2 EDG excitation cabinet, where the drawings specified 25A fuses.

In response, the licensee installed the correct fuses. In addition, the licensee strengthened DAP 11-27 to address fuse discrepancies. The team reviewed Calculation No. D0011-EF that concluded the installed fuses provided adequate protection. However, the calculation stated that the fuses specified on the drawings were the correct size. The team reviewed the fuse discrepancies identified in the past year and concluded that all of the discrepancies were adequately dispositioned. This item is considered closed.

e. <u>(Closed) Violation (237/92028-01; 249/92028-01)</u>: The station failed to follow plant procedures to locate, isolate and remove; enter an administrative LCO; and issue a JCO when appropriate for three acknowledged DC grounds.

In response, the licensee counseled the Operation's staff involved about the importance of procedure adherence. During the tailgate session, the three Notice of Violation examples were discussed. The team reviewed the DC grounds identified in the past 6 months. The licensee adequately implemented the ground detection procedure for three identified grounds. This item is considered closed.

<u>(Closed) Open Item (237/91016-04; 249/91016-04)</u>: The NRC was concerned that the original EDG output breaker trip logic design did not include a LOOP/LOCA trip signal to realign the EDG in the emergency mode when tested in parallel with offsite power. The potential existed to overload or backfeed the redundant bus during testing. This item was referred to NRR for resolution.

In response, NRR indicated that adding an emergency override feature as described in Regulatory Guide (RG) No. 1.108, "Periodic Testing of Diesel Generator Units Used as Onsite Electric Power Systems at Nuclear Power Plants," position C.1.b.3, would resolve the above concern. However, the RG 1.108 requirements were implemented for nuclear plants licensed after August 1977, that is, after Dresden's plants were licensed. Also, the NRC recognizes that these conditions (EDG in parallel with the grid for monthly testing) represent a limited window of vulnerability, and the probability of experiencing the above cited problems were very low. Therefore, NRR does not believe backfitting the EDG designs of these plants with the test override feature is sufficiently safety significant to warrant backfit. This item is considered closed.

g. <u>(Closed) Violation (237/92021-03; 249/92021-03)</u>: The licensee did not include four safety related SBGT current sensing relays in a calibration program.

In response, the licensee satisfactorily calibrated the four relays and added the relays to the calibration program. During the corrective action reviews, the licensee identified other relay types that require calibration, such as time delay relays (TDRs). The Safety Related Contact Testing Adequacy (SRCTA) program was expanded to include TDRs and other relay types in the program. The inspectors reviewed the TDR program and concluded the licensee had adequately addressed this concern. This item is considered closed.

3.0 <u>Instrument Loops Reviewed</u>

In assessing I&C capability, the team reviewed the plant's instrumentation and control system design, configuration and operation. The team reviewed the setpoint program, original and recent calculations, installed I&C equipment, I&C testing and procedures, equipment qualification, and compliance with regulations, design engineering standards and accepted engineering practices. The review was based on the following information:

- setpoint calculations
- system descriptions
- o UFSAR

÷ , ,

f.

- technical specifications (TSs)
- system design basis documents
- probabilistic risk assessment (PRA)
- o manufacturer documents
- o test and operating procedures
- o control logic diagrams
- elementary and loop schematic diagrams

The team conducted I&C equipment walkdowns to verify that the operational, environmental and seismic criteria had been correctly applied. For each instrument loop selected, the team reviewed the process sensing line and instrument design interface, and the trip device or control room indicator design.

The following instrumentation and control loops were reviewed:

<u>Unit 3</u>

- 1. Suppression Pool (torus)
 - a. Temperature
 - b. Level (indication and HPCI transfer
 - on high level in the torus)
- 2. HPCI Initiation

T . .

- a. Low-low reactor water level
- b. High drywell pressure
- 3. HPCI Turbine Trips
 - a. High reactor water level
 - b. High turbine exhaust pressure
 - c. Low booster pump suction pressure
- 4. HPCI Isolation Trips
 - a. High steam line flow
 - b. High steam line area temperature
 - c. Low reactor pressure
- 5. Condensate Storage Tank
 - a. Level (high level transfer HPCI to suppression pool)
 - b. Level Indication

<u>Unit 2</u>

- 1. ATWS Recirculation Pump Trip
 - a. High reactor pressure
 - b. Low-low reactor water level
- 2. ATWS Initiation
 - a. High torus water average temperature alarm
 - b. High reactor dome pressure
 - c. Low-low reactor water level alarm
- 3. LPCI Initiation
 - a. High drywell pressure
 - b. Low-low Rx level coincident with low reactor pressure or
 - c. Low-low Rx level sustained for 8.5 minutes
- 4. LPCI System Protection
 - a. Low pressure injection permissive
 - b. Keep fill system
- 5. Reactor Vessel Level
 - a. Level indication (narrow range)
 - b. Low reactor water level trip (RPS)
- 6. Standby Gas Treatment (secondary containment initiation)
 - a. High reactor building air monitor radiation
 - b. Group 2 primary containment isolation
 - Low reactor water level
 - High drywell pressure
 - High drywell radiation

3.1 <u>Setpoint Calculation Methodology</u>

3.1.1 <u>Setpoint Calculation and Basis</u>

•

The team reviewed Engineering Procedure Nos. TID-E/I&C-10, "Analysis of Instrument Channel Setpoint Error and Instrument Loop Accuracy," and TID-E/I&C-20, "Basis for Analysis of Instrument Channel Setpoint Error and Instrument Loop Accuracy." These procedures are used as the method and basis for instrument channel setpoint calculation preparation, review, approval and loop accuracy analysis. The team concluded that the methodology was technically sound, consistent with current industry practices, such as ISA 67.04-1988, and sufficiently comprehensive for their intended purpose.

The calculations reviewed by the team were consistent with the licensee's methodology, with the following exceptions:

- a. Several unverified assumptions were referenced in the calculations reviewed, such as:
 - unissued draft design sketch
 - untraceable design information identified on telecon memos
 - several calculations used instrument seismic or environmental accuracy data only if it was available or assumed an accuracy

Collectively, the team considered these examples of weak design calculation controls.

- b. Inconsistent number precision was carried through the calculations. The number of decimal places used in the calculations did not match the measurement precision in the calibration procedures. However, the team did not identify any instances where this practice resulted in unacceptable setpoint margin.
- c. Calculations used manufacturer instrument drift data rather than station historical drift data.

The licensee indicated that a program was being developed to collect and analyze historical drift data for setpoint determinations. This was acceptable to the team.

d. Several calculations prepared by contractors were presented in a study format rather than an engineering calculation format. The team noted that calculations performed by ComEd were more focused from input to the finished product. The team did not identify any errors attributable to calculation format. The contractors did prepare a useful and auditable "Master Calculation" for reactor water level (RWL) calculations. The master calculation established the general assumptions and bases for more detailed calculations involving RWL. The team considered the "master calculation" a good approach.



3.1.2 <u>Environmental and Seismic Effects</u>

•• • •

The team identified several examples where the licensee identified instrument seismic or environmental effects in the calculations only if manufacturer information was available. The calculations did not always clearly state the environment and accident conditions that the instrument loop must function in. In some instances, the calculations appeared generally limited to determining numerical values for loop error based on available data, rather than serving as the basis for loop performance during a DBA. While the calculations appeared correct within this limited scope, they were not always useful for drawing conclusions about instrument loop performance during all operating conditions. However, sufficient margin existed in the calculations that the team did not identify any operability concerns.

3.2 <u>Suppression Pool (Torus) Temperature and Level</u>

The instruments selected for review included torus bulk temperature (TR-3-1641-9) and water level (LI-3-1602-3, narrow range and LI-3-1640-10A, wide range). These indication channels are used to maintain suppression pool operating limits within technical specification limiting conditions for operation and are considered RG 1.97, Category 1 instruments. In addition, the team reviewed high torus level float switches (LS-2351A/B) located in float chambers. These switches are used following an accident for automatic HPCI suction transfer from the condensate storage tank to the torus.

3.2.1 <u>Setpoint Calculation and Basis</u>

- a. Prior to the I&C inspection, the licensee identified that the torus bulk temperature procedure operating limits did not allow sufficient margin for instrument uncertainties. The licensee performed an operability evaluation for this condition and was implementing corrective actions during the inspection. The operating limits were changed to allow additional margin for measurement error. This was acceptable to the team.
- b. Post accident monitoring channels, torus wide range level (Calculation No. NED-IEIC-0149) and torus bulk temperature (Calculation No. NED-I-EIC-0251) did not include environmental terms in the tolerance calculation. The bulk temperature calculation excluded seismic effects and the level calculation selectively excluded seismic effects for the recorders and panel meters. In addition, temperature, humidity, and radiation effects were unknown. This is considered an inspection followup item (237/94016-01(DRS); 249/94016-01(DRS)) pending NRC review of the licensee's actions to obtain and incorporate this information in the calculations.

Based on other margins identified in the calculations, the team concluded the above items would not affect operability. However, these items represent another example of weak design calculation control.

3.2.2 <u>Moore Industries Isolation Device Qualification</u>

The team was concerned that the Moore Industries isolators' installed configuration was not bounded by the test configuration that the devices were qualified to for maximum credible faults (MCF) and surge withstand capability.

During a plant tour, the team identified Moore Industries torus temperature isolator Nos. 943-237, -238, -242A and -242B, and several isolators installed in computer input cabinet No. 903-68 with their input, output, and power wiring bundled together. This field configuration appeared to defeat the isolation device purpose for separating safety related circuits from nonsafety circuits.

During the inspection, the licensee was unable to retrieve qualification documentation to support the installed configuration. Preliminary calculations performed by the licensee indicate the installed configuration was acceptable. However, this is considered an inspection followup item (237/94016-02(DRS); 249/94016-02(DRS)) pending NRC review of the licensee's calculations.

3.3 <u>HPCI Initiation</u>

. . .

The HPCI initiation instruments selected for review included low reactor water level (LIS-3-0263-72A) or high drywell pressure (PS-3-1632A). The instruments are used to initiate HPCI for LOCA or MSLB accidents.

3.3.1 <u>Setpoint Calculation and Basis</u>

- a. The team identified several calibration data sheet tolerances and setpoints that were less conservative than the values used in the setpoint calculations:
 - Surveillance Procedure (SP) No. DIS 0500-03 (lo-lo RWL) used a ± 2 INWC as the calibration tolerance while a ± 1 INWC tolerance was used in Calculation No. 0349-E-30 (Unit 3 low reactor water level ECCS initiate). In response, the licensee issued a Problem Identification Form (PIF) to initiate corrective actions. The team considered the difference between the calibration tolerance and the calculation to be minor.
 - SP No. DIS 2300-04 high drywell pressure setpoint was set less conservative (negative margin) than the setpoint established in Calculation No. NED-I-EIC-0111 (Unit 3 high drywell pressure ECCS initiation). However, the surveillance procedure setpoint did not exceed the TS value. In response, the licensee issued a PIF to initiate corrective actions. This was acceptable to the team.

The team reviewed an informal licensee analysis for the above items and concluded the discrepancies did not affect operability. However, these items represent another example of weak design calculation control.

- b. Calculation No. 0349-E-30 (Unit 3 RWL) contained the following unverified assumptions or documents:
 - Reference No. 17 identified a draft sketch (NUS SK-0349-M-002A).

A note on the sketch stated, in part, that it was not required to be issued because "...design parameters [are] included and checked in design calculations." However, the calculation referenced the informal sketch as the basis for several instrument elevation datum points.

Reference No. 24 identified training materials, Reference Nos. 41 and 50 identified two telecons, and Reference No. 28 identified a calibration procedure that were used to support the RWL analytical limit basis.

The licensee was unable to provide a qualitative basis to the team for these assumptions and documents.

• Paragraph No. 5.5.5.6.2 indicated that the RWL analytical limit (AL) was derived from the technical specification (-59" RWL).

ISA Standard S67.04-1988, "Setpoints for Nuclear Safety-Related Instrumentation," defines an AL as the "Limit of a measured or calculated variable established by the safety analysis to ensure that a safety limit is not exceeded." Although the licensee is not committed to this Standard, the team was concerned that the analytical limit for RWL was derived from the TS and not the safety analysis.

In response, the licensee stated that the RWL setpoint setting was more conservative than the TS value. In addition, the licensee indicated that consideration would be given to establishing the AL in accordance with ISA Standard S67.04-1988. This was acceptable to the team.

Attachment 2, page 26, discusses a telecon during which the Yarway manufacturer identified the level switch repeatability error as ± 3%. It was not apparent to the team that the manufacturer's value was consistent with the reference accuracy value used in the calculation. For example, repeatability errors should be separately identified because such errors are not amenable to calibration or adjustment.

In response, the licensee indicated that the manufacturer data, although attached to the calculation and referenced in the manufacturer's internal QA specification, was not used. Data in Calculation No. NED-I-EIC-0100 was used instead; however, this calculation was not provided to the team in sufficient time to complete a review. This is considered an inspection followup item (237/94016-03(DRS); 249/94016-03(DRS)) pending NRC review of Calculation No. NED-I-EIC-0100.

Based on other margins identified in the calculation, the team concluded the above items would not affect operability. However, these items represent another example of weak design calculation control.

3.3.2 <u>Environmental and Seismic Performance</u>

0

a. The team noted that the original equipment Yarway RWL switch setpoint calculations did not include an environmental error term. The level switches are required to mitigate LOCA and HELB (main steam line break inside containment) accidents.

In response, the licensee stated, in part, that the level switch protective functions would be performed ". . .prior to environmental

changes resulting from the abnormal condition (i.e., less than two minutes). As such they are not required to be qualified per [IEB] 79-01B." The level switches are located in EQ Zone Nos. 24 and 27. The following environmental conditions are postulated in these zones:

<u>Process</u>	<u>Normal</u>	<u>HELB</u>	<u>LOCA</u>
Temperature	104°F	212°F	104°F
Pressure	14.7 psig	14.8 psig	14.7 psig

The high energy line breaks that could occur in the vicinity of the level switches involved isolation condenser lines, the HPCI steam line, or a RWCU line (bounding accident). However, the level switches are not required to mitigate accidents that dominate EQ Zone Nos. 24 and 27. In addition, a drawing review did not indicate that the above lines could directly spray on the instrument racks.

The team concluded the Yarways could perform their safety function. In addition, ISA S67.04-1988 supports the licensee's basis for not including environmental effects in the Yarway calculation. Section 4.3.1.4, "Instrument Uncertainties by Design Basis Events," indicated that only uncertainties specific to the event and required period of service need be used. The use of different uncertainty components for the same process equipment for different events is permitted.

b. The team noted that original equipment SOR drywell pressure switches and Yarway RWL switches were classified as "commercial grade". Information provided in the calculations did not address their seismic qualification.

In response, the licensee provided the "commercial grade" dedication packages, however, the packages did not address the instruments' seismic capability. This is considered an inspection followup item (237/94016-04(DRS); 249/94016-04(DRS)) pending NRC review of the seismic documentation for these instruments.

Based on other margins identified in the calculation, the team concluded the above items would not affect operability. However, these items represent another example of weak design calculation control.

3.3.3 <u>Condensate/Particulate Traps in Drywell Pressure Impulse Lines and</u> <u>Methods for Ensuring the Lines Are Unrestricted</u>

The team noted that the drywell pressure calibration procedures did not verify if the instrument impulse lines were blocked or restricted. The lines must be open and unrestricted to insure the pressure instruments will respond to a DBA. In addition, installation drawings did not identify any provisions for protecting the impulse line opening inside the drywell or provisions to drain impulse line low points.

In response, the licensee walked down the lines and identified several low points (traps) that require further review. A PIF was issued to evaluate this item. This was acceptable to the team.





3.4 <u>HPCI Turbine Trips</u>

The HPCI turbine instruments selected for review included high reactor water level (LIS-3-0263-72A), high HPCI turbine exhaust pressure (PS-3-2368A) and low HPCI pump suction pressure (PS-3-2360). The setpoints must be set with adequate margin for equipment protection and must have adequate margin to prevent spurious HPCI trips during a DBA.

3.4.1 <u>Setpoint Calculation and Basis</u>

- a. Calculation No. NED-I-EIC-096 (HPCI turbine high exhaust pressure trip and suction pressure trip) did not evaluate Mercoid pressure switch seismic effects.
- b. Calculation No. NED-I-EIC-096 identified the Mercoid pressure switch temperature limit as 180°F, but the identified accident temperature was 230°F.
- c. The calculation did not identify any setpoint margin for the HPCI low suction pressure trip.

The licensee was unable to retrieve information on the above items during the inspection. This is considered an inspection followup item (237/94016-05(DRS); 249/94016-05(DRS)) pending NRC review of the licensee's actions to address the above. Based on other margins identified in the calculation, the team concluded the above items would not affect operability. However, these items represent another example of weak design calculation control.

3.5 <u>HPCI Isolation Trips</u>

The HPCI isolation instruments selected for review included high steamline flow (DPIS-3-2391-3), high steamline area temperature (TS-3-2370-A) and low reactor pressure (PIS-3-2391-1A).

- 3.5.1 <u>Setpoint Calculation and Basis</u>
- a. Calculation No. NED-I-EIC-108 (HPCI turbine/pump trip on high area temperature) did not evaluate temperature switch seismic effects.
- b. Calculation No. NED-I-EIC-108 stated, in part, that ". . .post-accident radiation induced errors are assumed to be small. . . ." No basis was provided in the calculation to support this assumption.

The licensee was unable to retrieve information on the above items during the inspection. This is considered an information followup item (237/94016-06(DRS); 249/94016-06(DRS)) pending NRC review of the licensee's actions to address the above. Based on other margins identified in the calculation, the team concluded the above items would not affect operability. However, these items represent another example of weak design calculation control.



3.6 <u>Condensate Storage Tank Level</u>

The instrument selected for low condensate storage tank level (LS-3-2350A) review initiates automatic HPCI suction transfer from the condensate storage tank to the suppression pool (torus).

3.6.1 <u>Setpoint Calculation and Basis</u>

The team noted that a setpoint calculation was not available and that the level switch (LS) was only functionally tested.

In response, the licensee developed an informal analysis and walked down the LS (mechanical float assembly) installation. The LS is located in a float chamber and has a limited mechanical operating range. The switch was not designed to be calibrated.

The team reviewed the informal analysis and concluded the LS would initiate HPCI suction transfer with adequate margin before losing HPCI pump NPSH. In addition, the team concluded a functional test was acceptable for this application.

3.7 <u>ATWS Recirculation Pump Trip and Alternate Rod Insertion (ARI)</u>

The anticipated transient without scram system was installed as a backup to the reactor protection system. The instruments selected for recirculation pump trip (ATWS RPT) and ARI review included high reactor pressure (PT-2-0263-20B) and 1o-1o RWL (LT-2-0263-23B).

3.7.1 <u>Setpoint Calculation and Basis</u>

- a. Calculation No. 0349-E-10 (Unit 2 RWL) did not conform to ISA S67.04-1988 (see Section 3.3.1.b, 3rd Bullet).
- b. Calculation No. 0349-E-10 (0349-E-30) did not include instrument drift data, calibration tolerances and environmental effects in the setpoint determination. The setpoint was determined from a scaling calculation. This is considered an inspection followup item (237/94016-07(DRS); 249/94016-07(DRS)) pending NRC review of the licensee's actions to obtain and incorporate this information in the calculation.

Based on other margins identified in the calculation, the team concluded the above items would not affect operability. However, these items represent another example of weak design calculation control.

3.8 <u>ATWS Manual Initiation</u>

Manual initiation was based on channel indication or alarms. The instruments selected for review included high torus water average temperature (TR-2-1641-200B), high drywell pressure (PS-2-1632B), and low RWL (LT-2-0263-57B or LS-2-0263-143B). The calculations associated with these instruments are identical to those previously discussed in Section Nos. 3.2.1.b, 3.3.1.a and 3.7.1.b, respectively, and the findings identified in those Sections are applicable to these instruments.

3.9 <u>LPCI Initiation</u>

The LPCI initiation instruments selected for review included high drywell pressure (PS-2-1632B) or lo-lo RWL coincident with low reactor pressure (LIS-2-0263-72B and PS-2-0263-52B). In addition, LPCI Loop II keep fill system (PS-2-1557B) and low reactor pressure permissive (PS-2-0263-52B) instruments were reviewed.

- 3.9.1 <u>Setpoint Calculation and Basis</u>
- a. A calculation did not exist for the keep fill system.

In response, the licensee indicated that the keep fill setpoint was an original design setting based on operating experience. The licensee provided the team a schedule for completion of setpoint calculations with priority based on design basis relevance. Categories of the setpoints included in the schedule were safety related, control system, regulatory related, reliability related, and nonsafey related setpoints. ESF/ECCS/RPS trip actuation or permissive signals, emergency operating procedures (EOPs), and RG 1.97 indication channel calculations receive the highest priority. Calculations for the remaining TS instruments, such as the keep fill system, are to follow. This was acceptable to the team.

b. Calculation No. 0349-E-10 (Unit 2 lo-lo RWL ECCS initiation) identified negative setpoint margin. Although negative setpoint margin indicates the potential for the combined setpoint uncertainties to exceed the TS allowable value, the actual surveillance procedure setpoint did not exceed the TS value.

Calculation No. NED-I-EIC-091 (Unit 2 high drywell pressure ECCS initiation) identified negative setpoint margin. However, the actual surveillance procedure setpoint did not exceed the TS value.

Based on other margins identified in the calculations discussed in b. and c. above, the team concluded these items would not affect operability. However, the above items represent another example of weak design calculation control.

3.10 <u>Reactor Water Level Narrow Range Indication</u>

The feedwater RWL instruments selected for review included the reactor level indication (LT-646B, LI-640-29B, and L/FR-640-26) and alarms for feedwater control.

3.10.1 <u>Setpoint Calculation and Basis</u>

The team noted that a loop error calculation was not available.

In response, the licensee indicated that the loop settings were based on original equipment operating experience. The licensee provided the available design information. Subsequent team review did not identify any discrepancies and the team concluded the instruments were operating within their design limits. The licensee indicated that the performance of a loop error calculation was being considered. This was acceptable to the team.

3.11 <u>Standby Gas Treatment (SBGT) Initiation</u>

The SBGT initiation instruments selected for review included the reactor building radiation monitor (RIS-2-1705-8B), lo-lo RWL (LT-2-0263-57B), high drywell pressure (PS-2-1621B) and high drywell radiation (RE-2-2418B).

3.11.1 <u>Setpoint Calculation and Basis</u>

The team noted that formal calculations did not exist for the reactor building ventilation trip and the high drywell radiation monitor.

In response, the licensee indicated that the ventilation trip was an original equipment setting and the high drywell radiation monitor settings were based upon NUREG 0737 analyses or offsite dose calculations. The team reviewed supporting documentation and concluded the setpoints were reasonable.

4.0 <u>Engineering and Technical Support</u>

The team evaluated Dresden's I&C engineering and technical support (E&TS) capability by reviewing the licensee's programs for modifications, engineering interfaces, document and drawing control, discrepancy management, safety evaluations (10 CFR 50.59), test development and control, setpoint methodology, calibration procedures, QA and maintenance. In addition, the team reviewed training programs for I&C engineers and interviewed design, construction and system I&C engineers.

Overall, the team concluded Dresden was receiving adequate I&C engineering and technical support and that I&C engineering expertise was available; however, efforts toward developing an integrated engineering approach appeared minimal. Ownership for the design, calculations and systems was difficult to identify because weak linkages existed between design, construction and system engineering. One consequence observed was slow progression of engineering initiatives from program conception to implementation. For example, engineering was slow in identifying and correcting performance problems with the Yarway level switches. It appeared to the team that ComEd's control of external design engineering activities was weaker than internal design activities. The team noted that I&C setpoint calculations performed by ComEd were more focused with a clear path from calculation input to the finished product. Several contractor I&C calculations appeared to jump around from instrument loop to instrument loop and appeared to be in a study format rather than an engineering calculation format. Although the setpoint calculation review did not identify any operability concerns, numerous design calculation control weaknesses were identified. This area may require additional management attention to ensure the setpoint methodology program is implemented consistently. The licensee informed the team that they were adding additional design engineers to the site. Engineering's goal was to perform $\approx 80\%$ of Dresden's design activities in-house.

The team identified several positive attributes. The Dresden counterpart I&C team was knowledgeable and experienced. In addition, recent setpoint methodology used was technically sound and reflected current industry practices. Finally, the HPCI design basis document (DBD) was good.

4.1 <u>Engineering Staff Training</u>

The team reviewed selected I&C engineers' training programs, training records and work experience. In addition, the team conducted interviews and technical discussions with selected I&C engineers. The I&C engineers interviewed were experienced and had a positive attitude. The team concluded that training was not focused on specific I&C skills and it appeared that I&C engineers were not completely trained on existing instrumentation system designs. It appeared to the team that the emerging I&C engineering group and their involvement with setpoint methodology may require additional training to ensure consistent implementation.

The team was informed that in October 1993, 22 modification and technical staff engineers received training on post modification testing as an effort to resolve previously identified weaknesses in that area. This training was provided after post modification test (PMT) No. SP 93-10-90 was approved for use in Modification No. P12-3-93-614 (see Section 4.2.a).

4.2 <u>Design Control and Modifications</u>

The team concluded that Dresden was adequately controlling station modifications. Safety evaluations were thorough and well documented. Eight permanent and three temporary modifications were reviewed. Two permanent and the three temporary modifications were walked down. The walkdowns reviewed the modifications against the design drawings and concluded the installations reflected the as-built configuration.

The team reviewed the PMTs for the modifications. Inadequate PMTs were identified in two permanent modifications.

a. <u>Modification P12-3-93-614</u>: Reroute Torus Bulk Temperature Monitoring System conduits to lessen Unit 3 flooding and/or corrosion concerns (completed July 1994). This modification replaced existing thermocouple cables and conduits for the post accident monitoring suppression pool temperature indication channels.

The team identified there was no basis for the \pm 6°F acceptance criteria specified in Special Procedure (SP) No. 93-10-90, "Modification Test for Torus Temperature Monitoring Conduit Relocation Minor Design Change P12-3-93-614."

In response, the licensee used design Calculation No. NED-I-EIC-0251, "Suppression Pool Temperature Loop Accuracy Calculation," and determined the acceptance criteria to be \pm 4.6°F. Based on indicator readability, the acceptance criteria specified in the PMT procedure should have been \pm 5°F. Although the actual temperature values recorded during performance of the SP were \leq 5°F. The failure to include acceptance limits contained in applicable design documents is a violation (237/94016-08a; 249/94016-08a(DRS)) of 10 CFR 50, Appendix B, Criterion XI, Test Control.

The team noted that the Unit 2 special procedure recorded temperature values showed no variances from the desired input values. Unit 3 recorded temperature values varied between $-4^{\circ}F$ and $+5^{\circ}F$. The team was concerned as to why the PMT results were different between units.

In response, the licensee indicated they would investigate the Unit 3 temperature variances and retest the modification. This was acceptable to the team.

b. <u>Modification M12-0-90-025</u>: Modify Standby Gas Treatment System (SBGT) logic so an isolation in either Unit will isolate both Units' Reactor Building Ventilation Systems (completed February 1991). Four relays were added to automatically close both Units' reactor building isolation dampers and trip their respective building ventilation and exhaust fans.

The team identified that new SBGT Train A relay (30K5 and 30K24) contacts (Drawing No. 12E-2400C, sh.1) and Train B relay (30K21 and 30K25) contacts (Drawing No. 12E-2400C, sh.2) were inadequately tested. Special Procedure Nos. SP 91-2-29, "Standby Gas Treatment Train A Logic Modification Test," and SP 91-1-12, "Standby Gas Treatment Train B Logic Modification Test," verified the isolation dampers automatically closed and that all reactor building fans tripped. However, the post modification tests did not identify that original construction relays CR-2 and CR-3 (Drawing Nos. 12E-2399C and 12E-3399B) would, in parallel, trip the reactor building fans upon isolation damper closure. Therefore, positive identification that the new relays had performed their intended function was not verified.

In response, the licensee indicated they would verify by test that the relay contacts could perform their intended functions. The failure to demonstrate that systems and components will perform satisfactorily in service and assure test requirements have been satisfied is a violation (237/94016-08b; 249/94016-08b(DRS)) of 10 CFR 50, Appendix B, Criterion XI, Test Control.

4.3 <u>Review of Licensee Self-Assessment Program in the I&C Area</u>

The team reviewed I&C related audits and surveillances performed during the last three years. Recent self-assessments appeared to be more self critical than earlier audits that had few technical findings. For example, the current instrument trending program was found marginal since only as-found values outside specified surveillance tolerances were trended (marginal instrument drift patterns may not be noted). The team concluded that recent licensee I&C self-assessments were acceptable.

4.4 <u>Measuring and Test Equipment (MTE)</u>

The inspectors noted that recent improvements in the licensee's MTE control practices were, in part, driven by self-assessment findings. To address the findings and other MTE problems, an Instrument Compliance Manager position was created. Increased management direction at several levels has lowered the MTE work request backlog, created a MTE problem list and involved the instrument mechanics (IMs) in solving MTE problems. The team concluded that MTE issue controls, such as storage, calibration interval and damaged or out of tolerance MTE instruments were acceptable.

4.5 <u>Instrument Calibration and Testing</u>

The team reviewed calibration and functional surveillance tests, logic functional tests and response time tests associated with the instrument loops

selected. The team concluded the procedures were user friendly and of good quality. However, as discussed in previous Sections of this report, several calculated setpoints used different tolerances than identified on surveillance procedure data sheets. It was unclear to the team how Dresden would tie the calculation and procedure together to ensure changes made to either document, such as MTE, would not invalidate the calculation. Though problems were noted, the surveillance procedures did incorporate the correct technical specification (TS) setpoint values and the setpoints were conservatively set below the allowable TS limits. The team concluded the instrument testing program was acceptable.

5.0 <u>Inspection Followup Items</u>

Inspection followup items are matters that have been discussed with the licensee, which will be reviewed further by the team, which involve some action on the part of NRC or licensee or both. Followup items disclosed during the inspection are discussed in Sections 3.2.1.b, 3.2.2, 3.3.1.b, 3.3.2.b, 3.4.1, 3.5.1, and 3.7.1.b of this report.

6.0 <u>Exit Meeting</u>

The team met with licensee representatives (denoted in Appendix A) after the inspection on September 16, 1994, to discuss the scope and findings of the inspection. During the exit meeting, the team discussed the likely informational content of the inspection report about documents or processes reviewed by the team during the inspection. Licensee representatives did not identify any such documents or processes as proprietary.

APPENDIX A

Dresden SBICI Exit Meeting September 16, 1994

Commonwealth Edison Company 1.0

- * E. Eenigenburg, Unit 2 Station Manager
- * H. Massin, Site Engineering & Construction Manager
- * H. Drumhiller, Station Engineering Department Superintendent
- 4 D. Barrett, Acting Quality Control Supervisor
- * J. Phelan, CECo I&C Team Leader
- G. Wagner, Acting Chief E/Instrument & Control Engineer *
- * P. Wicyk, Electrical - Instrument and Control Supervisor
- * D. Pritchard, Work Control Superintendent
- *
- J. Grzemski, ISEG Supervisor J. Williams, Dresden Construction Superintendent *
- * C. McDonough, Regulatory Assurance NRC Coordinator
- * R. Ralph, System Engineering Team Leader
- ÷ D. Ambler, SVP Executive Assistant
- G. Tietz, Operations Manager
- * M. Pacilio, Unit 3 Maintenance Superintendent
- * R. Mason, Instrumentation and Control Engineer
- * J. McHale, Instrumentation and Control Engineer
- * K. Robbins, Instrument Maintenance Supervising coordinator
- S. Stiller, Instrument Department Superintendent
- * L. McCalip, Instrument Compliance Manager
- J. Zeszutek, Regulatory Assurance Engineer
- * S. Koenig, Regulatory Performance Administrator
- * D. Rahn, Signals & Safeguards Inc.
- * R. Ellman, Signals & Safeguards Inc.
- * W. Barasa, S&L

U. S. Nuclear Regulatory Commission

- * M. Leach, Senior Resident Inspector
- * G. Wright, Chief, Engineering branch DRS
- * C. Settles, IDNS Resident Inspector

* Denotes those present at the exit meeting on September 16, 1994.

APPENDIX B

DRESDEN SBICI REQUESTS FOR INFORMATION

001	PROVIDE 3 COPIES OF SETPOINT METHODOLOGY
002	PROVIDE INFORMATION ON MILE PROGRAM
003	PROVIDE INFORMATION ON HOW THE MIKE PROGRAM IS IMPLEMENTED IN THE CALCULATION METHODOLOGY
004	PLEASE PROVIDE QUA SURVEILLANCES OR ADDITS OF TAG ENGINEERING
005	PROVIDE PROCEDURES INAI DEAL WITH SUPPRESSION POOL LEMPERATURE
007	PROVIDE PROCEDURES THAT DEAL WITH HERE INTIATION ON RX (O LO WATER LEVE)
008	PROVIDE PROCEDURES THAT DEAL WITH HPCI INITIATION ON HI DRYWELL PRESSURE
009	PROVIDE PROCEDURES THAT DEAL WITH HPCI PROTECTIVE TRIP ON HIGH FLOW (PIPING)
010	PROVIDE PROCEDURES THAT DEAL WITH HPCI PROTECTIVE TRIP ON HI TEMPERATURE IN HPCI PIPING
011	PROVIDE PROCEDURES THAT DEAL WITH THE HPCI KEEP FILL SYSTEM
012	PROVIDE PROCEDURES THAT DEAL WITH HPCI ISOLATION TRIPS ON STEAM LINE HIGH FLOW
013	PROVIDE PROCEDURES THAT DEAL WITH HPCI ISOLATION TRIPS ON STEAM LINE AREA HIGH TEMPERATURE
014	PROVIDE PROCEDURES THAT DEAL WITH HPCT ISOLATION TRIPS ON LO RA PRESSORE
015	PROVIDE PROCEDORES INAI DEAL WIN CSI LEVEL (LO LEVEL IRANSFER INCI IO SUPPRESSION FOOL)
017	PROVIDE PROCEDURES THAT DEAL WITH ATWS RECIRCULATION PIMP TATE ON REACTOR HIGH FRESSAR
018	PROVIDE PROCEDURES THAT DEAL WITH ATWS MANUAL INITIATION ON HIGH TORUS WATER AVERAGE TEMPERATURE ALARM
019	PROVIDE PROCEDURES THAT DEAL WITH ATWS MANUAL INITIATION ON REACTOR HIGH DOME PRESSURE HIGH ALARM
020	PROVIDE PROCEDURES THAT DEAL WITH ATWS MANUAL INITIATION ON REACTOR LOW LOW WATER LEVEL ALARM
021	PROVIDE PROCEDURES THAT DEAL WITH LPCI INITIATION ON HIGH DRYWELL PRESSURE
022	PROVIDE PROCEDURES THAT DEAL WITH LPCI INITIATION ON LOW LOW RX LEVEL COINCIDENT WITH LOW REACTOR
	PRESSURE
023	PROVIDE PROCEDURES THAT DEAL WITH LPCI INITIATION ON LOW LOW RX LEVEL SUSTAINED FOR 8.5 MINUTES
024	PROVIDE PROCEDURES THAT DEAL WITH LPCI INITIATION ON LOW PRESSURE INJECTION PERMISSIVE
025	PROVIDE PROCEDURES THAT DEAL WITH LPCT KEEP FILL SYSTEM
025	PROVIDE PROCEDURES INAL DEAL WITH REACTOR VESSEL LEVEL (INDICATION - NARROW RANGE)
027	PROVIDE PROCEDURES INAI DEAL WITH REACIDE VESSEL RES LEVEL 3 INIP Douvide procedures that deal with standay cas treatment initiation lidon secondady containment
028	INITIATION FOLLOWING DY BUILTING AT MODE GAS INCLAIMENT INITIATION OPEN SECONDART CONTAINMENT
029	PROVIDE PROCEDURES THAT DEAL WITH STANDRY GAS IREATMENT INITIATION UPON SECONDARY CONTAINMENT
	INITIATION FOLLOWING GROUP 2 PRIMARY CONTAINMENT ISOLATION ON:
	A) RX LO LEVEL
	B) HI DRYWELL PRESS
	C) DRYWELL HI RADIATION
030	PROVIDE ROUND SHEETS FOR LOOPS INDICATED ON ATTACHED LIST
031	PROVIDE DRAWINGS ASSOCIATED WITH SELECTED LOOPS
032	PROVIDE CABLE ROUTING FOR SUPPRESSION POOL
	A) TEMPERATURE
000	B) LEVEL (INDICATION AND HPCT TRANSFER ON HIGH LEVEL IN THE TOROS)
033	PROVIDE CABLE ROUTING FOR MECT INITIATION ON:
	A) REACTOR LOW LOW WATER LEVEL
034	B) IT THE DOLLENG FOR HERE PROTECTIVE TRIPS ON-
004	A) HIGH FLOW HPCI PIPING
	B) HIGH TEMPERATURE HPCI PIPING
	C) HPCI FILL SYSTEM
035	PROVIDE CABLE ROUTING FOR HPCI ISOLATION TRIPS ON:
	A) STEAM LINE HIGH FLOW
	B) STEAM LINE AREA HIGH TEMPERATURE
	C) LOW REACTOR PRESSURE
036 、	PROVIDE CABLE ROUTING FOR CONDENSATE STORAGE TANK
037	A) LEVEL (LOW LEVEL TRANSFER APLI TO SUPPRESSION POUL)
037	PROVIDE CABLE ROUTING FOR AIWS RELIRC FOMP TRIP
	B) REACTOR ION ION WATER LEVEL
038	PROVIDE CARLE ROUTING FOR ATWS MANUAL INITIATION ON:
	A) HIGH TORUS WATER AVERAGE TEMPERATURE ALARM
	B) REACTOR HIGH DOME PRESSURE HIGH ALARM
	C) RX LO LO WATER LEVEL ALARM
039	PROVIDE CABLE ROUTING FOR LPCI INITIATION ON:
	A) HI DW PRESSURE
	B) LO LO RX LEVEL COINCIDENT IN LO RX PRESS
	C) LO LO RX LEVEL SUSTAINED FOR 8.5 MINUTES
	D) LO PRESS INJECTION PERMISSIVE
	E) REEP FILL SYSTEM
040	PROVIDE CABLE ROUTING FOR RA VESSEL
	A) LEVEL (INDICATION - NARROW RANGE) B) DOG LEVEL 2 TOTO
041	D) RPS LEVEL STRIP Douting care fortante for standay gas treatment
041	PROVIDE CABLE ROUTING FOR STANDED AS TREATMENT
	(1) RX BLOG ATR MONITOR HIGH
	(1) RX BLOG AIR MONITOR HIGH (2) GRP 2 PRIMARY CONTAINMENT ISOLATION ON:
	 (1) RX BLDG AIR MONITOR HIGH (2) GRP 2 PRIMARY CONTAINMENT ISOLATION ON: A) RX LO LVL
	 (1) RX BLDG AIR MONITOR HIGH (2) GRP 2 PRIMARY CONTAINMENT ISOLATION ON: A) RX LO LVL B) HI DW PRESS
	(1) RX BLDG AIR MONITOR HIGH (2) GRP 2 PRIMARY CONTAINMENT ISOLATION ON: A) RX LO LVL B) HI DW PRESS C) DW HI RAD
042	(1) RX BLDG AIR MONITOR HIGH (2) GRP 2 PRIMARY CONTAINMENT ISOLATION ON: A) RX LO LVL B) HI DW PRESS C) DW HI RAD PROVIDE CALCULATIONS FOR SUPPRESSION POOL
042	(1) RX BLDG AIR MONITOR HIGH (2) GRP 2 PRIMARY CONTAINMENT ISOLATION ON: A) RX LO LVL B) HI DW PRESS C) DW HI RAD PROVIDE CALCULATIONS FOR SUPPRESSION POOL A) TEMPERATURE D) LEVEL (UNDCATION AND UPOL TAINGEER ON ULLEVELS 2017/07/07/07/07/07/07/07/07/07/07/07/07/07
042	(1) RX BLOG AIR MONITOR HIGH (2) GRP 2 PRIMARY CONTAINMENT ISOLATION ON: A) RX LO LVL B) HI DW PRESS C) DW HI RAD PROVIDE CALCULATIONS FOR SUPPRESSION POOL A) TEMPERATURE B) LEVEL (INDICATION AND HPCI TRANSFER ON HI LEVELS IN THE TORUS) DOVIDE CALCULATIONS FOR DUPCI INITIATION ON:
042 043	(1) RX BLDG AIR MONITOR HIGH (2) GRP 2 PRIMARY CONTAINMENT ISOLATION ON: A) RX LO LVL B) HI DW PRESS C) DW HI RAD PROVIDE CALCULATIONS FOR SUPPRESSION POOL A) TEMPERATURE B) LEVEL (INDICATION AND HPCI TRANSFER ON HI LEVELS IN THE TORUS) PROVIDE CALCULATIONS FOR HPCI INITIATION ON: A) PX LO LO WATER LEVEL
042 043	(1) RX BLDG AIR MONITOR HIGH (2) GRP 2 PRIMARY CONTAINMENT ISOLATION ON: A) RX LO LVL B) HI DW PRESS C) DW HI RAD PROVIDE CALCULATIONS FOR SUPPRESSION POOL A) TEMPERATURE B) LEVEL (INDICATION AND HPCI TRANSFER ON HI LEVELS IN THE TORUS) PROVIDE CALCULATIONS FOR HPCI INITIATION ON: A) RX LO LO WATER LEVEL B) HI DRY
042 043 044	 A) INFIGUENT OF ON SECONDARY CONTAINMENT INFIGUENTIAL (1) RX BLDG AIR MONITOR HIGH (2) GRP 2 PRIMARY CONTAINMENT ISOLATION ON: A) RX LO LVL B) HI DW PRESS C) DW HI RAD PROVIDE CALCULATIONS FOR SUPPRESSION POOL A) TEMPERATURE B) LEVEL (INDICATION AND HPCI TRANSFER ON HI LEVELS IN THE TORUS) PROVIDE CALCULATIONS FOR HPCI INITIATION ON: A) RX LO LO WATER LEVEL B) HI DRYWELL PRESSURE PROVIDE CALCULATIONS FOR HPCI PROTECTIVE TRIPS ON:
042 043 044	 A) INTERTED OF ON SECONDARY CONTAINMENT INTERTED FOLLOWING: RX BLDG AIR MONITOR HIGH RX LO LVL RX LO LVL R) HI DW PRESS C) DW HI RAD PROVIDE CALCULATIONS FOR SUPPRESSION POOL A) TEMPERATURE B) LEVEL (INDICATION AND HPCI TRANSFER ON HI LEVELS IN THE TORUS) PROVIDE CALCULATIONS FOR HPCI INITIATION ON: A) RX LO LO WATER LEVEL B) HI DRYWELL PRESSURE PROVIDE CALCULATIONS FOR HPCI PROTECTIVE TRIPS ON: A) HI FLOW HPCI PIPING
042 043 044	 A) INTITATION OPIN SECONDART CONTAINENT INTITATION FOLLOWING: RX BLDG AIR MONITOR HIGH RX LO LVL RX LO LVL B) HI DW PRESS C) DW HI RAD PROVIDE CALCULATIONS FOR SUPPRESSION POOL A) TEMPERATURE B) LEVEL (INDICATION AND HPCI TRANSFER ON HI LEVELS IN THE TORUS) PROVIDE CALCULATIONS FOR HPCI INITIATION ON: A) RX LO LO WATER LEVEL B) HI DRYWELL PRESSURE PROVIDE CALCULATIONS FOR HPCI PROTECTIVE TRIPS ON: A) HI FLOW HPCI PIPING
042 043 044	 A) INTITATION OP ON SECONDARY CONTAINMENT INTITATION FOLLOWING: RX BLDG AIR MONITOR HIGH RX LO LVL RX LO LVL B) HI DW PRESS C) DW HI RAD PROVIDE CALCULATIONS FOR SUPPRESSION POOL A) TEMPERATURE B) LEVEL (INDICATION AND HPCI TRANSFER ON HI LEVELS IN THE TORUS) PROVIDE CALCULATIONS FOR HPCI INITIATION ON: RX LO LO WATER LEVEL B) HI DRWELL PRESSURE PROVIDE CALCULATIONS FOR HPCI PROTECTIVE TRIPS ON: A) HI FLOW HPCI PIPING C) KEEP FILL SYSTEM
042 043 044 045	 A) INFIGUENT OF ON SECONDARY CONTAINENT INFIGUENTION FOLLOWING: RX BLDG AIR MONITOR HIGH RX LO LVL RX LO LVL RX LO LVL HI DW PRESS D WHI RAD PROVIDE CALCULATIONS FOR SUPPRESSION POOL A) TEMPERATURE B) LEVEL (INDICATION AND HPCI TRANSFER ON HI LEVELS IN THE TORUS) PROVIDE CALCULATIONS FOR HPCI INITIATION ON: A) RX LO LO WATER LEVEL B) HI DRYWELL PRESSURE PROVIDE CALCULATIONS FOR HPCI PROTECTIVE TRIPS ON: A) HI FLOW HPCI PIPING C) KEEP FILL SYSTEM PROVIDE CALCULATIONS FOR HPCI ISOLATION TRIPS
042 043 044 045	 A) INFIGUENT OF ON SECONDARY CONTAINMENT INFIGUENTION FOLLOWING: RX BLDG AIR MONITOR HIGH RX LO LVL RX LO LVL B) HI DW PRESS C) DW HI RAD PROVIDE CALCULATIONS FOR SUPPRESSION POOL A) TEMPERATURE B) LEVEL (INDICATION AND HPCI TRANSFER ON HI LEVELS IN THE TORUS) PROVIDE CALCULATIONS FOR HPCI INITIATION ON: A) RX LO LO WATER LEVEL B) HI DRYWELL PRESSURE PROVIDE CALCULATIONS FOR HPCI PROTECTIVE TRIPS ON: A) HI TEMPERATURE HPCI PIPING C) KEEP FILL SYSTEM PROVIDE CALCULATIONS FOR HPCI ISOLATION TRIPS A) STEAM LINE HIGH FLOW A) STEAM LINE HIGH FLOW
042 043 044 045	 A) INTERTACTION OF ON SECONDARY CONTAINMENT INTERTION FOLLOWING: RX BLDG AIR MONITOR HIGH RX LO LVL B) HI DW PRESS C) DW HI RAD PROVIDE CALCULATIONS FOR SUPPRESSION POOL A) TEMPERATURE B) LEVEL (INDICATION AND HPCI TRANSFER ON HI LEVELS IN THE TORUS) PROVIDE CALCULATIONS FOR HPCI INITIATION ON: A) RX LO LO WATER LEVEL B) HI DRYWELL PRESSURE PROVIDE CALCULATIONS FOR HPCI PROTECTIVE TRIPS ON: A) AN HI FLOW HPCI PIPING B) HI TEMPERATURE HPCI PIPING C) KEEP FILL SYSTEM PROVIDE CALCULATIONS FOR HPCI ISOLATION TRIPS A) STEAM LINE HIGH FLOW B) STEAM LINE AREA HIGH TEMPERATURE

046		
047	PROVIDE CALCULATIONS FOR CST LEVEL (LO LEVEL TRANSFER HPCI TO SUPPRESSION POOL) PROVIDE CALCULATIONS FOR ATWS RECIRC PUMP TRIP ON:	
048	PROVIDE CALCULATIONS FOR ATWS MANUAL INITIATION	
	A) HI TORUS WATER AVERAGE TEMP ALARM	
	B) RX HI DOME PRESSURE HIGH ALARM	
049	C) RX LO LO WATER ALARM DOUTRE CALCHIATIONS FOR LOCI INITIATION ON-	
043	A) HI DRYWELL PRESSURE	
	B) LO LO RX LEVEL COINCIDENT WITH LO RX PRESS	
	C) LO LO RX LEVEL SUSTAINED FOR 8.5 MINUTES	
	D) LO PRESS INJECTION PERMISSIVE	
050	E) KEEP FILL STSTEM DOUTDE CALCHIATIONS FOD DEACTOD VESSEL.	
050	A) LEVEL (INDICATION - NARROW RANGE)	
	B) RPS LEVEL 3 TRIP	
051	PROVIDE CALCULATIONS FOR STANDBY GAS TREATMENT:	
	A) INITIATION UPON SECONDARY CONTAINMENT INITIATION FOLLOWING:	
	(1) RX BLDG AIR MONITOR HIGH	
	B) HI DRYWELL PRESS	
	C) DRYWELL HI RADIATION	
052	PROVIDE CLOSURE PACKAGES FOR:	
	237/249/91016-04, 237/91038-05, 237/91038-06, 237/249/92028-03, 237/249/92021-03, 249/92023-05,	
053	23/249/92020-01, AND 23/249/92020-02. Dowing itst of the moniterations/eris dedeadmen aved last 5 years	
054	PROVIDE LIST OF LER'S, DR'S, ETC, THAT DEAL WITH INSTRUMENTS OVER LAST 5 YEARS.	
055	PROVIDE A DISCUSSION AND AVAILABLE INFO REGARDING OLD FSAR VS. UFSAR SECTION TRANSLATION.	
056	PROVIDE HPCI TURBINE HI RX LEVEL TRIP SETPOINT CALCULATION AND LOOP CALIBRATION PROCEDURE.	
057	PROVIDE HPCI TURBINE HI TURBINE EXHAUST PRESSURE TRIP SETPOINT CALCULATION AND LOOP CALIBRATION	
059	PROCEDURE. Douvide upor turbing for poster numb suction dessure this setroint calculation and califyration	
058	DOCEDIDE TOUS TORBANE LOW DOUSTER POMP SUCTION PRESSURE TRIP SELPOINT CALCULATION AND CALIBRATION	
059	PROVIDE A LIST (OR LISTS) OF INDUSTRY INITIATIVES (INS. VENDOR TECHNICAL BULLETINS, GENERIC LETTERS,	
	SILS, ETC.) (LAST 5 YEARS) DEALING WITH I&C.	
060	PROVIDE ATWS SER FOR UNIT 2.	
061	PROVIDE PIR 12-2-93-106, CAR 12-93-040, AND DVR 12-2-92-026. INCLUDE ANY SUPPORTING INFORMATION.	
062	PROVIDE LERS 3-91-03, 3-92-19, 3-93-1 PLUS SUPPLEMENI, AND 3-94-8. INCLUDE SUPPORTING INFORMATION.	
003	BEEN DORE TO CORRECT THIS? PROVIDE ALL SUPPORTING INFORMATION.	
064	PROVIDE DVRs: 12-2-90-022, 12-2-90-025,	
	12-2-90-116, 12-2-90-160, 12-2-91-148, 12-2-92-111 AND 12-2-92-152. (INCLUDE SUPPORTING INFORMATION)	
065	PROVIDE DVRs: 12-3-90-068, 12-3-91-036,	
	12-3-91-063, $12-3-92-014$, $12-3-92-021$, $12-3-92-038$, 12-3-02, 0.75 (Include Supporting Include Support	
066		
000	P12-3-93-614, P12-2-93-601, P12-2-92-748, M12-3-89-024, P12-3-94-224 AND P12-3-93-208.	
067	PROVIDE MOD PROCEDURE, TEMPORARY MOD PROCEDURE AND LIST OF TEMPORARY MODS FOR BOTH UNITS.	
068	PROVIDE DRESDEN'S RESPONSE TO BULLETIN/LETTER FROM NRC THAT ADDRESSES CONDENSATE POT DEGASSING AND IT'S	'S
069	RUFSAR 6.3.3.1.3.2.1. PGS. 6.3-29,	
	(1) WHAT IS THE HI DP STEAM LINE ISOLATION OF HPCI TURBINE IN 50 SEC?	
	(2) ARE THEIR ANY SETPOINT CALCS AND CALIBRATION PROCEDURES?	
070	(3) DWG. #"S. PROVIDE DRESDEN'S CONTROL OF MATE PROCEDURES (WE HAVE A COPY OF TID-F/I&C-26).	
0,0		
071	PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN	
071	PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD-)_
071	PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237 (201038-05: 249/01042-05 SEE ATTACHED)-
071 072 073	PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER:)-
071 072 073	PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS_CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED).)-
071 072 073	PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE FOR THE SETPOINT. (3) PROVIDE THE AVALUE FOR THE SETPOINT.)-
071 072 073	PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT.)-
071 072 073 074	<pre>PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. CST LVL INDICATION: (1) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS?</pre>)-
071 072 073 074	<pre>PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (3) PROVIDE FT³ VALUE FOR THE SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. CST LVL INDICATION: (1) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (2) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE</pre>)-
071 072 073 074	<pre>PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE FT³ VALUE FOR THE SETPOINT. (3) PROVIDE TT⁴ VALUE FOR THE SETPOINT. CST LVL INDICATION: (1) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (2) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES,</pre>)-
071 072 073 074	<pre>PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER; (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. CST LVL INDICATION: (1) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (2) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, (3) WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS?</pre>)-
071 072 073 074 075	<pre>PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (1) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (2) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, (3) WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? U3 TORUS: (1) DRONUDE NAPPO(/ DANCE LVL YNITED INSTALLATION DDAN/INC)</pre>)-
071 072 073 074 075	<pre>PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (4) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (2) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, (3) WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? US TORUS: (1) PROVIDE NARROW RANGE LVL XMITTER INSTALLATION DRAWING. (2) PROVIDE XMITTER PIPING CONNECTION TO THE TORUS (TAP HEIGHT LOCATION).</pre>)-
071 072 073 074 075	<pre>PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (4) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (5) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, (3) WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? U3 TORUS: (1) PROVIDE MARROW RANGE LVL XMITTER INSTALLATION DRAWING. (2) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (3) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (3) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (3) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (4) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (5) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (5) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (5) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (5) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (5) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (5) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (5) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (5) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (5) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (5) PROVIDE XMITTER VENDOR MANUAL AND OTHER</pre>)-
071 072 073 074 075	<pre>PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (4) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (5) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE</pre>)-
071 072 073 074 075 076	<pre>PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE HE ANALYTICAL LIMIT FOR THIS SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (1) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (2) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, (3) WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? U3 TORUS: (1) PROVIDE NARROW RANGE LVL XMITTER INSTALLATION DRAWING. (2) PROVIDE XMITTER PIPING CONNECTION TO THE TORUS (TAP HEIGHT LOCATION). (3) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (4) PROVIDE XMITTER NENDOR MANUAL AND OTHER LOOP COMPONENTS. (5) TORUS HI LVL:</pre>)-
071 072 073 074 075 076	 PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE FT3 VALUE FOR THE SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (1) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (2) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, (3) WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? U3 TORUS: (1) PROVIDE NARROW RANGE LVL XMITTER INSTALLATION DRAWING. (2) PROVIDE XMITTER PIPING CONNECTION TO THE TORUS (TAP HEIGHT LOCATION). (3) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (4) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS. (1) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS. (1) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS. (1) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS. (1) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS. (1) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS. (2) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS. (3) OFTICE TOPING TO THE TORUS (TAP HEIGHT LOCATION). (4) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS. (5) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS. (6) PROVIDE LUL SWITCH VENDOR MANUAL.)-
071 072 073 074 075 076	<pre>PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (3) PROVIDE FT4 ANALYTICAL LIMIT FOR THIS SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (4) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (5) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, (3) WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? U3 TORUS: (1) PROVIDE XMITTER PIPING CONNECTION TO THE TORUS (TAP HEIGHT LOCATION). (3) PROVIDE XMITTER PIPING CONNECTION TO THE TORUS (TAP HEIGHT LOCATION). (4) PROVIDE XMITTER ENVIRONMENTAL CONDITIONS, SUCH AS HELB ENVIRONMENT. U3 TORUS HI LVL: (1) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (4) PROVIDE XMITTER ENVIRONMENTAL CONDITIONS, SUCH AS HELB ENVIRONMENT. (3) TORUS HI LVL: (1) PROVIDE XMITTER PIPING CONNECTION (TAP HEIGHT LOCATION). (3) PROVIDE XMITTER ENVIRONMENTAL CONDITIONS, SUCH AS HELB ENVIRONMENT. (4) PROVIDE XMITTER ENVIRONMENTAL CONDITIONS, SUCH AS HELB ENVIRONMENT. (5) PROVIDE LVL SWITCH VENDOR MANUAL. (6) PROVIDE TORUS INSIDE DIMENSIONS (DRAWING IF AVAILABLE). (7) PROVIDE TORUS INSIDE DIMENSIONS (DRAWING IF AVAILABLE). (8) PROVIDE TORUS INSIDE DIMENSIONS (DRAWING IF AVAILABLE). (9) PROVIDE TORUS INSIDE DIMENSIONS (DRAWING IF AVAILABLE). (1) PROVIDE TENVIPONENT ENVIPONENT ENVIPONENT FOR IS APPONENT FOR IS A</pre>)-
071 072 073 074 075 076	 PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE FT³ VALUE FOR THE SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (1) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (2) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, (3) WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? U3 TORUS: (1) PROVIDE XMITTER PIPING CONNECTION TO THE TORUS (TAP HEIGHT LOCATION). (3) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (4) PROVIDE XMITTER ENVIRONMENTAL CONDITIONS, SUCH AS HELB ENVIRONMENT. U3 TORUS HI LVL: (1) PROVIDE LVL SWITCH VENDOR MANUAL. (2) PROVIDE LVL SWITCH VENDOR MANUAL. (3) PROVIDE LVL SWITCH VENDOR MANUAL. (4) PROVIDE TORUS INSIDE DIMENSIONS (DRAWING IF AVAILABLE). (5) PROVIDE TORUS LEVEL CURVE FT³ VS. LEVEL.)-
071 072 073 074 075 076 077	 PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETFOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). PROVIDE ES CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). PROVIDE TH³ VALUE FOR THE SETPOINT. PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. CST LVL INDICATION: DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? U3 TORUS: PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). PROVIDE XMITTER ENVIRONMENTAL CONDITIONS, SUCH AS HELB ENVIRONMENT. U3 TORUS HI LVL: PROVIDE XMITTER ENVIRONMENTAL CONDITIONS, SUCH AS HELB ENVIRONMENT. U3 TORUS HI LVL: PROVIDE LVL SWITCH VENDOR MANUAL. PROVIDE LVL SWITCH VENDOR MANUAL. PROVIDE LVL SWITCH VENDOR MANUAL. PROVIDE ACCIDENT ENVIRONMENT FOR LS AND ANY EQ INFORMATION. PROVIDE ACCIDENT ENVIRONMENT FOR LS AND ANY EQ INFORMATION. PROVIDE LORUS LEVEL CURVE FT³ VS. LEVEL. PROVIDE COPY CST LEVEL SWITCH VENDOR MANUAL.)-
071 072 073 074 075 076 077	 PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) UKI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE TT³ VALUE FOR THE SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (1) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (2) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, (3) WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? U3 TORUS: (1) PROVIDE NARROW RANGE LVL XMITTER INSTALLATION DRAWING. (2) PROVIDE XMITTER PIPING CONNECTION TO THE TORUS (TAP HEIGHT LOCATION). (3) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (4) PROVIDE XMITTER VENDOR MANUAL. (2) PROVIDE LVL SWITCH VENDOR MANUAL. (3) PROVIDE LVL SWITCH VENDOR MANUAL. (4) PROVIDE LVL SWITCH VENDOR MANUAL. (5) PROVIDE LORUS INSIDE DIMENSIONS (DRAWING IF AVAILABLE). (3) PROVIDE LORUS INSIDE DIMENSIONS (DRAWING IF AVAILABLE). (4) PROVIDE ACCIDENT ENVIRONMENT FOR LS AND ANY EQ INFORMATION. (4) PROVIDE COPY CST LEVEL SWITCH VENDOR MANUAL. (5) PROVIDE ACCIDENT ENVIRONMENT FOR LS AND ANY EQ INFORMATION. (4) PROVIDE COPY CST LEVEL SWITCH VENDOR MANUAL. (5) PROVIDE COPY CST LEVEL SWITCH VENDOR MANUAL. (6) PROVIDE COPY CST LEVEL SWITCH VENDOR MANUAL. (7) PROVIDE COPY CST LEVEL SWITCH VENDOR MANUAL. (8) PROVIDE COPY CST LEVEL SWITCH VENDOR MANUAL. (9) PROVIDE CST LS INSTALLATION DRAWING (WE HAVE M-310 SH 62))-
071 072 073 074 075 076 077	PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE HT ANALYTICAL LIMIT FOR THIS SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (3) DROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (1) DOES THIS INST. LOOP HAVE ANY ALRRM/CONTROL FUNCTIONS? (2) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, (3) WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? U3 TORUS: (1) PROVIDE NARROW RANGE LVL XMITTER INSTALLATION DRAWING. (2) PROVIDE XMITTER PIPING CONNECTION TO THE TORUS (TAP HEIGHT LOCATION). (3) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (4) PROVIDE XMITTER ENVIRONMENTAL CONDITIONS, SUCH AS HELB ENVIRONMENT. U3 TORUS HI LVL: (1) PROVIDE LVL SWITCH VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (4) PROVIDE XMITTER ENVIRONMENTAL CONDITIONS, SUCH AS HELB ENVIRONMENT. U3 TORUS HI LVL: (1) PROVIDE LVL SWITCH VENDOR MANUAL. (2) PROVIDE LVL SWITCH VENDOR MANUAL. (3) PROVIDE LVL SWITCH VENDOR MANUAL. (4) PROVIDE LVL SWITCH VENDOR MANUAL. (5) PROVIDE ACCIDENT ENVIRONMENT FOR LS AND ANY EQ INFORMATION. (4) PROVIDE ACCIDENT ENVIRONMENT FOR LS AND ANY EQ INFORMATION. (4) PROVIDE TORUS LEVEL CURVE FT ³ VS. LEVEL. (1) PROVIDE COPY CST LEVEL SWITCH VENDOR MANUAL. (2) PROVIDE COPY CST LEVEL SWITCH VENDOR MANUAL. (3) PROVIDE CST LS PIPING CONNECTION TO CST DRAWING (UP LOCATION). (4) PROVIDE CST LS PIPING CONNECTION TO CST DRAWING (OP LOCATION). (5) PROVIDE CST LS PIPING CONNECTION TO CST DRAWING (OP LOCATION). (6) PROVIDE CST LS PIPING CONNECTION TO CST DRAWING (TOP LOCATION). (7) PROVIDE CST LS PIPING CONNECTION TO CST DRAWING CONTENT OF THE DATA)-
071 072 073 074 075 076 077	<pre>PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE FT³ VALUE FOR THE SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. CST LVL INDICATION: (1) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (2) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE</pre>)-
071 072 073 074 075 076 077 078	<pre>PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/1&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/1&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/1&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE TAMASTER: (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (1) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (2) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, (3) WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? U3 TORUS: (1) PROVIDE NARROW RANGE LVL XMITTER INSTALLATION DRAWING. (2) PROVIDE XMITTER PIPING CONNECTION TO THE TORUS (TAP HEIGHT LOCATION). (3) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (4) PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (4) PROVIDE XMITTER VENDOR MANUAL. (2) PROVIDE LVL SWITCH VENDOR MANUAL. (3) PROVIDE LVL SWITCH VENDOR MANUAL. (4) PROVIDE LVL SWITCH VENDOR MANUAL. (5) PROVIDE LVL SWITCH VENDOR MANUAL. (6) PROVIDE LVL SWITCH VENDOR MANUAL. (7) PROVIDE LORUS INSIDE DIMENSIONS (DRAWING IF AVAILABLE). (8) PROVIDE CORUS LEVEL CURVE FT³ VS. LEVEL. (1) PROVIDE CORUS LEVEL SWITCH VENDOR MANUAL. (2) PROVIDE CORUS LEVEL CURVE FT³ VS. LEVEL. (3) PROVIDE CORUS LEVEL CURVE FT³ VS. LEVEL. (4) PROVIDE CORUS LEVEL SWITCH VENDOR MANUAL. (5) PROVIDE CORUS CST LEVEL SWITCH VENDOR MANUAL. (6) PROVIDE CST LS INSTALLATION DRAWING (WE HAVE M-310 SH 62) (3) PROVIDE CST LS ENVIRONMENTAL OPERATING CONDITIONS, SUCH AS TEMP. (4) PROVIDE CST LS ENVIRONMENTAL OPERATING CONDITIONS, SUCH AS TEMP. (5) TORUS NARROW RANGE LEVEL: (6) TORUS NARROW RANGE LEVEL: (7) TORUS NARROW RANGE LEVEL: (7) TORUS NARROW RANGE LEVEL: (7) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (8) TORUS NARROW RANGE LEVEL: (7) TORUS NARROW RA</pre>)-
071 072 073 074 075 076 077 078	PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE FT ³ VALUE FOR THE SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (5) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, (3) WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? U3 TORUS; (1) PROVIDE NARROW RANGE LVL XMITTER INSTALLATION DRAWING. (2) PROVIDE XMITTER PIPING CONNECTION TO THE TORUS (TAP HEIGHT LOCATION). (3) PROVIDE XMITTER PIPING CONNECTION TO THE TORUS (TAP HEIGHT LOCATION). (4) PROVIDE XMITTER ENVIRONMENTAL CODITIONS, SUCH AS HELB ENVIRONMENT. U3 TORUS HI LVL: (1) PROVIDE XMITTER ENVIRONMENTAL CODITIONS, SUCH AS HELB ENVIRONMENT. (2) PROVIDE XMITTER ENVIRONMENT FOR LS AND ANY EQ INFORMATION. (4) PROVIDE TORUS LEVEL CURVE FT ³ VS. LEVEL. (5) PROVIDE TORUS LEVEL CURVE FT ³ VS. LEVEL. (6) PROVIDE TORUS LEVEL CURVE FT ³ VS. LEVEL. (7) PROVIDE COT CONS LEVEL CURVE FT ³ VS. LEVEL. (8) PROVIDE CST LS PIFING CONNECTION TO TS TRANING (TOP LOCATION). (4) PROVIDE CST LS PIFING CONNECTION TO CST DRAWING (TOP LOCATION). (5) PROVIDE CST LS PIFING CONNECTION TO CST DRAWING (TOP LOCATION). (6) PROVIDE CST LS PIFING CONNECTION TO CST DRAWING (TOP LOCATION). (7) PROVIDE CST LS PIFING CONNECTION TO CST DRAWING (TOP LOCATION). (8) PROVIDE CST LS PIFING CONNECTION TO CST DRAWING (TOP LOCATION). (9) PROVIDE CST LS PIFING CONNECTION TO CST DRAWING (TOP LOCATION). (4) PROVIDE CST LS PIFING MENTAL OPERATING CONDITIONS, SUCH AS TEMP. U3 TORUS NARROW RANGE LEVEL: (1) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (2) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE)-
071 072 073 074 075 076 077 078	<pre>PROVIDE PROCEDURES QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE TAMSFER: (1) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (3) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, (3) WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? U3 TORUS; (1) PROVIDE XMITTER PIPING CONNECTION TO THE TORUS (TAP HEIGHT LOCATION). (3) PROVIDE XMITTER PIPING CONNECTION TO THE TORUS (TAP HEIGHT LOCATION). (4) PROVIDE XMITTER VENOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (4) PROVIDE XMITTER VENOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). (5) PROVIDE TORUS LEVEL CURVE FT3 VS. LEVEL. (1) PROVIDE TORUS LEVEL CURVE FT3 VS. LEVEL. (2) PROVIDE TORUS LEVEL CURVE FT3 VS. LEVEL. (3) PROVIDE TORUS LEVEL CURVE FT3 VS. LEVEL. (4) PROVIDE COPY CST LEVEL SWITCH VENDOR MANUAL. (5) PROVIDE COPY CST LEVEL SWITCH VENDOR MANUAL. (6) PROVIDE CST LS INSTICH ORDERNENTS (INCLUDE YABLED). (6) PROVIDE CST LS PIPING CONNECTION TO CST DRAWING (TOP LOCATION). (7) PROVIDE CST LS PIPING CONNECTION TO CST DRAWING (TOP LOCATION). (8) PROVIDE CST LS INSTLATION DRAWING (WE HAVE M-310 SH 62) (9) PROVIDE CST LS PIPING CONNECTION TO CST DRAWING (TOP LOCATION). (4) PROVIDE CST LS PIPING CONNECTION TO SUB THIS INST. LOOP TO MAKE ACCIDENT MITIGATION THE ARALYCONTROL FUNCTIONS? (2) USING EODY ABNORAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, (1) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (2) USING EODY ABNORAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE A</pre>)-
071 072 073 074 075 076 077 078	<pre>PROVIDE PROCEDURES QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-D5; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE TT VALUE FOR THE SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (5) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (1) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (2) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, (3) WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? U3 TORUS: (1) PROVIDE NARROW RANGE LVL XMITTER INSTALLATION DRAWING. (2) PROVIDE XMITTER PIPING CONNECTION TO THE TORUS (TAP HEIGHT LOCATION). (3) PROVIDE XMITTER PUPING CONNECTION TO THE TRONG STAP HEIGHT LOCATION). (4) PROVIDE XMITTER ENVIRONMENTAL CONDITIONS, SUCH AS HELB ENVIRONMENT. (1) PROVIDE XMITTER ENVIRONMENTAL CONDITIONS, SUCH AS HELB ENVIRONMENT. (3) PROVIDE XMITTER VENDOR MANUAL. (4) PROVIDE XMITTER ENVIRONMENT FOR LS AND ANY EQ INFORMATION. (5) PROVIDE TORUS INSIDE DIMENSIONS (DRAWING IF AVAILABLE). (6) PROVIDE TORUS LEVEL CURVE FT³ VS. LEVEL. (7) PROVIDE TORUS LEVEL SWITCH VENDOR MANUAL. (8) PROVIDE TORUS LEVEL SWITCH VENDOR MANUAL. (9) PROVIDE CST LS INSTALLATION DRAWING (WE HAVE M-310 SH 62) (6) PROVIDE CST LS PIPING CONNECTION TO CST DRAWING (TO LOCATION). (4) PROVIDE CST LS PIPING CONNECTION TO CST DRAWING (TO LOCATION). (5) PROVIDE CST LS ENVIRONMENTAL OPERATING CONDITIONS, SUCH AS TEMP. U3 TORUS NARROW RANGE LEVEL: U3 TORUS NARROW RANGE ANY ALARM/CONTROL FUNCTIONS? (2) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, (3) WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? (3) WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? (3) WHAT ARE THE LEVELS AND WHAT ARE TH</pre>)-
071 072 073 074 075 076 077 078 079	<pre>PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05: 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: (1) PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). (2) PROVIDE TY AULE FOR THE SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (3) PROVIDE THE ANALYTICAL LIMIT FOR THIS SETPOINT. (3) DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? (2) USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE</pre>)-
071 072 073 074 075 076 077 078 079	 PROVIDE PROCEDURES QE 16, QE 16.1, QE 72, QE 80, QE 80.1, TID-E/I&C-11 AND 12 AND ANY DRESDEN PROCEDURES THAT CONTROL SETPOINTS. (NOTE: TID-E/I&C-21 CORRECTS TYPOGRAPHICAL ERROR OF REQUESTED TD- E/I&C-12) URI 237/91038-05; 249/91042-05. SEE ATTACHED. TORUS HI LVL HPCI TRANSFER: PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). PROVIDE LS CALIBRATION PROCEDURE (FUNCTIONAL TEST WAS PROVIDED). PROVIDE FIT VALUE FOR THE SETPOINT. DOES THIS INST. LOOP HAVE ANY ALARM/CONTROL FUNCTIONS? USING EOPS/ABNORMAL OPERATING PROCEDURES, DOES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? TORUS: PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). PROVIDE XMITTER VENDOR MANUAL AND OTHER LOOP COMPONENTS (INCLUDE VENDOR MANUALS). PROVIDE XMITTER VENDOR MANUAL. PROVIDE XMITTER NOTROMENTAL CONDITIONS, SUCH AS HELB ENVIRONMENT. TORUS HI LVL: PROVIDE TOT ENVIRONMENTAL CONDITIONS, SUCH AS HELB ENVIRONMENT. TORUS HI LVL: PROVIDE TOTHE SINSED DIMENSIONS (DRAWING IF AVAILABLE). PROVIDE COPY CST LEVEL SWITCH VENDOR MANUAL. PROVIDE COPY CST LEVEL SWITCH VENDOR MANUAL. PROVIDE COPY CST LEVEL SWITCH VENDOR MANUAL. PROVIDE CST LS PIPING CONNECTION TO ST DEMATING (TOP LOCATION). PROVIDE CST LS PIPING CONNECTION TO ST DEMATING (TOP LOCATION). PROVIDE CST LS PIPING CONNECTION TO ST ET CONST PROVIDE CST LS PIPING CONNECTION TO ST DEAM MANUAL. PROVIDE CST LS PIPING CONNECTION TO ST DAWING (TOP LOCATION). PROVIDE CST LS PIPING CONNECTION TO ST DRAWING (TOP LOCATION). PROVIDE CST LS PIPING CONNECTION TO ST DES OPERATION'S USE THIS INST. LOOP TO MAKE ACCIDENT MITIGATION TYPE DECISIONS? IF YES, WHAT ARE THE LEVELS AND WHAT ARE THEIR ANALYTICAL LIMITS? <l< td=""><td>)-</td></l<>)-

•	

081	(2) PROVIDE CALIBRATION PROCEDURES AND VENDOR MANUALS FOR CST LI LOOP.
081	UPN TTEM 23/19105-06 (1) PROVIDE UNIT 2/3 DIESEL GENERATOR ROUND BOOK PG 22 (D/G ROOM TEMP)
	(2) PROVIDE UNIT 2/3 DIESEL GENERATOR ROOM TEMPERATURES FOR JUNE 1994.
082	OPN ITEM 237/91038-06
092	NEED TO DISCUSS UNIT 2/3 DIESEL GENERATOR ROOM TEMPERATURES WITH SYSTEM ENGINEER.
083	N92-06 & N92-06SI (IN), N90-28 (IN), N82-16 (IN).
	GL-92-04, N90-22 (ÌN), SIL 470 & SIL 47051 (ĠE TÉCH REP), N93-27 (IN).
084	OPEN ITEM 237/249/92028-03: HAVE OTHER PORCELAIN FUSE HOLDERS AND/OR OTHER FUSE HOLDER TYPES BEEN
085	VERIFIED THAT THE AVAILABLE FAULT CURRENT IS LESS THAN THE HOLDER 'WITHSTAND' RATING?
005	(1) IS THERE A PROGRAM TO ADDRESS NON-LIKE-FOR-LIKE FUSE DISCREPANCIES, PROVIDE INFORMATION?
	(2) HAVE INSTALLED FUSES AT DRESDEN BEEN WALKED DOWN AND VERIFIED AGAINST DESIGN DRAWINGS?
086	OPN ITEM 237/249/92028-03:
	 PROVIDE COORDINATION CORVE FOR BOSS NON 3 FOSE AND GE ITPE TER ISA CIRCUIT BAR. PROVIDE MAX FAULT CURRENT FOR CIPCUITS FUL THOUGH FULS IN PANEL 2/3-5400-105. (CR HVAC). REF.
	CALC 8772-14-19-19.
087	OPN ITEM 237/249/92028-03: S&L DISCREPANCY #D-92-150 IDENTIFIED THAT COORDINATION DID NOT EXIST
	BEIMEEN THE FUSES AND UPSTREAM CIRCUIT BRRS. THESE CIRCUITS ARE SAFETY RELATED. COULD THE OPENING OF
088	OPN ITEM 237/91038-06:
	(1) PROVIDE HIGHEST AFTERNOON DRESDEN OUTDOOR TEMPERATURE FOR EACH WEEK DURING JUNE 1994, INCLUDE
	DATE.
089	(2) WERE THE RX UNITS OPERATING DURING JUNE, 1994.
005	(1) PROVIDE COPY OF PROCEDURES OADMP-1 AND OADMP-1A.
	(2) PROVIDE LAST CALIBRATION RECORD FOR THE FOUR SBGT HEATER CURRENT SENSING RELAYS.
	(3) PROVIDE RELAY VENDOR MANUAL.
090	PROVIDE NRC INSP. REPORT NOS. THAT REVIEWED DRESDENS ATWS COMMITMENTS.
001	(1) PROVIDE DOP 6900-07 AND DAP 07-05
	(2) FOR THE PAST 6 MONTHS, PROVIDE A LIST OF ALL U2 AND U3 125 VDC GROUNDS THAT INITIATED ENTRY
	INTO DOP 6900-07, INCLUDE DATE AND POTENTIAL.
092	(3) FROWIDE CORRECTIVE ACTIONS FOR THE LIST AND DATE WHEN GROUND WAS REMOVED. OPN ITEM 237/91038-D68: FDG (2/3) ELECTRICAL RELAYS AND EXCITER ARE RATED FOR A MAXIMUM TEMP OF 122*F.
	(1) IS THIS TEMPERATURE EXTERNAL TO THE EQUIPMENT CABINETS OR AN INTERNAL CABINET TEMPERATURE.
	(2) WHAT IS A TYPICAL INTERNAL CABINET TEMP IN THE 2/3 EDG ROOM?
093	V10 23/1249/92026-02: (1) DDOVIDE FUSE DISCDERDANCY TRD: LIST BACK ONE YEAD
	(2) PROVIDE PROCEDURE DAP 11-27
094	V10 237/249/92028-02:
	(1) PROVIDE WR AND DCR PACKAGE THAT CHANGED OUT THE DG EXCITER CABINET 40A FUSE TO A 30A FUSE.
095 ·	PROVIDE (2) COPIES OF DRESEN ENVIRONMENTAL ZONE MAPS AND NOTES (DRESEN UFAR SECTION 3.11)
096	PROVIDE TORUS FT ³ VS LEVEL CURVE NOT SUPPLIED ON T-076.
097	PROVIDE COPIES OF IR DROP CALCULATIONS.
098	CALL 349-E-10 REV. 6 INDICATES TECHNICAL SPEC VALUES AS ANALYTICAL LIMITS. PROVIDE SOURCE OF THE CHARTITATIVE RASIS FOR ANALYTICAL THITS AND THEID MADGINS
099	CALC NO. 349-E-10 REV. 6 SEC. 5.5.1.18 INDICATES A TRIP UNIT CHANGE TO G.E. VENDOR DATA ATTACHED IS FOR
	A ROSEMONT TRIP UNIT. PLEASE CLARIFY.
100	CALC NO. 349-E-10 REV. 6 SEC. 5.5.12.1 IDENIIFIES A "HEAD CORRECTION", PROVIDE SOURCE OF THIS NUMBER AND HOW DETERMINED. (WAIKDOWN - INSTALLATION DWGS?)
101	(CALC 0349-E-30) PROVIDE REFS. 24,28,41,50 AND APPROPRIATE DESIGN BASIS DOCUMENTATION THAT SUPPORTS THE
	BASIS FOR THE ANALYTICAL LIMITS FOR RV LEVEL SETPOINTS.
102	(CALC 0349-E-30) PROVIDE INSTALLATION DETAILS OF RECORD; THESE APPEAR TO BE REF. 7,8,17. INSTALLATION DETAILS FOR LEVEL INSTRUMENTS SHOULD IDENTIFY LOCATION ADDANGEMENT INFRONTING (SLOPES INSTALLATION
	TOLERANCES, AND ELEVATIONS TRACEABLE TO TOP OF FUEL.
103	(CALC 0349-E-30) PROVIDE THE ANALYSIS SUPPORTING THE SIZING OF THE CONDENSING CHAMBERS THAT
104	DEMONSTRATES THE CHAMBERS WILL ACCOMMODATE THE TOTAL VOLUME DISPLACEMENT OF CONNECTED INSTRUMENTS.
104	(GRC 0349-C-30) FARA 3.3.1.12, 3.3.3 APPEARS TO INDICATE THAT RV LEVEL INSTRUMENTS ARE NOT REQUIRED TO Perform in A Harsh Environment. Why Arrivit the Environmental Feffers of Initiating Events Succe as
	LOCAS OR HELB - INCLUDED (EG FLASHING OF THE REFERENCE LEG)
105	(FSAR 9.2.6.5) WHY ISN'T THE AUTO TRANSFER OF HPCI SUCTION FROM THE CST (ON LOW CST LEVEL) TO THE
106	SUPPRESSION POOL IDENTIFIED IN THIS FSAR SECTION?
105	PROCEDURE IND-6/18C -10. PG 5. DEFINITION AST. IS THIS THE DIFFERENCE RETWEEN THE PROCESS OPERATIONAL
	LIMIT TRANSIENT AND THE POSITIVE SETPOINT TOLERANCE FOR A DECREASING TRIP AND NEGATIVE SETPOINT
	TOLERANCE FOR AN INCREASING TRIP?
108	PROVIDE AN ANALYSIS DEMONSTRATING THAT SUFFICIENT MARGIN FOR UNCERTAINTIES IN THE SUPPRESSION POOL HIGH
	PROVIDE THE BASIS FOR THE ANALYTICAL LIMIT (ACCIDENT ANALYSIS, VOLUME/LEVEL CALCULATIONS, ETC).
109	PROVIDE FOLLOWING REFERENCES IN CALC 349-E-10 REV. 6, ITEM 7: M-4023 SH. 1 & 2:
	ITEM 8: M-310 SHTS 28 & 38;
	ITEM II: ZOTANSDAM KEV. IU; ITEM II: NUS SKETCH SK-D349-M-001 REV. R.
110	HOW IS THE TRENDING DATA FOR INSTRUMENTS CURRENTLY APPLIED TO THE SETPOINT CALCULATIONS.
111	SCHEM. 12E-3430 SH. 1 REV. AP IDENTIFIES A CROSS REF. TO 12E-3769A FOR DEPICTION OF LIS 263-72A, BUT
	12E-3769A REV. S DOES NOT SHOW THE DEVICE. WHAT MAKE/MODEL NO. IS THE DEVICE, AND WHERE IS THIS INFO.
112	PROVIDE ACCESS TO EQ PACKAGE (COPY NOT NECESSARY) FOR REACTOR LOW WATER LEVEL INSTRUMENTATION.
113	SBGT M12-0-90-025:
	(1) WHY WAS THE DESIGN CHANGED TO TRIP ALL RX. BLDG. VENT & EXHAUST FANS, INCLUDING THE
	(2) IS THIS BECAUSE THE ISOLATION DAMPER CLOSURE CAUSED THE UNAFFECTED UNIT RX BLDG FANS TO LOSF
	SUCTION SOURCE?
114	SBGT M12-0-90-025: WHAT VENTILATION SOURCE WILL PROVIDE RX BLDG VENTILATION IN THE NON-ACCIDENT UNIT,
115	IF ALL THE RA DEUG FANS ARE TRIFFER CALC 0349-E-30 SUPPORTS A "NEW SETPOINT" (P. 85) OF 85.83 + 1 DEC AND 155.22 + 1 INC: HOWEVED. THE
-	CALIBRATION DATA SHEET, P.68 OF DIS 0500-03 REV. 13, ALLOWS A GREATER TOLERANCE (85.8 \pm 2 AND 155.2 \pm
	2). ALSO, "85.83 ± 1" IS NOT STATISTICALLY MEANINGFUL. PLEASE EXPLAIN.





1 " ¹		
•	116	SEE ATTACHED: M12-0-90-025 SBGT POST MOD PROCEDURES SP-91-2-29
	117	SP-91-1-12 Please make available for review the latest nprds/cfar reports (location, contact person, time etc.)
	118	PAST 3 YEARS. PLEASE MAKE AVAILABLE FOR REVIEW DESIGN BASIS DOCUMENTATION (FOR HPCI LPCI, ETC ~ PROVIDE A LISTING OF AVAILABLE DEDS UNDER RECONSTITUTION PROGRAM).
	119	MOD M12-2-91-22: PROVIDE DOCUMENTATION TO SUPPORT SEISMIC INSTALLATION OF RELAY CV 902-30/A1 INSTALLATION DWG M310 SH
	120 121	310 (HPCI VALVE M02-2301-10 INTERPOSING RELAY) MOD M12-2-91-22: NEED TO WALKDOWN RELAY CVAI INSTALLATION (HPCI VALVE M02-2301-10 INTERPOSING RELAY). PROVIDE METHOD TO ENSURE THAT CHANGES TO SURVEILLANCE PROCEDURES, SUCH AS MT&E AND SETTING TOLERANCES, WILL BE CONTROLLED AND REVIEWED AGAINST APPLICABLE CALCULATIONS SO THAT THE SETPOINT CALCULATION IS NOT
	122	INVALIDATED. PROVIDE ANALYTICAL LIMITS/ACCIDENT ANALYSIS LIMITS USED IN SAFETY ANALYSIS FOR TORUS – LO AND HI LEVEL AND BULK TEMPERATURE; HPCI/LPCI INITIATION – LO-LO (L2) LEVEL AND HI DRYWELL PRESS; AND RPS TRIP – L3, INCLUDE THE BASIS AND CALCULATION WHICH SUPPORTS THESE LIMITS.
	123 124	PROVIDE A COPY OF THE OPERABILITY ASSESSMENT PERFORMED FOR THE YARWAY LEVEL SWITCH DRIFT ISSUE. MOD P12-3-93-614:
		 IS IT COMMON PRACTICE TO GROUND THERMOCOUPLES? DURING AN ACCIDENT AND IF THE THERMOCOUPLES BECAME SUBMERGED, COULD GROUND CURRENTS (COMMON MODE CURRENTS) FLOW AND CAUSE FALSE INDICATION? HAVE GROUND CURRENTS BETWEEN TC AND RECORDER SYSTEM GROUND EVER CAUSED A PROBLEM? MOD P12-3-93-614: DOUTINE COMPLETED CODY OF DIE 1600 18 DEDEODMED ON OR ADOUND MADCH 8, 94.
	126	 (1) PROVIDE COMPLETED COPT OF DIS ISOCIA PERCOMPLETING ON A ROUND MARCH 3, 54; (2) WAS THIS SURVEILLANCE PERFORMED PRIOR TO COMPLETING THE CABLE/CONDUIT CHANGES? (3) ARE RECORDERS 1641-200 A/B CONSIDERED CLASS 1E? DIS 1600-18 SUPPRESSION FOOL TEMP. CAL:
		(1) WHO COMPARES I.20.C., PG 69, WITH I.5.C(2), PG 56, TO DETERMINE EACH TC INPUT IS FUNCTIONING SATISFACTORILY, FOLLOWING RESTORATION?
	127	SUPPRESSION POOL BULK TEMP: (1) SINCE THIS TEMP. IS TAKEN ONCE PER SHIFT, HOW WOULD AN OPEN/SHORTED TC INPUT AFFECT THE READING;
	128	(2) WOULD THE CHANNEL CHECK READILY DETECT THE MALFUNCTION AND/OR WOULD THE ALARM? SUPPRESSION POOL TEMP. TC: SUPPRESSION POOL TEMP. TC:
	100	 (1) HAS DRESDEN HAD ANT PROBLEMS WITH TO DEGRADATION DOE TO MATERIAL ENVIRONMENT IN THE TOROS: (2) IF SO, WOULD THE CHANNEL BULK TEMP. CHECK BE ABLE TO DISTINGUISH THIS DEGRADATION (CHANNEL CHECK SENSITIVITY)? DOUDDEDGE COD FOLLOWING INSTRUMENTS?
	129	PROVIDE ACCESS TO EQ BINDERS FOR FOLLOWING INSTRUMENTS LIS-003-0263-72A (RX LEVEL-YARWAY), LIS-003-1626-10 (TORUS), PS-003-1632-A (DRYWELL), PS-003-2360 (HPCI PUMP SUCTION), PS-003-2368-A (HPCI TURBINE EXH.); DPT 003-2352 (HPCI STM LINE FLOW) TS-003-2370-A (HPCI STEAM LEAK) PT-003-2389-A (LOW RX. PRESS/HPCI ISOL)
	130 131	PLEASE PROVIDE MISSING PAGES 27 AND 91 TO CALC NO 0349-E-10. Mod P12-2-93-601:
		 (1) PROVIDE JUSTIFICATION FOR ROTATING THE WATER SENSING LINE TEST TAP FLANGE BY 90°; (2) PROVIDE JUSTIFICATION THAT DETAIL 'B', DWG M310, SH 207, IS SEISMICALLY QUALIFIED; (3) PROVIDE TRANSMITTER (1153 DD5 RG) VENDOR MANUAL (V-205)
	132	DIS 1600-17, REV. 7, PG. 9, NOTE FOLLOWING STEP 8: DO IMS KNOW THEY ARE TO RECORD ROSEMOUNT XMIT. CALIB. MEASUREMENTS TO THREE DECIMAL PLACES? DATA SHEET 1 PG 24 (P12-2-92-601, 3/18/93) MEASURED TO TWO PLACES. WHAT OTHER PROCEDURES HAVE THE SAME NOTE?
	133 134	PROVIDE 0349-E-00, REV. 1, CECO RVWLIS MASTER CALC. (IF NOT TO LARGE, INCLUDE TWO COPIES) (FOLLOW UP ON RESPONSE TO JL-11 [N-105] OF 8/26/94) (1) THE CECO RESPONSE SAYS FUNCTION OF LIS-003-0263-72A, ET AL, IS TO "PROTECT AGAINST AN ACCIDENT CONDITION." HOWEVER, IT APPEARS THAT THESE INSTRUMENTS ARE REQUIRED TO INITIATE MITIGATION OF ACCIDENTS AFTER THEY HAVE OCCURRED. PLEASE CLARIFY THE ORIGINAL RESPONSE. SEE ATTACHED.
	135	(REF. M-310 SH 102 REV. 2) A) IS THERE A DRAWING SHOWING THE IMPULSE LINE ROUTING FOR THE DRYWELL PRESSURE INSTRUMENTS? B) PROVIDE ASSURANCE THAT THE LINES ARE PROPERLY SLOPED TO AVOID TRAPS OR LOOP SEALS. C) HOW IS THE DRYWELL END OF THE IMPULSE LINE PROTECTED FROM BLOCKAGE. ETC?
	136	D) HOW LONG IS THE IMPULSE LINE (LONGEST LINE) AND WHAT DIAMETER? PROVIDE INSTALLATION DETAILS FOR: PS-003-2360 (HPCI P. SUCTION); PS-003-2368 (HPCI TURBINE EXH); DPT-003-2370-A (HPCI STEAMLINE FLOW); TS-003-2370-A (HPCI STEAM LEAK DET.); PT-003-2380-A (HPCI STEAMLINE LOW RX PRESS); LS-003-2350-A (CST LEVEL). SHOULD SHOW PROCESS (PIPING, ETC.) INTERFACE AND INSTR. INSTALLATION. WHAT ARE APPROACH CONDITIONS TO
	137	FOLLOW INSTRUMENTS? (ARE FLOW ELEMENTS IN ALL UNINSTRUCTED STRAIGHT RUN OF PIPE.) (PROVIDE BASIS FOR TRIP SETTINGS FOR TOPIC ITEMS 8E, 9A, 10.1 AND 10.2C, WHICH DO NOT HAVE REFERENCED Calculations) when will these calculations be dedommen (tentative schedule). See attached
	138	 PROVIDE TRAINING PLAN (QUALIFICATIONS) FOR I&C ENGINEERS BOTH SITE AND CORPORATE. (09-02-94) MAKE AVAILABLE FOR REVIEW THE TRAINING RECORDS FOR I&C ENGINEERS. (COULD BE THE WEEK OF SEPT 12)
	139 140	PROVIDE INSTALLATION DETAILS FOR LT-002-0646 B, AND PS-002-1621B. DIS 1600-7 PERFORMED (05/01/94) DURING P12-3-93-614 (TORUS TEMP CONDUCTS): WHY DID SOMEONE CHANGE UNSAT TO SAT FOR TC 1641-205, TC 1641-208, TC 1641-213 AND TC 1641-214? I BELIEVE UNSAT FOLLOWS THE PROCEDURE AND CORRECTIVE ACTIONS WERE ADEQUATELY ANNOTATED.
	141 142	M12-3-89-24: PROVIDE CALIBRATION PROCEDURE/PM FOR TEMP INDICATOR 3-5741-19. DIS 0260-06 TABLE 1, PG. 117, LT-3-263-23B (ATMS LO LO LVL) PROVIDE THE SPAN SHIFT BIAS ADJUSTMENT
	143	SCALING USED TO ADJUST THE ZERU & SPAN CALIBRATION POINTS (ACTUAL SCALING DETERMINATION). IN RESPONSE TO N132 (DB-41): PROVIDE COPY OF PIF AND AN IDEA AS TO WHAT CORRECTIVE ACTIONS ARE GOING TO BE CONSIDERED AND WHEN TO COMPLETE THEM.
	144	WE UNDERSTAND ANALOG INSTRUMENTATION ASSOCIATED WITH TR 2-1641-200B FAILED WHEN POWER WAS TRANSFERRED FROM MAINTENANCE POWER TO NORMAL (UPS) POWER. A W.R. WAS WRITTEN 8-26-94, AND WE UNDERSTAND A PIF IS BEING DISPOSITIONED DIFASE POWURDS STATUS OF THE DIE OD OTHER ANTIONS BEING TAKEN
	145	SERVICE WATER AND OTHER PIPING (e.g., RBCCW LINES) ARE ROUTED IN THE AREA OF THE "CAGED" SAFETY RELATED INSTRUMENTS ON ELEV. 545'. WHAT ARE THE CONSEQUENCES OF A SINGLE PIPE BREAK IN THESE AREAS?
	146	WHAT ARE THE CONSEQUENCES OF A BREAK IN THE HEATING STEAM LINE(S) OVER CLASS IE PANELS 2203-73A (DIV. I) AND 2203-73B (DIV II) THAT ARE LOCATED IN U2? ARE THE LINES SEISMICALLY SUPPORTED?
	147	THE MOORE INDUSTRIES ISOLATION DEVICES IN THE CONTROL BOARD (FOR EXAMPLE, TORUS TEMP ISOL 943-237, - 238, -242A, -242B). AND ELSEWHERE, DO NOT PROVIDE SEPARATION OF CONNECTED INPUT, OUTPUT, AND EXCITATION

Q,

.

	WIRING. HOW DOES THIS CONFORM TO DRESDEN SEPARATION CRITERIA? WHAT IS THE QUALIFICATION BASIS FOR THE
140	ISOLATION DEVICES?
148	PROVIDE A GUIDED PLANT TOUR. CALC. 0349-E-30 DOES NOT APPEAR TO ADDRESS THE EFFECTS OF THE "BACKFILL MOD" (TO ADDRESS NON-
	CONDENSABLE GASES IN REF. LEG) ON THE COLD REFERENCE LEG CONFIGURATION, WITH RESPECT TO EFFECTS ON
150	ACCURACY. WHERE ARE THESE POTENTIAL EFFECTS EVALUATED AND ANALYZED? DROVIDE DEE 21 OF CALL DIAGE_30. CALL CA30_M_13 (DWULTS DEF LEG TEMP DISTRIBUTION)
151	SEE ATTACHED CONCERN #1 RE: POST MODIFICATION TESTING.
152	PLEASE PROVIDE THE FOLLOWING DOCUMENTS DIS 1600-18, NED-I-EIC-0251, NED-I-EIC-0089, NED-I-EIC-0090.
153	CECO/NUS DWG M-4025 SH 1, 2 (PIPING ISO FOR RV LEVEL INSTR) APC 6-30-93; PROVIDE BASIS/DISPOSITION OF "HOLD" STATUS AND DOCUMENTATION OF FILL VERIFICATION: FOLLOW-UP DOWID3 DESPONSE BE COND CHAMBER.
	[SPECIFIC QUESTIONS (A) THRU (D) ATTACHED]
154	THE RESPONSE TO N-112 APPEARS TO INDICATE THAT THERE IS NO SEISMIC OR ENVIRONMENTAL QUALIFICATION FOR
155	THE YARWAY INSTRUMENTS. IF SU, HOW IS THIS ALLEPTABLE. THE TRAINING MATERIAL PROVIDED IN RESPONSE TO N-101 REFLECTS A YARWAY CONDENSING CHAMBER AND IS AN
	OBSOLETE CONFIGURATION WHAT IS THE TRAINING DOCUMENTATION OF RECORD FOR THE NEW (COLD REFERENCE LEG)
156	INSTALLATION?
100	[POLLOW-UP ON RESPONSE TO THIS] THE RESPONSE TO THIS (RYMLIS CONDENSING CHAMBERS, ETC.) INCLUDED CONTRACTOR (NUS) RESPONSES TO VENDOR (GE) COMMENTS PROVIDE DOCUMENTATION OF THE RESOLUTION OF THESE
	RESPONSES; I.E. WAS G.E. AGREEABLE TO THE RESPONSES.
157	CALC NED-I-FIC-90 IN SECT 10 SUGGEST CHANGING THE SETPT OF PS 1621-B FLOW 53 IN WC + 1 TO 49 IN W.C. +
	TRIPSET AS 53 IN WOIL PLEASE CLARIFY CALC SECT 10.
158	SEE ATTACHED CONCERN #2, RE: SETPOINT TOLERANCES AND INCONSISTENCIES.
159	SEE ATTACHED CONCERN #3, RE: LACK OF ENGINEERING RIGOR.
160	HOW IS THE CALC, INFORMATION TO BE INCORPORATED INTO THE CALIBRATION PROC. FOR THE CHANGED SET PISY NO REFERENCE TO CALCS IS NOTED IN ANY CALIBRATION PROCEDURE OR DATA SHFFTSI (ENGINEERING CALC, INTERFACE
	TO CALIB. PROCEDURE) AND VICE VERSA.
161	PROVIDE LAST US RESPONSE TIME TEST OF THE RPS INSTRUMENTS IN TABLE 3.1.1 OF TECH SPECS.
162	ATTACHMENT 3 TO CALC. NED-I-ELC-91, NEV. 1 (4-10-93) IDENTIFIES THAT SOR CONSIDERS DRYMELL PRESSURE SWITCHES DS-2(3)-1632A-D. FT AL. AS COMMERCIAL GRADE, ALSO, GEN ASSIMPTION 2 DE CALC. STATES THAT
	SEISMIC QUALIF. IS NOT REQUIRED. THESE INSTRUMENTS PERFORM SAFETY FUNCTIONS. PROVIDE THE
	DOCUMENTATION SUPPORTING THEIR USE FOR SAFETY FUNCTIONS.
163	REVIEW OF SEVERAL CALCS REVEALS ONLY ASSUMED (VENDOR) DRAFT DATA WHEN ACTUAL DATA FROM MAINTENANCE -
	(1) WILL CALCS BE UPDATED TO REFLECT ACTUAL INSTRUMENT (DRIFT DATA) EXPERIENCE?
	(2) WILL SOMEONE VERIFY THAT VENDOR DRIFT INFO IS CONSERVATIVE TO ACTUAL DRIFT DATA?
164	SEE ATTACHED CONCERN #4, RE: ANALYTICAL LIMIT RETRIEVABILITY.
165	SEE ATTACHED CORCERN #3, RE: AFFELCATION OF INSTRUMENT ISOLATORS.
167	THE PROCESS USED TO "NORMALIZE" A VENDOR ACCURACY SPEC SEEMS QUESTIONABLE. REF. 1 STATES THAT A
	VENDOR'S 30 VALUE CAN BE DIVIDED BY 3 TO "NORMALIZE" IT TO A 10 VALUE. REF. 2(CALC) PARA 7.1.2 APPEARS
	TO INCORRECTLY APPLY AN ASSUMPTION (ASSUMPTION 9) TO THE PROCESS INSTRUMENT, NOT THE MIE, AND INCORRECTLY IMPROVE ACCURACY BY A FACTOR OF 2.
168	CALC 0349-E-30 REV. 3 (RVWLIS): ANSWER ATTACHED QUESTIONS (A) THRU (N) REGARDING BASIS FOR OATUM
160	POINTS AND OTHER ASSUMPTIONS/VALUES USED IN THE CALCULATION.
169	(1) PROVIDE RESULTS OF DRESDEN'S CONTACT TESTING PROGRAM. (2) HAVE ALL CONTACTS BEEN IDENTIFIED AND TESTED?
170	CALC 0349-E-30 OR E-10 FOR PT-263-20 A, B, C, D:
	(1) WHY WASN'T DRIFT, CAL ACCURACY AND MTE ACCURACY FIGURED IN THE SETPOINT DETERMINATION?
	(2) PROCEDURE DIS 020-06 USES AN MIE OF OF 10 10 100 UN OF 10 2000 PSIG HEISE GAUGE, HOW IS THE ACCURACY OF THE MTE (+ PSIG) MAINTAINED?
171	P12-3-93-208:
	(1) HAVE ATWS SETPOINT CALCS BEEN UPDATED TO REFLECT THE USE OF THE G.E. TRIP UNITS? (2) HAVE GE TRIP UNITS BEEN INSTAILED IN BOTH UNITS AND ADE THEY CONSIDERED DEEDABLE AT THIS
	(2) HAVE DE HAT UNITS BEEN INSTALLED IN BUT UNITS AND ARE THET CONSIDERED OFERADLE AT THIS
172	SEE ATTACHED CONCERN #6, RE: APPARENT LACK OF MARGIN BTWN DEOPS AND TECH SPEC.
173	
	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3
	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF <5" (HI LEVEL):
	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME.
174	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET).
174 175	 [REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS G 1.97 CAT 1 TYPE A VARIABLES. HOWEVER.
174 175	 [REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES
174 175	 [REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97
174 175	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATMS DWG 12F-7582C: SFE ATTACHED.
174 175 176 177	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATWS DWG 12E-7582C: SEE ATTACHED. DIS 0260-06 (REV. 1)
174 175 176 177	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATWS DWG 12E-7582C: SEE ATTACHED. DIS 0260-06 (REV. 1) (1) SHOULD ANN WINDOW #46, "ATWS LEVEL/PRESSURE ABNORMAL", BE VERIFIED IN THIS PROCEDURE OR IS IT VERTIFIED FORMERTS.
174 175 176 177	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATWS DWG 12E-7582C: SEE ATTACHED. DIS 0260-06 (REV. 1) (1) SHOULD ANN WINDOW #46, "ATWS LEVEL/PRESSURE ABNORMAL", BE VERIFIED IN THIS PROCEDURE OR IS IT VERIFIED SOMEWHERE ELSE? (2) STOP 40, 66 121 TRAIN A CHECKLIST. SHOULD A NOTE BE ADDED THAT THE RKPS TRIPS IN 9 SECONDS?
174 175 176 177	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATWS DWG 12E-7582C: SEE ATTACHED. DIS 0260-06 (REV. 1) (1) SHOULD ANN WINDOW #46, "ATWS LEVEL/PRESSURE ABNORMAL", BE VERIFIED IN THIS PROCEDURE OR IS IT VERIFIED SOMEWHERE ELSE? (2) STOP 40, 66, 121, TRAIN A CHECKLIST, SHOULD A NOTE BE ADDED THAT THE BKRS TRIPS IN 9 SECONDS? PROVIDE A DISCUSSION OF THE ROLES & DUTIES OF THE STATION M&TE COORDINATOR.
174 175 176 177 178 179	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATWS DWG 12E-7582C: SEE ATTACHED. DIS 0260-06 (REV. 1) (1) SHOULD ANN WINDOW #46, "ATWS LEVEL/PRESSURE ABNORMAL", BE VERIFIED IN THIS PROCEDURE OR IS IT VERIFIED SOMEWHERE ELSE? (2) STOP 40, 66, 121, TRAIN A CHECKLIST, SHOULD A NOTE BE ADDED THAT THE BKRS TRIPS IN 9 SECONDS? PROVIDE A DISCUSSION OF THE ROLES & DUTIES OF THE STATION M&TE COORDINATOR. PROVIDE LAST THREE CALIBRATIONS FOR TDRS;
174 175 176 177 178 179	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATWS DWG 12E-7582C: SEE ATTACHED. DIS 0260-06 (REV. 1) (1) SHOULD ANN WINDOW #46, "ATWS LEVEL/PRESSURE ABNORMAL", BE VERIFIED IN THIS PROCEDURE OR IS IT VERIFIED SOMEWHERE ELSE? (2) STOP 40, 66, 121, TRAIN A CHECKLIST, SHOULD A NOTE BE ADDED THAT THE BKRS TRIPS IN 9 SECONDS? PROVIDE A DISCUSSION OF THE ROLES & DUTIES OF THE STATION M&TE COORDINATOR. PROVIDE LAST THREE CALIBRATIONS FOR TDRS; 2-230-1028-1 AND 2-2330-102A-1; 2-595-117A, B, C, D; AND 3-150-105, 133, 182, 282. REFERENCE DVR 12- 2-90-102-22-2111; AND 12-32-2014 BESPECTIVELY
174 175 176 177 178 179 180	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (3) THE AL SUPPORTING THE CO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATWS DWG 12E-7582C: SEE ATTACHED. DIS 0260-06 (REV. 1) (1) SHOULD ANN WINDOW #46, "ATWS LEVEL/PRESSURE ABNORMAL", BE VERIFIED IN THIS PROCEDURE OR IS IT VERIFIED SOMEWHERE ELSE? (2) STOP 40, 66, 121, TRAIN A CHECKLIST, SHOULD A NOTE BE ADDED THAT THE BKRS TRIPS IN 9 SECONDS? PROVIDE LAST THREE CALIBRATIONS FOR TDRS; 2-2330-1028-1 AND 2-2330-102A-1; 2-595-117A, B, C, D; AND 3-150-105, 133, 182, 282. REFERENCE DVR 12- 2-90-160; 12-2-92-111; AND 12-3-92-014 RESPECTIVELY. PROVIDE PM THAT CHANGES OUT ENERGIZED AND DE-ENERGIZED AGASTAT GP RELAYS REFERENCE DVR 12-3-91-63 (249-
174 175 176 177 178 179 180	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATWS DWG 12E-7582C: SEE ATTACHED. DIS 0260-06 (REV. 1) (1) SHOULD ANN WINDOW #46, "ATWS LEVEL/PRESSURE ABNORMAL", BE VERIFIED IN THIS PROCEDURE OR IS IT VERIFIED SOMEWHERE ELSE? (2) STOP 40, 66, 121, TRAIN A CHECKLIST, SHOULD A NOTE BE ADDED THAT THE BKRS TRIPS IN 9 SECONDS? PROVIDE LAST THREE CALIBRATIONS FOR TDRS; 2-2330-102B-1 AND 2-2330-102A-1; 2-595-117A, B, C, D; AND 3-150-105, 133, 182, 282. REFERENCE DVR 12- 2-90-160; 12-2-92-111; AND 12-3-92-014 RESPECTIVELY. PROVIDE PM THAT CHANGES OUT ENERGIZED AGASTAT GP RELAYS REFERENCE DVR 12-3-91-63 (249- 200-91-06301)
174 175 176 177 178 179 180 181	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATWS DWG 12E-7582C: SEE ATTACHED. DIS 0260-06 (REV. 1) (1) SHOULD ANN WINDOW #46, "ATWS LEVEL/PRESSURE ABNORMAL", BE VERIFIED IN THIS PROCEDURE OR IS IT VERIFIED SOMEWHERE ELSE? (2) STOP 40, 66, 121, TRAIN A CHECKLIST, SHOULD A NOTE BE ADDED THAT THE BKRS TRIPS IN 9 SECONDS? PROVIDE A DISCUSSION OF THE ROLES & DUTIES OF THE STATION M&TE COORDINATOR. PROVIDE LAST THREE CALIBRATIONS FOR TDRS; 2-2330-102B-1 AND 2-2330-102A-1; 2-595-117A, B, C, D; AND 3-150-105, 133, 182, 282. REFERENCE DVR 12- 2-90-160; 12-2-92-111; AND 12-3-92-014 RESPECTIVELY. PROVIDE PM THAT CHANGES OUT ENERGIZED AND DE ENERGIZED AGASTAT GP RELAYS REFERENCE DVR 12-3-91-63 (249- 200-91-06301) PLEASE PROVIDE LAST 2 SURVEILLANCES FOR TORUS WR LEVEL (LT(3)-1641-5A/B) DRYWELL PRESSURE (PS-2-1632A, B) DRYWELL HIGH DEFSS (DS-2-1632A, D) THEN (TUD) THE TORUS WR LEVEL (LT(3)-1641-5A/B) DRYWELL PRESSURE (PS-2-1632A, B) DRYMELL HIGH DEFSS (DS-2-1632A, D) THEN (TUD) AND LEVEL (LT(3)-1641-5A/B) DRYWELL PRESSURE (PS-2-1632A, B) DRYMELL HIGH DEFSS (DS-2-1632A, D) THME (TUD) AND HER (TUD) AND HER SURPESSURE (PS-2-1632A, B) DRYMELL HIGH DEFSS (DS-2-1632A, D) THME (TUD) AND
174 175 176 177 178 179 180 181	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATWS DWG 12E-7582C: SEE ATTACHED. DIS 0250-06 (REV. 1) (1) SHOULD ANN WINDOW #46, "ATWS LEVEL/PRESSURE ABNORMAL", BE VERIFIED IN THIS PROCEDURE OR IS IT VERIFIED SOMEWHERE ELSE? (2) STOP 40, 66, 121, TRAIN A CHECKLIST, SHOULD A NOTE BE ADDED THAT THE BKRS TRIPS IN 9 SECONDS? PROVIDE A DISCUSSION OF THE ROLES & DUTIES OF THE STATION M&TE COORDINATOR. PROVIDE LAST THREE CALIBRATIONS FOR TDRS; 2-2330-102B-1 AND 2-2330-102A-1; 2-595-117A, B, C, D; AND 3-150-105, 133, 182, 282. REFERENCE DVR 12- 2-90-160; 12-2-92-111; AND 12-3-92-014 RESPECTIVELY. PROVIDE PM THAT CHANGES OUT ENERGIZED AND DE-ENERGIZED AGASTAT GP RELAYS REFERENCE DVR 12-3-91-63 (249- 200-91-06301) PLEASE PROVIDE LAST 2 SURVEILLANCES FOR TORUS WR LEVEL (LT(3)-1641-5A/B) DRYWELL PRESSURE (PS-2-1632A, B) DRYWELL HIGH PRESS (PS-2-1621-B) SUPPRESS POOL TEMP (TT-003-1641-222A, TY-3-1641-225A) RX LOW LVL (PS-2-263-52B)
174 175 176 177 178 179 180 181 182	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATWS DWG 12E-7582C: SEE ATTACHED. DIS 0260-06 (REV. 1) (1) SHOULD ANN WINDOW #46, "ATWS LEVEL/PRESSURE ABNORMAL", BE VERIFIED IN THIS PROCEDURE OR IS IT VERIFIED SOMEWHERE ELSE? (2) STOP 40, 66, 121, TRAIN A CHECKLIST, SHOULD A NOTE BE ADDED THAT THE BKRS TRIPS IN 9 SECONDS? PROVIDE A DISCUSSION OF THE ROLES & DUTIES OF THE STATION M&TE CORDINATOR. PROVIDE LAST THREE CALIBRATIONS FOR TDRS; 2-2330-102B-1 AND 2-2330-102A-1; 2-595-117A, B, C, D; AND 3-150-105, 133, 182, 282. REFERENCE DVR 12- 2-90-160; 12-2-92-111; AND 12-3-92-014 RESPECTIVELY. PROVIDE PM THAT CHANGES OUT ENERGIZED AND DE-ENERGIZED AGASTAT GP RELAYS REFERENCE DVR 12-3-91-63 (249- 200-91-06301) PLEASE PROVIDE LAST 2 SURVEILLANCES FOR TORUS WR LEVEL (LT(3)-1641-5A/B) DRYWELL PRESSURE (PS-2-1632A, B) DRYWELL HIGH PRESS (PS-2-1621-B) SUPPRESS POOL TEMP (TT-003-1641-222A, TY-3-1641-225A) RX LOW LVL (PS-2-263-52B) DEOP 200-1 APPEAR TO PROVIDE FOR A 0.5 IN MARGIN FOR INSTRUMENT ACCURACY FOR TORUS HI/LOW OPERATING DEOP 200-1 APPEAR TO PROVIDE FOR A 0.5 IN MARGIN FOR INSTRUMENT ACCURACY FOR TORUS HI/LOW OPERATING
174 175 176 177 178 179 180 181 182	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCV. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATWS DWG 12E-7582C: SEE ATTACHED. DIS 0260-06 (REV. 1) (1) SHOULD ANN WINDOW #46, "ATWS LEVEL/PRESSURE ABNORMAL", BE VERIFIED IN THIS PROCEDURE OR IS IT VERIFIED SOMEWHERE ELSE? (2) STOP 40, 66, 121, TRAIN A CHECKLIST, SHOULD A NOTE BE ADDED THAT THE BKRS TRIPS IN 9 SECONDS? PROVIDE A DISCUSSION OF THE ROLES & DUTIES OF THE STATION M&TE COORDINATOR. PROVIDE LAST THREE CALIBRATIONS FOR TORs; 2-230-1028-1 AND 2-2330-102A-1; 2-595-117A, B, C, D; AND 3-150-105, 133, 182, 282. REFERENCE DVR 12- 2-90-160; 12-2-92-111; AND 12-3-92-014 RESPECTIVELY. PROVIDE FM THAT CHANGES OUT ENERGIZED AND DE-ENERGIZED AGASTAT GP RELAYS REFERENCE DVR 12- 2-90-160; 12-2-92-111; AND 12-3-92-014 RESPECTIVELY. PROVIDE FM THAT CHANGES OUT ENERGIZED AND DE-ENERGIZED AGASTAT GP RELAYS REFERENCE DVR 12- 300-91-06301) PLEASE PROVIDE LAST 2 SURVEILLANCES FOR TORUS WR LEVEL (LT(3)-1641-5A/B) DRYWELL PRESSURE (PS-2-1632A, B) DRYWELL HIGH PRESS (PS-2-1621-B) SUPPRESS POOL TEMP (TT-003-1641-222A, TY-3-1641-225A) RX LOW LVL (PS-2-263-52B) DEOP 200-1 APPEAR TO PROVIDE FOR A 0.5 IN MARGIN FOR INSTRUMENT ACCURACY FOR TORUS HI/LOW OPERATING LIMITS (TS VALUES APPEAR TO PROVIDE FOR A 0.5 IN MARGIN FOR INSTRUMENT ACCURACY FOR TORUS HI/LOW OPERATING LIMITS (TS VALUES APPEAR TO PROVIDE FOR A 0.5 IN MARGIN FOR INSTRUMENT ACC
174 175 176 177 178 179 180 181 182 182	[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATWS DWG 12E-7582C: SEE ATTACHED. DIS 0260-06 (REV. 1) (1) SHOULD ANN WINDOW #46, "ATWS LEVEL/PRESSURE ABNORMAL", BE VERIFIED IN THIS PROCEDURE OR IS IT VERIFIED SOMEWHERE ELSE? (2) STOP 40, 66, 121, TRAIN A CHECKLIST, SHOULD A NOTE BE ADDED THAT THE BKRS TRIPS IN 9 SECONDS? PROVIDE A DISCUSSION OF THE ROLES & DUTIES OF THE STATION M&TE COORDINATOR. PROVIDE LAST THREE CALIBRATIONS FOR TDRs; 2-230-102B-1 AND 2-230-102A-1; 2-595-117A, B, C, D; AND 3-150-105, 133, 182, 282. REFERENCE DVR 12- 2-90-160; 12-2-92-111; AND 12-3-92-014 RESPECTIVELY. PROVIDE PM THAT CHANGES OUT ENERGIZED AND DE-ENERGIZED AGASTAT GP RELAYS REFERENCE DVR 12-3-91-63 (249- 200-91-06031) PLEASE PROVIDE LAST 2 SURVEILLANCES FOR TORUS WR LEVEL (LT(3)-1641-5A/B) DRYWELL PRESSURE (PS-2-1632A, B) DRWWELL HIGH PRESS (PS-2-1621-B) SUPPRESS POOL TEMP (TT-003-1641-222A, TY-3-1641-225A) RX LOW LVL (PS-2-263-52B) DEOP 200-1 APPEAR TO PROVIDE FOR A 0.5 IN MARGIN FOR INSTRUMENT ACCURACY FOR TORUS HI/LOW OPERATING LIMITS (TS VALUES APPEAR TO BE EQUIVALENT TO -1.0 IN AND -5IN, AND TS VALUES = AL VALUES) [1,2]. THERE IS NO CALC FOR THE N.R. TORUS LEVEL LINSTRUMENT ACCURACY FOR TORUS HI/LOW OPERATING LIMITS (TS VALUES APPEAR TO BE EQUIVALENT TO -1.0 IN AND -5IN, AND TS VALUES = AL VALUES) [1,2]. THERE IS NO CALC F
174 175 176 177 178 179 180 181 182 183	<pre>[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF <5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATWS DWG 12E-7582C: SEE ATTACHED. DIS 0260-06 (REV. 1) (1) SHOULD ANN WINDOW #46, "ATWS LEVEL/PRESSURE ABNORMAL", BE VERIFIED IN THIS PROCEDURE OR IS IT VERIFIED SOMEWHERE ELSE? (2) STOP 40, 66, 121, TRAIN A CHECKLIST, SHOULD A NOTE BE ADDED THAT THE BKRS TRIPS IN 9 SECONDS? PROVIDE A DISCUSSION OF THE ROLES & DUTIES OF THE STATION M&TE COORDINATOR. PROVIDE LAST THREE CALIBRATIONS FOR TDRS; 2-2330-1028-1 AND 2-2330-102A-1; 2-595-117A, B, C, D; AND 3-150-105, 133, 182, 282. REFERENCE DVR 12- 2-90-160; 12-2-92-111; AND 12-3-92-014 RESPECTIVELY. PROVIDE HM THAT CHANGES OUT ENERGIZED AND DE ENERGIZED AGASTAT GP RELAYS REFERENCE DVR 12-3-91-63 (249- 200-91-06301) PLEASE PROVIDE LAST 2 SURVEILLANCES FOR TORUS WR LEVEL (LT(3)-1641-54/B) DRYWELL PRESSURE (PS-2-1632A, B) DRYWELL HIGH PRESS (PS-2-1621-B) SUPPRESS POOL TEMP (TT-003-1641-222A, TY-3-1641-226A) RX LOW LVL (PS-2-263-52B) DEOP 200-1 APPEAR TO PROVIDE FOR A 0.5 IN MARGIN FOR INSTRUMENT ACCURACY FOR TORUS HI/LOW OPERATING LIMITS (TS VALUES APPEAR TO BE EQUIVALENT TO -1.0 IN AND -51N, AND TS VALUES = AL VALUES) [1,2]. THERE IS NO CALC FOR THE N.R. TORUS LEVEL INSTRUMENT. HOW IS IT KNOWN THAT THE ACCV. IS ADEQUATE? CALC NEO-1-EIC-096 IDENTIFIES TEMPERATURE LIMITS OF 180°F ON THE MERCOTO PS, BUT SHOWS AN ACCIDENT TEMP OF 230°F M</pre>
174 175 176 177 178 179 180 181 182 183	<pre>[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF ≤5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATWS DWG 12E-7582C: SEE ATTACHED. DIS 0260-06 (REV. 1) (1) SHOULD ANN WINDOW #46, "ATWS LEVEL/PRESSURE ABNORMAL", BE VERIFIED IN THIS PROCEDURE OR IS IT VERIFIED SOMEWHERE ELSE? (2) STOP 40, 66, 121, TRAIN A CHECKLIST, SHOULD A NOTE BE ADDED THAT THE BKRS TRIPS IN 9 SECONDS? PROVIDE LAST THREE CALIBRATIONS FOR TORS; 2-2330-102B-1 AND 2-2330-102A-1; 2-595-117A, B, C, D; AND 3-150-105, 133, 182, 262. REFERENCE DVR 12- 2-90-160; 12-2-92-111; AND 12-3-92-014 RESPECTIVELY. PROVIDE H THAT CHANGES OUT ENERGIZED AND DE-ENERGIZED AGASTAT GP RELAYS REFERENCE DVR 12- 3-90-160; 12-2-92-111; AND 12-3-92-014 RESPECTIVELY. PROVIDE LAST 2 SURVEILLANCES FOR TORUS WR LEVEL (LT(3)-1641-5A/B) DRYWELL PRESSURE (PS-2-1632A, B) DRYWELL HIGH PRESS (PS-2-1621-B) SUPPRESS POOL TEMP (TT-003-1641-222A, TY-3-1641-225A) RX LOW LVL (PS-2-263-52B) DEOP 200-1 APPEAR TO PROVIDE FOR A 0.5 IN MARGIN FOR INSTRUMENT ACCURACY FOR TORUS HI/LOW OPERATING LIMITS (TS VALUES APPEAR TO BE EQUIVALENT TO -1.0 IN AND -51N, AND TS VALUES > AL VALUES) [1,2]. THERE IS NO CALC FOR THE N.R. TORUS LEVEL INSTRUMENT. HOW IS IT KNOWN THAT THE ACCY. IS ADEQUATE? CALC NED-1-EIC-096 IDENTIFY OB EEQUIVALENT TO -1.0 IN MARGIN FOR INSTRUMENT ACCURACY FOR TORUS HI/LOW OPERATING LIMITS (TS VALUES APPEAR TO BE EQUIVALENT TO -1.0 IN AND -51</pre>
174 175 176 177 178 179 180 181 182 183 184	<pre>[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE TS TRIP LEVEL SETTING OF <5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATWS DWG 12E-7582C: SEE ATTACHED. DIS 0260-06 (REV. 1) (1) SHOULD ANN WINDOW #46, "ATWS LEVEL/PRESSURE ABNORMAL", BE VERIFIED IN THIS PROCEDURE OR IS IT VERIFIED SOMEWHERE ELSE? (2) STOP 40, 66, 121, TRAIN A CHECKLIST, SHOULD A NOTE BE ADDED THAT THE BKRS TRIPS IN 9 SECONDS? PROVIDE LAST THREE CALIBRATIONS FOR TDRs; 2-230-1028-1 AND 2-230-102A-1; 2-595-117A, B, C, D; AND 3-150-105, 133, 182, 282. REFERENCE DVR 12- 2-90-160; 12-2-92-111; AND 12-3-92-014 RESPECTIVELY. PROVIDE LAST THREE CALIBRATIONS FOR TORUS WR LEVEL (LT(3)-1641-54/B) DRYWELL PRESSURE (PS-2-1632A, B) DRYWELL HIGH PRESS (PS-2-1621-B) SUPPRESS POOL TEMP (TT-003-1641-222A, TY-3-1641-225A) RX LOW LVL (PS-2-263-52B) DEOP 200-1 APPEAR TO PROVIDE FOR A 0.5 IN MARGIN FOR INSTRUMENT ACCURACY FOR TORUS HI/LOW OPERATING LIMITS (TS VALUES APPEAR TO BE EQUIVALENT TO -1.0 IN AND -51 N, AND TS VALUES = AL VALUES) [1,2]. THERE IS NO CALC FOR THE N.R. TORUS LEVEL INSTRUMENT. HOR IS IT KNOWN THAT THE ACCY. IS ADEQUATE? CALC RED-1-EIC-096 IDENTIFIES TEMPERATURE LIMITS OF 160°F NO THE MERCOID PS, BUT SHOWS AN ACCIDENT TEMP IS.1. PLEASE CLARIFY. REFERENCE THE EQ FOR THE DEVICE. NED-1-EIC-096 DOES NOT IDENTIFY OR EVALUATE SEISMICCHFECTS. A) ARE THE MERCOID IN THE THE RESIS</pre>
174 175 176 177 178 179 180 181 182 183 184	<pre>[REF RESPONSES TO T-108, N-096, T-073, ET AL] THE RESPONSE TO T-108 IS NOT CLEAR. THERE ARE 3 ANALYTICAL LIMITS OF INTEREST: (1) THE AL SUPPORTING THE IS TRIP LEVEL SETTING OF <5" (HI LEVEL); (2) THE AL SUPPORTING THE MAX/MIN LCO FOR WATER VOLUME. (3) THE AL SUPPORTING THE LCO FOR MAX/MIN DOWNCOMER SUBMERGENCE. (CONTINUED ON ATTACHED SHEET). SEE ATTACHED CONCERN #7, RE: NO CALIBRATION PROCEDURES FOR CST & TORUS LEVEL SWITCHES. FSAR 7.5.1.1 IDENTIFIES SUPPRESSION POOL LEVEL AND TEMP AS RG 1.97 CAT 1 TYPE A VARIABLES. HOWEVER, THE TEMP ACCY. CALC [1] EXCLUDES SEISMIC EFFECTS AND THE LEVEL ACCY. CALC. [2] SELECTIVELY INCLUDES SEISMIC EFFECTS FOR CERTAIN INSTRUMENTS (E.G., RECORDER). THIS DOES NOT APPEAR TO CONFORM 40 RG 1.97 COMMITMENTS? ATWS DWG 12E-7582C: SEE ATTACHED. DIS 0260-06 (REV. 1) (1) SHOULD ANN WINDOW #46, "ATWS LEVEL/PRESSURE ABNORMAL", BE VERIFIED IN THIS PROCEDURE OR IS IT VERIFIED SOMEWHERE ELSE? (2) STOP 40, 66, 121, TRAIN A CHECKLIST, SHOULD A NOTE BE ADDED THAT THE BKRS TRIPS IN 9 SECONDS? PROVIDE A DISCUSSION OF THE ROLES & DUTIES OF THE STATION M&TE COORDINATOR. PROVIDE LAST THAEE CALIBRATIONS FOR TORS; 2-230-102B-1 AND 2-230-102A-1; 2-595-117A, B, C, D; AND 3-150-105, 133, 182, 282. REFERENCE DVR 12- 2-90-160; 12-2-92-111; AND 12-3-92-014 RESPECTIVELY. PROVIDE H THAT CHANGES OUT ENERGIZED AND DE-ENERGIZED AGASTAT GP RELAYS REFERENCE DVR 12- 3-90-16301) PLEASE PROVIDE LAST 2 SURVEILLANCES FOR TORUS WR LEVEL (LT(3)-1641-54/B) DRYWELL PRESSURE (PS-2-1632A, B) DRYWELL HIGH PRESS (PS-2-1621-B) SUPPRESS POOL TEMP (TT-003-1641-222A, TY-3-1641-225A) RX LOW LVL (PS-2-263-52B) DEOP 200-1 APPEAR TO PROVIDE FOR A 0.5 IN MARGIN FOR INSTRUMENT ACCURACY FOR TORUS HI/LOW OPERATING LIMITS (TS VALUES APPEAR TO BE EQUIVALENT TO -1.0 IN AND -51N, AND TS VALUES = AL VALUES) [1,2]. THERE IS NO CALC FOR THE N.R. TORUS LEVEL INSTRUMENT IN MIST IT KNOWN THAT THE ACCY. IS ADEQUATE? SALUES APPEAR TO BE EQUIVALENT TO -1.0 IN AND -51N, AND TS VALUES = AL VALUES) [1,2]. THERE IS NO CALC FOR THE N.R. TORUS LEVEL INST</pre>

185	NED-I-EIC-096 CONCLUSIONS (P. 39) DO NOT APPEAR TO IDENTIFY MARGIN TO SPURIOUS TRIP OF THE HPCI PUMP.
	WHAT IS THE DESIGN BASIS RANGE OF HPCI PUMP TURB, EXH PRESSURE AND HPCI PUMP SUCTION PRESSURE DURING ACCIDENT/EVENT CONDITIONS? WHAT IS MADEIN TO SUBJOIS TDIOS?
186	PLEASE PROVIDE THE TOP 50 TECHNICAL ISSUE LIST (WITH RESPONSIBLE PERSON ON EACH ITEM AND ACTIVE DUE
	DATE).
187	[NED-I-EIC-108] GEN ASSUMPTION 2=
	A) WHY ARE SEISMIC EFFECTS IGNORED? WHAT ABOUT AVOIDANCE OF SPURIOUS TRIP DURING SEISMIC EVENT?
	B) ARE THE INSTALLED DEVICES SEISMICALLY QUALIFIED?
188	[NED-1-EIC-108, DIS 2300-06]: WHERE TEMP. SWITCHES ARE USED TO DETECT AND RESPOND TO STEAM BREAKS (HIS
	IS ONE EXAMPLE), WHAT ARE THE RESPONSE TIME REQUIREMENTS AND HOW IS IT ASSURED THET WILL BE SATISFIED FOR DRA CONDITIONS? THE CALL AND TEST PROCEDURES DO NOT ADDRESS THIS DEDECOMMANCE
189	INFOLTED A CONTINUES. THE CARE AND TEST PROCEEDERS DO NOT ADDRESS INTO FEROMENACE.
100	SMALL"?
190	DIS 2300-1, REV. 12, 2-24-94, DATA SHEET 3 IDENTIFIES A SETPOINT LESS CONSERVATIVE (NEGATIVE MARGIN)
	THEN IDENTIFIED IN CALC NED-I-EIC-0111, REV. 2, 7/12/94. (THIS IS ANOTHER EXAMPLE FOR CONCERN #2)
191	[CALC NED-I-EIC-0111]
	(1) P. 5, PARAGRAPH 5A - WHAT IS BASIS FOR DIVIDING CAL TOLERANCE BY 3?
	(2) P. 5, PARAGRAPH 5B- ARE TEMPERATURE AND SEISMIC ERRORS CONSIDERED RANDOM? IF SO, HOW
102	JUSTIFIED: 100 101 0 DOWINE DESDONSE/ACTIONS TO ADDDESS TDACK #240.100.02-12001 AND 240.100.02.12002
193	LER 249/91-003: PROVIDE RESPONSE/ACTIONS TO ADDRESS TRACKING #249-200-91-03603 AND 249-200-91-03604.
194	LER 249/94-008: PROVIDE POLICY STATEMENT #12
195	NEED TO WALKDOWN TEMP ALTS.
	UNIT 2, 34–92 (DEGRADED VOLTAGE RELAY & AGASTAT TIMER)
	UNIT 2, 37-93 (CHART RECORDER FOR RX LEVEL 'A' NORMAL RANGE)
	UNIT 2, 50-93 (MONITOR AIR COMPRESSOR 2B 1AC PERFORMANCE)
196	LER 249/94008: CORRECTIVE ACTIONS INCLUDED CHANGING DAP 02-15, REV. 4, PG 3, POLICY E.3, TO REQUIRE
	THE STATION MANAGER OR DESIGNEE TO APPROVE CHANGING AN IRP LEVEL I OR 2 EVENT SCOPE & SCHEDULE, HOW
	DOES FLOW CHART F.2., PG 6, IMPLEMENT THE ABOVE? I DON'T SEE HOW A LVL 1 & 2 WILL GET TO THE PLANT
107	MANAGER. Desenves to (11-20) T-134
137	(1) WHAT IS THE BASIS CALC OD WHAT EVER FOR THE 2 MINUTE ENVIRONMENT THAT THE VARWAY HAS TO
	OPERATE IN?
	(2) WILL THE YARWAY BE ABLE TO PERFORM IT'S FUNCTION WITH OUT BEING QUALIFIED?



1

í , ,

₹,