

Commonwealth Edison Company
Dresden Generating Station
6500 North Dresden Road
Morris, IL 60450
Tel 815-942-2920

ComEd

June 6, 1995

TPJLTR 95-0063

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Licensee Event Report 92-045, Revision 03, Docket 50-237 is being submitted as required by Technical Specification 6.6 and 10CFR50.73(a)(2)(iv). This supplemental report deletes a commitment to implement a new trip setting at the condensate return side based on actual process temperatures. The supplement also identifies procedures changed to specify valve opening/closing sequence during startup/shutdown to minimize any pressure spikes sensed by the flow transmitter.

Sincerely,



Thomas P. Joyce
Site Vice President

TPJ/:pt

Enclosure

cc: J. Martin, Regional Administrator, Region III
NRC Resident Inspector's Office
File/NRC
File/Numerical

TPJ950063.95

9506140417 950606
PDR ADOCK 05000237
S PDR

A Unicom Company

IE22
||