

Commonwealth Edison Company  
Dresden Generating Station  
6500 North Dresden Road  
Morris, IL 60450  
Tel 815-942-2920

**ComEd**


June 6, 1995

TPJLTR 95-0064

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

Licensee Event Report 93-003, Revision 03, Docket 50-249 is being submitted as required by Technical Specification 6.6 and 10CFR50.73(a)(2)(iv). This supplemental report deletes a commitment to implement a new trip setting at the condensate return side based on actual process temperatures. The supplement also identifies procedures changed to specify valve opening/closing sequence during startup/shutdown to minimize any pressure spikes sensed by the flow transmitter.

Sincerely,



Thomas P. Joyce  
Site Vice President

TPJ/:pt

Enclosure

cc: J. Martin, Regional Administrator, Region III  
NRC Resident Inspector's Office  
File/NRC  
File/Numerical

9506140425	950606
PDR	ADDOCK 05000249
S	PDR

TPJ95\0064.95

*Handwritten initials and scribbles*