



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

August 16, 1995

Mr. D. L. Farrar  
Manager, Nuclear Regulatory Services  
Commonwealth Edison Company  
Executive Towers West III, Suite 500  
1400 OPUS Place  
Downers Grove, Illinois 60515

SUBJECT: RESOLUTION OF CORE SHROUD CRACKING AT DRESDEN, UNIT 3, AND QUAD CITIES, UNIT 1 (TAC NOS. M91298 AND 91299)

Dear Mr. Farrar:

During refueling outages in the spring of 1994, Commonwealth Edison Company (ComEd) discovered cracking in the circumferential welds in the core shrouds at Dresden, Unit 3, and Quad Cities, Unit 1. ComEd provided documentation for the NRC staff review and approval concluding that the cracked core shrouds could maintain margins against failure as specified in Section XI of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code (Code).

The NRC staff reviewed the ComEd analysis and by letter dated July 21, 1994, issued a safety evaluation (SE) which concluded that the cracked shrouds will satisfy ASME Code margins against weld failure for 15 months of operation above cold shutdown.

During the NRC staff review uncertainties were identified in the following parts of ComEd's analyses:

1. the sizing of the crack in the H5 weld;
2. the recirculation line break load analysis; and
3. core shroud movement under postulated accident loads assuming complete failure of the H5 weld.

The staff's independent evaluation used conservative assumptions to account for the uncertainties identified in ComEd's analyses; however, as discussed in Section 2.6 of the July 21, 1994, SE, ComEd was requested to provide the following confirmatory analyses to the NRC by December 15, 1994:

1. a computerized 3-dimensional asymmetric depressurization analysis for the recirculation line break, including assumptions and entry level conditions,

9508210185 950816  
PDR ADOCK 05000249  
P PDR

LEO1  
11  
AA3  
NRC FILE CENTER COPY

2. the WHAM calculations for the recirculation line break, including assumptions and entry level conditions, and
3. a detailed analysis of shroud movement, assuming a 360° through-wall crack, following postulated events, including all assumptions, entry level conditions, calculational techniques, and conservatisms. In your evaluation of seismic considerations, the analysis should be based on the most limiting seismic input motion (i.e., Golden Gate Park, time history, and El Centro, and Housner).

By letter dated September 2, 1994, November 15, 1994, and December 14, 1994, ComEd provided additional information to address each of the above uncertainties. The NRC staff has reviewed the above information, and based on the enclosed SE, the NRC staff finds the conclusion reached in our July 21, 1994, SE, that the cracked shrouds will satisfy ASME Code margins against weld failure for 15 months of operation above cold shutdown, remains valid. Satisfying the ASME Code margins against failure provides reasonable assurance that the core shrouds at Dresden, Unit 3, and Quad Cities, Unit 1, will remain intact even under postulated licensing basis and beyond licensing basis accident conditions. Therefore, Dresden, Unit 3, and Quad Cities, Unit 1, can continue to operate without undue risk to the public health and safety.

The NRC staff is currently reviewing plans for a permanent repair of the entire core shroud at Dresden and Quad Cities.

If you have any questions concerning this SE, please contact me at (301) 415-1345.

Sincerely,

Original signed by

John F. Stang, Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket Nos. 50-249 and 50-254

Enclosure: Safety Evaluation

cc w/encl: See next page

Distribution:

Docket File	PUBLIC
PDIII-2 r/f	JRoe (JWR)
EAdensam (EGA1)	RCapra
CMoore	JStang
OGC	ACRS (4)
PHiland, RIII	KKavanagh
JMedoff	JRajan
RPulsifer	

DOCUMENT NAME: DR91298.LTR

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	LA:PDIII-2	E	PM:PDIII-2	E	PM:PDIII-2	E	D:PDIII-2	E		
NAME	CMOORE		JSTANG avl		RPULSIFER		RCAPRA aoc			
DATE	08/15/95		08/16/95		08/16/95		08/16/95			

OFFICIAL RECORD COPY

D. L. Farrar  
Commonwealth Edison Company

Dresden Nuclear Power Station  
Unit Nos. 2 and 3  
Quad Cities Nuclear Power Station  
Unit Nos. 1 and 2

cc:

Michael I. Miller, Esquire  
Sidley and Austin  
One First National Plaza  
Chicago, Illinois 60603

Mr. Thomas P. Joyce  
Site Vice President  
Dresden Nuclear Power Station  
6500 North Dresden Road  
Morris, Illinois 60450-9765

Mr. J. Heffley  
Station Manager  
Dresden Nuclear Power Station  
6500 North Dresden Road  
Morris, Illinois 60450-9765

U.S. Nuclear Regulatory Commission  
Resident Inspectors Office  
Dresden Station  
6500 North Dresden Road  
Morris, Illinois 60450-9766

Regional Administrator  
U.S. NRC, Region III  
801 Warrenville Road  
Lisle, Illinois 60532-4351

Illinois Department of Nuclear Safety  
Office of Nuclear Facility Safety  
1035 Outer Park Drive  
Springfield, Illinois 62704

Chairman  
Grundy County Board  
Administration Building  
1320 Union Street  
Morris, Illinois 60450

Mr. Stephen E. Shelton  
Vice President  
Iowa-Illinois Gas and  
Electric Company  
P. O. Box 4350  
Davenport, Iowa 52808

Mr. L. William Pearce  
Station Manager  
Quad Cities Nuclear Power Station  
22710 206th Avenue North  
Cordova, Illinois 61242

U.S. Nuclear Regulatory Commission  
Quad Cities Resident Inspectors Office  
22712 206th Avenue North  
Cordova, Illinois 61242

Chairman  
Rock Island County Board  
of Supervisors  
1504 3rd Avenue  
Rock Island County Office Bldg.  
Rock Island, Illinois 61201

Warren Bilanin, EPRI Task Manager  
3412 Hillview Ave.  
Palo Alto, California 94303

Robin Dyle, Technical Chairman  
BWRVIP Assessment Task  
Southern Nuclear Operating Company  
Post Office Box 236  
40 Inverness Center Parkway  
Birmingham, Alabama 35201