



September 25, 1995

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: Dresden Nuclear Power Station Unit 2
Core Spray Flaw Evaluations
NRC Docket No. 50-237

Reference: P. Piet letter to U.S. NRC, dated September 12, 1995.

The purpose of this letter is to provide to the NRC staff Revision 1 to ComEd's evaluation of the core spray flaws observed at Dresden Unit 2, during the current refueling outage (D2R14). Attachment A provides Revision 1 of the Core Spray Flaw Evaluation Report. Attachment B provides Revision 1 of the Integrated Evaluation Report of the Core Spray Flaws. The revisions made do not affect the conclusions of the previous reports and represent the resolution of a non-design significant discrepancy in the evaluation of the Loop 'B' 260° collar. These revised evaluations continue to conclude that sufficient margin exists to operate for one cycle with the identified flaws. It should be noted that this submittal does not contain any proprietary information.

To the best of my knowledge and belief, the statements in this response are true and correct. In some respects, these statements are not based on my personal knowledge, but obtained information furnished by other ComEd employees, contractor employees, and consultants. Such information has been reviewed in accordance with company practice, and I believe it to be reliable.

k:nla:dresden:corespr.wpf:1

950925
9509270182 950925
PDR ADOCK 05000237
P PDR

A Unicom Company

ADD


September 25, 1995

If there are any questions regarding this submittal, please contact this office.

Sincerely,



Peter L. Piet
Nuclear Licensing Administrator



Mary Jo Yack 9-25-95

- Attachments: A. Dresden Unit 2 - Core Spray Flaw Evaluation Report, Rev. 1
B. Dresden Unit 2 - Integrated Evaluation Report of Core Spray Flaws, Rev. 1

cc: H.J. Miller, Regional Administrator - RIII
J.F. Stang, Project Manager - NRR
C.L. Vanderniet, Senior Resident Inspector - Dresden
Office of Nuclear Facility Safety - IDNS