

Distribution:

1. Boyer, Robert P
2. Gardner, Troy R
3. Howell, Pamela T
4. Mc Ginnis, Vickie L
5. OPS HUMAN PERFORMANCE -
6. OPS TRNG MGR.
7. QATS-
8. RESIDENT NRC INSPECT
9. SERV BLDG FILE ROOM -
10. U S NUC REG WASHINGTON, DC
11. USNRC
12. WESTINGHOUSE ELECTRIC CO LLC

Duke Energy DOCUMENT TRANSMITTAL FORM

Facility: **MCGUIRE NUCLEAR STATION**

SUBJECT

Issue TS 3.6.13 Amendment 292/271 & TS 3.6.14 Amendment 294/273

Page 1 of 1

Date: **6/26/2017**Document Transmittal #: **TR-NUC-MC-006433**Purpose: **Issue**

Released By:

Duke Energy**13225 Hagers Ferry Road****Document Management****MG02DM****Huntersville, NC 28078****MNSDCRM@duke-energy.com**

Document ID	1	2	3	4	5	6	7	8	9	10	11	12
LICN - MC - MNS-TS-3.6.13 - 001 - ISSUED	FYI E	FYI E	FYI E	FYI E	FYI E	R&A E	FYI E	PRINT LP	FYI E	R&A E	R&A E	R&A E
LICN - MC - MNS-TS-3.6.14 - 001 - ISSUED	FYI E	FYI E	FYI E	FYI E	FYI E	R&A E	FYI E	PRINT LP	FYI E	R&A E	R&A E	R&A E

Remarks:

ADDI
NRR

3.6 CONTAINMENT SYSTEMS

3.6.13 Ice Condenser Doors

LCO 3.6.13 The ice condenser lower inlet doors, intermediate deck doors, and top deck doors shall be OPERABLE and closed.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

-----NOTE-----

1. Separate Condition entry is allowed for each ice condenser door.
2. Entry into Condition B is not required due to personnel standing on or opening an intermediate deck or top deck door for short durations to perform required surveillances, minor maintenance such as ice removal or routine tasks such as system walkdowns.

CONDITION		REQUIRED ACTION	COMPLETION TIME
A.	One or more ice condenser lower inlet doors inoperable due to being physically restrained from opening.	A.1 Restore lower inlet door to OPERABLE status.	1 hour

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. One or more ice condenser doors inoperable for reasons other than Condition A or not closed.	B.1 Verify maximum ice bed temperature is $\leq 27^{\circ}\text{F}$.	Once per 4 hours
	<u>AND</u> -----NOTE----- Required Action B.2.1 applies only when one or more ice condenser lower inlet doors are inoperable due to having an invalid open alarm. -----	
	B.2.1 Verify affected lower inlet door is closed. <u>OR</u> B.2.2 Restore ice condenser door to OPERABLE status and closed positions.	Once per 14 days 14 days
C. Required Action and associated Completion Time of Condition B not met.	C.1 Restore ice condenser door to OPERABLE status and closed position.	48 hours
D. Required Action and associated Completion Time of Condition A or C not met.	D.1 Be in MODE 3.	6 hours
	<u>AND</u> D.2 Be in MODE 5.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.13.1 Verify all lower inlet doors indicate closed by the Inlet Door Position Monitoring System.	In accordance with the Surveillance Frequency Control Program
SR 3.6.13.2 Verify, by visual inspection, each intermediate deck door is closed and not impaired by ice, frost, or debris.	In accordance with the Surveillance Frequency Control Program
SR 3.6.13.3 Verify, by visual inspection, each top deck door: a. Is in place; and b. Has no condensation, frost, or ice formed on the door that would restrict its opening.	In accordance with the Surveillance Frequency Control Program
SR 3.6.13.4 Verify, by visual inspection, each lower inlet door is not impaired by ice, frost, or debris.	In accordance with the Surveillance Frequency Control Program
SR 3.6.13.5 Verify torque required to cause each lower inlet door to begin to open is ≤ 675 in-lb, and verify free movement of the door.	In accordance with the Surveillance Frequency Control Program
SR 3.6.13.6 (deleted)	
SR 3.6.13.7 Verify for each intermediate deck door: a. No visual evidence of structural deterioration; b. Free movement of the vent assemblies; and c. Free movement of the door.	In accordance with the Surveillance Frequency Control Program

3.6 CONTAINMENT SYSTEMS

3.6.14 Divider Barrier Integrity

LCO 3.6.14 Divider barrier integrity shall be maintained.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. -----NOTE----- For this action, separate Condition entry is allowed for each personnel access door or equipment hatch.</p> <p>One or more personnel access doors or equipment hatches (other than one pressurizer or one steam generator enclosure hatch addressed by Condition D) open or inoperable, other than for personnel transit entry.</p>	<p>A.1 Restore personnel access doors and equipment hatches to OPERABLE status and closed positions.</p>	<p>1 hour</p>
<p>B. Divider barrier seal inoperable.</p>	<p>B.1 Restore seal to OPERABLE status.</p>	<p>1 hour</p>
<p>C. Required Action and associated Completion Time not met.</p>	<p>C.1 Be in MODE 3. <u>AND</u> C.2 Be in MODE 5.</p>	<p>6 hours 36 hours</p>
<p>D. One pressurizer or one steam generator enclosure hatch open or inoperable.</p>	<p>D.1 Restore affected hatch to OPERABLE status and closed position.</p>	<p>48 hours</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.14.1 Verify, by visual inspection, all personnel access doors and equipment hatches between upper and lower containment compartments are closed.	Prior to entering MODE 4 from MODE 5
SR 3.6.14.2 Verify, by visual inspection, that the seals and sealing surfaces of each personnel access door and equipment hatch have: <ul style="list-style-type: none"> a. No detrimental misalignments; b. No cracks or defects in the sealing surfaces; and c. No apparent deterioration of the seal material. 	Prior to final closure after each opening <u>AND</u> -----NOTE----- Only required for seals made of resilient materials ----- In accordance with the Surveillance Frequency Control Program
SR 3.6.14.3 Verify, by visual inspection, each personnel access door or equipment hatch that has been opened for personnel transit entry is closed.	After each opening
SR 3.6.14.4 Remove two divider barrier seal test coupons and verify both test coupons' tensile strength is ≥ 39.7 lbs.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.6.14.5 Visually inspect $\geq 95\%$ of the divider barrier seal length, and verify:</p> <ul style="list-style-type: none">a. Seal and seal mounting bolts are properly installed; andb. Seal material shows no evidence of deterioration due to holes, ruptures, chemical attack, abrasion, radiation damage, or changes in physical appearance.	<p>In accordance with the Surveillance Frequency Control Program</p>